

II. Background

As a result of the lessons learned from the accident at the Fukushima Daichi Nuclear Power Plant, the U.S. Nuclear Regulatory Commission staff performed a systematic evaluation and inspection of selected fuel cycle facilities to (1) confirm that licensees are in compliance with regulatory requirements and facility-specific license conditions; and (2) to evaluate their readiness to address NPH events and other licensing basis events related to NPH. From December 2011 through May 2012, the staff conducted these inspections in accordance with NRC Temporary Instruction (TI) 2600/015, "Evaluation of Licensee Strategies for the Prevention and/or Mitigation of Emergencies at Fuel Facilities."

As a result of the TI inspection activities, the staff identified URI's related to Part 70 requirements and the current licensing basis of these facilities. The URIs document the need to further evaluate whether licensees are in compliance with regulatory requirements regarding accident sequences resulting from NPH. The staff is issuing this ISG to provide additional guidance for addressing accident sequences that may result from NPH. This ISG will be incorporated into future revisions of Appendix D of Chapter 3 of NUREG 1520, "Standard Review Plan for the Review of a License Application for a Fuel Cycle Facility" (ADAMS Accession No. ML020930033).

Dated at Rockville, Maryland, this 13th day of February, 2015.

For the Nuclear Regulatory Commission.

Craig Erlanger,

Deputy Director, Division of Fuel Cycle Safety, Safeguards, and Environmental Review, Office of Nuclear Material Safety and Safeguards.

[FR Doc. 2015-03764 Filed 2-23-15; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket Nos. 50-387 and 50-388; NRC-2012-0283]

PPL Susquehanna, LLC; Susquehanna Steam Electric Station, Units 1 and 2

AGENCY: Nuclear Regulatory Commission.

ACTION: License amendment application; withdrawal by applicant.

SUMMARY: The U.S. Nuclear Regulatory Commission (NRC) has granted the request of PPL Susquehanna, LLC to withdraw its application dated September 18, 2012, as supplemented

by letter dated May 10, 2013, for a proposed amendment to Renewed Facility Operating License Nos. NPF-14 and NPF-22 for the Susquehanna Steam Electric Station, Units 1 and 2. The proposed amendment would have changed Technical Specification (TS) Surveillance Requirements 3.8.1.9, 3.8.1.11, 3.8.1.12, and 3.8.1.19 in TS 3.8.1, "AC Sources—Operating." Specifically, the proposed amendments would increase the diesel generator (DG) acceptable minimum steady state voltage when operating in emergency/isochronous mode.

DATES: Notice of withdrawal of license amendment application given on February 24, 2015.

ADDRESSES: Please refer to Docket ID NRC-2012-0283 when contacting the NRC about the availability of information regarding this document. You may obtain publicly-available information related to this document using any of the following methods:

- Federal Rulemaking Web site: Go to <http://www.regulations.gov> and search for Docket ID NRC-2012-0283. Address questions about NRC dockets to Carol Gallagher; telephone: 301-415-3463; email: Carol.Gallagher@nrc.gov. For technical questions, contact the individual listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- NRC's Agencywide Documents Access and Management System (ADAMS): You may obtain publicly-available documents online in the ADAMS Public Documents collection at <http://www.nrc.gov/reading-rm/adams.html>. To begin the search, select "ADAMS Public Documents" and then select "Begin Web-based ADAMS Search." For problems with ADAMS, please contact the NRC's Public Document Room (PDR) reference staff at 1-800-397-4209, 301-415-4737, or by email to pdr.resource@nrc.gov. The ADAMS accession number for each document referenced in this document (if that document is available in ADAMS) is provided the first time that a document is referenced.

- NRC's PDR: You may examine and purchase copies of public documents at the NRC's PDR, Room O1-F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

FOR FURTHER INFORMATION CONTACT: Jeffrey A. Whited, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001; telephone: 301-415-4090, email: jeffrey.whited@nrc.gov.

SUPPLEMENTARY INFORMATION: The NRC has granted the request of PPL Susquehanna, LLC (the licensee) to

withdraw its application dated September 18, 2012 (ADAMS Accession No. ML12262A322), as supplemented by letter dated May 10, 2013 (ADAMS Accession No. ML13130A130), for a proposed amendment to the Susquehanna Steam Electric Station, Units 1 and 2, located in Luzerne County, Pennsylvania.

The proposed amendment would have changed TS Surveillance Requirements 3.8.1.9, 3.8.1.11, 3.8.1.12, and 3.8.1.19 in TS 3.8.1, "AC Sources—Operating." Specifically, the proposed amendments would increase the DG acceptable minimum steady state voltage when operating in emergency/isochronous mode.

The NRC published a Biweekly Notice in the **Federal Register** on November 27, 2012 (77 FR 70842), that gave notice that this proposed amendment was under consideration by the NRC. However, by letter dated December 22, 2014 (ADAMS Accession No. ML15022A013), the licensee requested to withdraw the proposed amendment.

Dated at Rockville, Maryland, this 9th day of February 2015.

For the Nuclear Regulatory Commission.

Jeffrey A. Whited,

Project Manager, Plant Licensing Branch I-2, Division of Operating Reactor Licensing, Office of Nuclear Reactor Regulation.

[FR Doc. 2015-03773 Filed 2-23-15; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket No. 50-334; NRC-2014-0180]

FirstEnergy Nuclear Operating Company; Beaver Valley Power Station, Unit 1

AGENCY: Nuclear Regulatory Commission.

ACTION: License amendment application; withdrawal by applicant.

SUMMARY: The U.S. Nuclear Regulatory Commission (NRC) has granted the request of FirstEnergy Nuclear Operating Company to withdraw its application dated July 30, 2013, for a proposed amendment to Renewed Facility Operating License No. DPR-66, for the Beaver Valley Power Station, Unit 1. The proposed amendment would authorize the implementation of § 50.61a of Title 10 of the *Code of Federal Regulations* (10 CFR), "Alternate Fracture Toughness Requirements for Protection Against Pressurized Thermal Shock Events," in lieu of the requirements located in 10 CFR 50.61, "Fracture Toughness

Requirements for Protection Against Pressurized Thermal Shock Events.”

DATES: Notice of withdrawal of license amendment application given on February 24, 2015.

ADDRESSES: Please refer to Docket ID NRC–2014–0180 when contacting the NRC about the availability of information regarding this document. You may obtain publicly-available information related to this document using any of the following methods:

- Federal Rulemaking Web site: Go to <http://www.regulations.gov> and search for Docket ID NRC–2014–0180. Address questions about NRC dockets to Carol Gallagher; telephone: 301–415–3463; email: Carol.Gallagher@nrc.gov. For technical questions, contact the individual listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- NRC’s Agencywide Documents Access and Management System (ADAMS): You may obtain publicly-available documents online in the ADAMS Public Documents collection at <http://www.nrc.gov/reading-rm/adams.html>. To begin the search, select “ADAMS Public Documents” and then select “Begin Web-based ADAMS Search.” For problems with ADAMS, please contact the NRC’s Public Document Room (PDR) reference staff at 1–800–397–4209, 301–415–4737, or by email to pdr.resource@nrc.gov. The ADAMS accession number for each document referenced in this document (if that document is available in ADAMS) is provided the first time that a document is referenced.

- NRC’s PDR: You may examine and purchase copies of public documents at the NRC’s PDR, Room O1–F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

FOR FURTHER INFORMATION CONTACT:

Taylor A. Lamb, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, DC 20555–0001; telephone: 301–415–7128, email: Taylor.Lamb@nrc.gov.

SUPPLEMENTARY INFORMATION:

The NRC has granted the request of FirstEnergy Nuclear Operating Company (the licensee) to withdraw its application dated July 30, 2013 (ADAMS Accession No. ML13212A027), for a proposed amendment to the Beaver Valley Power Station, Unit 1, located in Beaver County, Pennsylvania.

The proposed amendment would authorize the implementation of Title 10 of the *Code of Federal Regulations* (10 CFR) 50.61a, “Alternate Fracture Toughness Requirements for Protection Against Pressurized Thermal Shock Events,” in lieu of the requirements

located in 10 CFR 50.61, “Fracture Toughness Requirements for Protection Against Pressurized Thermal Shock Events.”

The NRC published a Biweekly Notice in the **Federal Register** on August 5, 2014 (79 FR 45476), that gave notice that this proposed amendment was under consideration by the NRC. However, by letter dated February 5, 2015 (ADAMS Accession No. ML15036A424), the licensee requested to withdraw the proposed amendment.

Dated at Rockville, Maryland, this 18th day of February 2015.

For the Nuclear Regulatory Commission.

Taylor A. Lamb,

Project Manager, Plant Licensing Branch I–2, Division of Operating Reactor Licensing, Office of Nuclear Reactor Regulation.

[FR Doc. 2015–03758 Filed 2–23–15; 8:45 am]

BILLING CODE 7590–01–P

NUCLEAR REGULATORY COMMISSION

[Docket Nos. 50–387 and 50–388; NRC–2012–0283]

PPL Susquehanna, LLC; Susquehanna Steam Electric Station, Units 1 and 2

AGENCY: Nuclear Regulatory Commission.

ACTION: License amendment application; withdrawal by applicant.

SUMMARY: The U.S. Nuclear Regulatory Commission (NRC) has granted the request of PPL Susquehanna, LLC to withdraw its application dated September 18, 2012, as supplemented by letter dated May 10, 2013, for a proposed amendment to Renewed Facility Operating License Nos. NPF–14 and NPF–22, for the Susquehanna Steam Electric Station, Units 1 and 2. The proposed amendment would have made changes to Technical Specification (TS) Surveillance Requirement (SR) 3.8.1.19 in TS 3.8.1 “AC Source—Operating.” Specifically, the proposed amendment would increase the minimum steady state frequency for Diesel Generator E during the loss of offsite power and emergency core cooling system surveillance.

DATES: Notice of withdrawal of license amendment application given on February 24, 2015.

ADDRESSES: Please refer to Docket ID NRC–2012–0283 when contacting the NRC about the availability of information regarding this document. You may obtain publicly-available information related to this document using any of the following methods:

- Federal Rulemaking Web site: Go to <http://www.regulations.gov> and search

for Docket ID NRC–2012–0283. Address questions about NRC dockets to Carol Gallagher; telephone: 301–415–3463; email: Carol.Gallagher@nrc.gov. For technical questions, contact the individual listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- NRC’s Agencywide Documents Access and Management System (ADAMS): You may obtain publicly-available documents online in the ADAMS Public Documents collection at <http://www.nrc.gov/reading-rm/adams.html>. To begin the search, select “ADAMS Public Documents” and then select “Begin Web-based ADAMS Search.” For problems with ADAMS, please contact the NRC’s Public Document Room (PDR) reference staff at 1–800–397–4209, 301–415–4737, or by email to pdr.resource@nrc.gov. The ADAMS accession number for each document referenced in this document (if that document is available in ADAMS) is provided the first time that a document is referenced.

- NRC’s PDR: You may examine and purchase copies of public documents at the NRC’s PDR, Room O1–F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

FOR FURTHER INFORMATION CONTACT:

Jeffrey A. Whited, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, DC 20555–0001; telephone: 301–415–4090, email: jeffrey.whited@nrc.gov.

SUPPLEMENTARY INFORMATION:

The NRC has granted the request of PPL Susquehanna, LLC (the licensee) to withdraw its application dated September 18, 2012 (ADAMS Accession No. ML12262A321), as supplemented by letter dated May 10, 2013 (ADAMS Accession No. ML13130A127), for a proposed amendment to the Susquehanna Steam Electric Station, Units 1 and 2, located in Luzerne County, Pennsylvania.

The proposed amendment would have made changes to TS SR 3.8.1.19 in TS 3.8.1 “AC Source—Operating.” Specifically, the proposed amendment would increase the minimum steady state frequency for Diesel Generator E during the loss of offsite power and emergency core cooling system surveillance.

The NRC published a Biweekly Notice in the **Federal Register** on November 27, 2012 (77 FR 70843), that gave notice that this proposed amendment was under consideration by the NRC. However, by letter dated December 22, 2014 (ADAMS Accession No. ML15022A013), the licensee requested to withdraw the proposed amendment.