

Electronic Access to This Document: The official version of this document is the document published in the **Federal Register**. Free Internet access to the official edition of the **Federal Register** and the Code of Federal Regulations is available via the Federal Digital System at: <http://www.gpo.gov/fdsys>. At this site you can view this document, as well as all other documents of this Department published in the **Federal Register**, in text or Adobe Portable Document Format (PDF). To use PDF you must have Adobe Acrobat Reader, which is available free at the site.

You may also access documents of the Department published in the **Federal Register** by using the article search feature at: <http://www.federalregister.gov>. Specifically, through the advanced search feature at this site, you can limit your search to documents published by the Department.

Dated: August 9, 2011.

Alexa Posny,

Assistant Secretary for Special Education and Rehabilitative Services.

[FR Doc. 2011-20607 Filed 8-11-11; 8:45 am]

BILLING CODE 4000-01-P

DEPARTMENT OF ENERGY

Environmental Management Site-Specific Advisory Board, Nevada

AGENCY: Department of Energy.

ACTION: Notice of open meeting.

SUMMARY: This notice announces a meeting of the Site-Wide Environmental Impact Statement (EIS) Committee of the Environmental Management Site-Specific Advisory Board (EM SSAB), Nevada. The Federal Advisory Committee Act (Pub. L. 92-463, 86 Stat. 770) requires that public notice of this meeting be announced in the **Federal Register**.

DATES: Wednesday, August 17, 2011, 2 p.m.

ADDRESSES: Nevada Site Office, 232 Energy Way, North Las Vegas, Nevada 89030.

FOR FURTHER INFORMATION CONTACT:

Denise Rupp, Board Administrator, 232 Energy Way, M/S 505, North Las Vegas, Nevada 89030. Phone: (702) 657-9088; Fax: (702) 295-5300 or e-mail: ntscab@nv.doe.gov.

SUPPLEMENTARY INFORMATION:

Purpose of the Board: The purpose of the Board is to make recommendations to DOE-EM and site management in the areas of environmental restoration, waste management, and related activities.

Purpose of the Committee: The purpose of the Committee is to review and prepare comments on the draft site-wide EIS.

Tentative Agenda: The Committee members will review and prepare comments on the draft site-wide EIS.

Public Participation: The EM SSAB, Nevada, welcomes the attendance of the public at its meetings and will make every effort to accommodate persons with physical disabilities or special needs. If you require special accommodations due to a disability, please contact Denise Rupp at least seven days in advance of the meeting at the phone number listed above. Written statements may be filed with the Committee either before or after the meeting. Individuals who wish to make oral presentations pertaining to agenda items should contact Denise Rupp at the telephone number listed above. The request must be received five days prior to the meeting and reasonable provision will be made to include the presentation in the agenda. The Deputy Designated Federal Officer is empowered to conduct the meeting in a fashion that will facilitate the orderly conduct of business. Individuals wishing to make public comments will be provided a maximum of five minutes to present their comments. This notice is being published less than 15 days prior to the meeting date due to programmatic issues that had to be resolved prior to the meeting date.

Minutes: Minutes will be available by writing to Denise Rupp at the address listed above or at the following *Web site*: <http://nv.energy.gov/nssab/MeetingMinutes.aspx>.

Issued at Washington, DC on August 9, 2011.

LaTanya R. Butler,

Acting Deputy Committee Management Officer.

[FR Doc. 2011-20590 Filed 8-11-11; 8:45 am]

BILLING CODE 6450-01-P

DEPARTMENT OF ENERGY

Office of Energy Efficiency and Renewable Energy

[Case No. CAC-033]

Decision and Order Granting a Waiver to Fujitsu General Limited From the Department of Energy Commercial Package Air Conditioner and Heat Pump Test Procedures

AGENCY: Office of Energy Efficiency and Renewable Energy, Department of Energy.

ACTION: Decision and Order.

SUMMARY: This notice publishes the U.S. Department of Energy's (DOE) Decision and Order in Case No. CAC-033, which grants Fujitsu General Limited (Fujitsu) a waiver from the existing DOE test procedures applicable to commercial package air-source central air conditioners and heat pumps. The waiver is specific to the Fujitsu AIRSTAGE V-II Variable Refrigerant Flow (VRF) multi-split commercial heat pump models specified in Fujitsu's petition for waiver. As a condition of this waiver, Fujitsu must use the alternate test procedure set forth in this notice to test and rate these AIRSTAGE V-II VRF multi-split commercial heat pumps.

DATES: This Decision and Order is effective August 12, 2011.

FOR FURTHER INFORMATION CONTACT: Dr. Michael G. Raymond, U.S. Department of Energy, Building Technologies Program, Mailstop EE-2J, 1000 Independence Avenue, SW., Washington, DC 20585-0121. Telephone: (202) 586-9611. E-mail: Michael.Raymond@ee.doe.gov.

Ms. Elizabeth Kohl, U.S. Department of Energy, Office of the General Counsel, Mail Stop GC-71, Forrestal Building, 1000 Independence Avenue, SW., Washington, DC 20585-0103. Telephone: (202) 586-7796. E-mail: Elizabeth.Kohl@hq.doe.govmailto:.

SUPPLEMENTARY INFORMATION: In accordance with Title 10 of the Code of Federal Regulations (10 CFR) 431.401(f)(4), DOE provides notice of the issuance of the Decision and Order set forth below. In this Decision and Order, DOE grants Fujitsu a waiver from the existing DOE commercial package air conditioner and heat pump test procedures for the basic models of AIRSTAGE V-II multi-splits set forth in its petition. DOE also requires the use of an alternate test procedure for this equipment. Fujitsu must use American National Standards Institute/Air-Conditioning, Heating and Refrigeration Institute (ANSI/AHRI) Standard 1230-2010, "Performance Rating of VRF Multi-Split Air-Conditioning and Heat Pump Equipment" to test and rate the models of AIRSTAGE V-II VRF multi-split commercial heat pumps identified below. The cooling capacities of these models range from 72,000 Btu/h to 288,000 Btu/h.

Today's decision prohibits Fujitsu from making any representations concerning the energy efficiency of these products unless the product has been tested consistent with the provisions and restrictions in the alternate test procedure set forth in the Decision and Order below, and the