

Dated at Rockville, Maryland, this 5th day of July, 2011.

For the Nuclear Regulatory Commission.

Harriet Karagiannis,

Acting Chief, Regulatory Guide Development Branch, Division of Engineering, Office of Nuclear Regulatory Research.

[FR Doc. 2011-17441 Filed 7-11-11; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[NRC-2011-0006]

Sunshine Federal Register Notice

AGENCY HOLDING THE MEETINGS: Nuclear Regulatory Commission.

DATE: Weeks of July 11, 18, 25, August 1, 8, 15, 2011.

PLACE: Commissioners' Conference Room, 11555 Rockville Pike, Rockville, Maryland.

STATUS: Public and Closed.

Week of July 11, 2011

Tuesday, July 12, 2011

9:30 a.m. Briefing on the NRC Actions for Addressing the Integrated Regulatory Review Service (IRRS) Report (Public Meeting (Contact: Jon Hopkins, 301-415-3027).

This meeting will be webcast live at the Web address—<http://www.nrc.gov>.

Week of July 18, 2011—Tentative

Tuesday, July 19, 2011

9:30 a.m. Briefing on the Task Force Review of NRC Processes and Regulations Following Events in Japan (Public Meeting) (Contact: Nathan Sanfilippo, 301-415-3951).

This meeting will be webcast live at the Web address—<http://www.nrc.gov>.

Week of July 25, 2011—Tentative

Thursday, July 28, 2011

9 a.m. Briefing on Severe Accidents and Options for Proceeding with Level 3 Probabilistic Risk Assessment Activities (Public Meeting) (Contact: Daniel Hudson, 301-251-7919).

This meeting will be webcast live at the Web address—<http://www.nrc.gov>.

Week of August 1, 2011—Tentative

There are no meetings scheduled for the week of August 1, 2011.

Week of August 8, 2011—Tentative

There are no meetings scheduled for the week of August 8, 2011.

Week of August 15, 2011—Tentative

There are no meetings scheduled for the week of August 15, 2011.

* * * * *

* The schedule for Commission meetings is subject to change on short notice. To verify the status of meetings, call (recording)—(301) 415-1292. Contact person for more information: Rochelle Baval, (301) 415-1651.

* * * * *

The NRC Commission Meeting Schedule can be found on the Internet at: <http://www.nrc.gov/public-involve/public-meetings/schedule.html>.

* * * * *

The NRC provides reasonable accommodation to individuals with disabilities where appropriate. If you need a reasonable accommodation to participate in these public meetings, or need this meeting notice or the transcript or other information from the public meetings in another format (e.g. braille, large print), please notify Bill Dosch, Chief, Work Life and Benefits Branch, at 301-415-6200, TDD: 301-415-2100, or by e-mail at william.dosch@nrc.gov. Determinations on requests for reasonable accommodation will be made on a case-by-case basis.

* * * * *

This notice is distributed electronically to subscribers. If you no longer wish to receive it, or would like to be added to the distribution, please contact the Office of the Secretary, Washington, DC 20555 (301-415-1969), or send an e-mail to darlene.wright@nrc.gov.

Dated: July 7, 2011.

Rochelle C. Baval,

Policy Coordinator, Office of the Secretary.

[FR Doc. 2011-17574 Filed 7-8-11; 11:15 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket Nos. 50-272 and 50-311; NRC-2009-0390]

PSEG Nuclear, LLC, Salem Nuclear Generating Station, Units 1 and 2; Notice of Issuance of Renewed Facility Operating License Nos. DPR-70 and DPR-75 for an Additional 20-Year Period

Notice is hereby given that the U.S. Nuclear Regulatory Commission (the Commission) has issued Renewed Facility Operating License Nos. DPR-70 and DPR-75 to PSEG Nuclear LLC (the licensee), the operator of the Salem Nuclear Generating Station, Units 1 and

2 (Salem). Renewed Facility Operating License Nos. DPR-70 and DPR-75 authorize the licensee to operate Salem at reactor core power levels not in excess of 3,459 megawatts thermal in accordance with the provisions of the Salem renewed license and its technical specifications.

The notice also serves as the record of decision for the renewal of Facility Operating License Nos. DPR-70 and DPR-75, consistent with Title 10 of the *Code of Federal Regulations* (10 CFR) 51.103, "Record of Decision—General." As discussed in the final supplemental environmental impact statement for Salem (NUREG-1437, Supplement 45, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants, Supplement 45, Regarding Hope Creek Generating Station and Salem Nuclear Generating Station, Units 1 and 2, Final Report," issued March 2011), the Commission has considered a range of reasonable alternatives that included generation from coal-fired generation, natural gas combined-cycle generation, a combined alternative, and the no-action alternative. The factors considered in the record of decision can be found in the supplemental environmental impact statement for Salem.

Salem's units are pressurized-water reactors located in Lower Alloways Creek Township, Salem County, NJ. The application for the renewed license complied with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations. As required by the Act and the Commission's regulations in 10 CFR Chapter I, "Nuclear Regulatory Commission," the Commission has made appropriate findings, which are set forth in the license. Prior public notice of the action involving the proposed issuance of the renewed license and of an opportunity for a hearing regarding the proposed issuance of the renewed license was published in the **Federal Register** on October 23, 2009 (74 FR 54854).

For further details with respect to this action, see (1) PSEG Nuclear LLC's license renewal application for Salem Nuclear Generating Station, Units 1 and 2, dated August 18, 2009, as supplemented by letters dated through May 18, 2011, (2) the Commission's safety evaluation report (NUREG-2101, "Safety Evaluation Report Related to the License Renewal of the Salem Nuclear Generating Station," issued June 2011), (3) the licensee's updated safety analysis report, and (4) the Commission's final environmental impact statement (NUREG-1437, Supplement 45), for Salem, published in March 2011. These

documents are available at the NRC's Public Document Room, One White Flint North, 11555 Rockville Pike, Rockville, MD 20852, and are available online in the NRC Library at <http://www.nrc.gov/reading-rm.html>.

Copies of Renewed Facility Operating License Nos. DPR-70 and DPR-75 may be obtained by writing to the U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention: Director, Division of License Renewal. Copies of the safety evaluation report for Salem (NUREG-2101) and the final environmental impact statement (NUREG-1437, Supplement 45) may be purchased from the National Technical Information Service, U.S. Department of Commerce, Springfield, VA 22161 (<http://www.ntis.gov>), 703-605-6000, or Attention: Superintendent of Documents, U.S. Government Printing Office, P.O. Box 371954, Pittsburgh, PA 15250-7954 (<http://www.gpoaccess.gov>), 202-512-1800. All orders should clearly identify the NRC publication number and the requestor's Government Printing Office deposit account number or VISA or MasterCard number and expiration date.

Dated at Rockville, Maryland, this 30th day of June, 2011.

For the Nuclear Regulatory Commission.

Bo M. Pham,

Chief, Projects Branch 1, Division of License Renewal, Office of Nuclear Reactor Regulation.

[FR Doc. 2011-17443 Filed 7-11-11; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket No. 50-225; NRC-2008-0277]

Rensselaer Polytechnic Institute Critical Experiments Facility; Notice of Issuance of Renewed Facility Operating License No. CX-22

The U.S. Nuclear Regulatory Commission (NRC, the Commission) has issued renewed Facility Operating License No. CX-22, held by the Rensselaer Polytechnic Institute (the licensee), which authorizes continued operation of the Rensselaer Polytechnic Institute Critical Experiments Facility (RCF), located in Schenectady, Schenectady County, New York. The RCF is a tank-type, light-water-moderated, critical facility licensed to operate at steady-state power levels up to and including 100 watts thermal power. The renewed Facility Operating License No. CX-22 will expire at midnight 20 years from its date of issuance.

The renewed facility operating license complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the NRC's regulations in Title 10 of the *Code of Federal Regulations* (10 CFR), and sets forth those findings in the renewed facility operating license. The agency afforded an opportunity for hearing in the Notice of Opportunity for Hearing published in the **Federal Register** on May 15, 2008 (73 FR 28170). The NRC received no request for a hearing or petition for leave to intervene.

The NRC staff prepared a safety evaluation report for the renewal of Facility Operating License No. CX-22 and concluded, based on that evaluation, that the licensee can continue to operate the facility without undue risk to the health and safety of the public. The NRC staff also prepared an Environmental Assessment and Finding of No Significant Impact for license renewal, noticed in the **Federal Register** on June 14, 2011 (76 FR 34770), and concluded that renewal of the facility operating license will not have a significant impact on the quality of the human environment.

For details with respect to the application for renewal, see the licensee's letter dated November 19, 2002 (ML023380455 and ML072210835), as supplemented on July 21 (ML082060048), July 28 (ML082190523), and September 3, 2008 (ML101260200); June 28 (ML101820298), August 31 (ML102790045), October 14 (ML103070074), and October 28, 2010 (ML103080207); and February 14 (ML110490531) and May 9, 2011 (ML11131A180). Documents may be examined, and/or copied for a fee, at the NRC's Public Document Room (PDR), located at One White Flint North, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible electronically from the Agencywide Documents Access and Management System (ADAMS) Public Electronic Reading Room on the NRC Web site, <http://www.nrc.gov/reading-rm/adams.html>. Persons who do not have access to ADAMS or who encounter problems in accessing the documents located in ADAMS should contact the NRC PDR Reference staff at 1-800-397-4209 or 301-415-4737, or send an e-mail to pdr.resource@nrc.gov.

Dated at Rockville, Maryland, this 27th day of June, 2011.

For the Nuclear Regulatory Commission.

Jessie Quichocho,

Chief, Research and Test Reactors Licensing Branch, Division of Policy and Rulemaking, Office of Nuclear Reactor Regulation.

[FR Doc. 2011-17440 Filed 7-11-11; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[NRC-2011-0150; Docket Nos. 50-003, 50-247, and 50-286; License Nos. DPR-5, DPR-26, and DPR-64]

Entergy Nuclear Indian Point 2, LLC, Entergy Nuclear Indian Point 3, LLC, Entergy Nuclear Operations, Inc.; Receipt of Request for Action

Notice is hereby given that by petition dated March 28, 2011, Eric T. Schneiderman, Attorney General for the State of New York, the petitioner, has asked the U.S. Nuclear Regulatory Commission (NRC) to take enforcement action against Entergy Nuclear Operations, Inc. (Entergy), and its affiliates for violations of the agency's 1980 fire safety regulations at Indian Point Nuclear Generating Unit 1, 2, and 3. The petitioner asked the NRC to take immediate action by issuing an order that requires the following actions:

- Identify the violations of paragraphs F and G of Section III of Appendix R, "Fire Protection Program for Nuclear Power Facilities Operating prior to January 1, 1979," to Title 10 of the *Code of Federal Regulations* (10 CFR) part 50, "Domestic Licensing of Production and Utilization Facilities," that exist as of the date of the petition (i.e., March 28, 2011) at Indian Point Units 1, 2, and 3.
- Compel Entergy and its affiliates to comply on or before September 20, 2011, with the requirements in paragraphs F and G for all the fire zones in Indian Point Units 2 and 3 and any Indian Point Unit 1 fire zone or system, structure, or component relied on by Indian Point Units 2 and 3.
- Convene an evidentiary hearing before the Commission to adjudicate the violations by Entergy and its affiliates of paragraphs F and G at Indian Point Units 1, 2, and 3.

As the basis for the request, the petitioner stated, in part, the following:

- The petitioner cited the population centers adjacent to the Indian Point facility. The petitioner described past investigations by both the NRC Office of Investigations and the Government Accountability Office on fire barriers, most specifically Thermo-Lag and Hemyc. The petitioner implied that the NRC staff has not been aggressive in resolving fire barrier issues or in taking