

V. Program: Role of Museums and Libraries in Serving Diverse Communities

Dr. Robert S. Martin, Director IMLS
Mr. Edwin Rigaud, President,
National Underground Railroad and Freedom Center, Cincinnati, OH
and member National Museum and Library Services Board

Ms. Alyce Sadongei (Kiowa/Tohono O'odham), Assistant Curator for Native American Relations, Arizona State Museum, University of Arizona

Ms. Susan Kent, Director and Chief Executive of The Branch Libraries, New York Public Library

VI. Other Business

VII. Adjourn

ADDRESSES: The Hotel Washington, 515 15th Street, NW., Washington, DC, (202) 638-5900.

FOR FURTHER INFORMATION CONTACT: Elizabeth Lyons, Special Assistant to the Director, Institute of Museum and Library Services, 1100 Pennsylvania Avenue, NW., Room 510, Washington, DC 20506, (202) 606-4649.

SUPPLEMENTARY INFORMATION: The National Museum and Library Services Board is established under the Museum and Library Services Act, 20 U.S.C. Section 9101 *et seq.* The Board advises the Director of the Institute on general policies with respect to the duties, powers, and authorities related to Museum and Library Services.

The executive session from 9 a.m. to 10:30 a.m. on Thursday, October 7, 2004 will be closed pursuant to subsections (c)(4) and (c)(6) of section 552b of Title 5, United States Code because the Board will consider information that may disclose: Trade secrets and commercial or financial information obtained from a person and privileged or confidential; and information of a personal nature the disclosure of which would constitute a clearly unwarranted invasion of personal privacy. The meetings from 11 a.m. until 12:30 p.m. on Thursday, October 7, 2004 and the meeting from 9 a.m. to 12:30 p.m. on Friday, October 8, 2004 are open to the public. If you need special accommodations due to a disability, please contact: Institute of Museum and Library Services, 1100 Pennsylvania Avenue, NW., Washington, DC 20506, (202) 606-8536, TDD (202) 606-8636 at least seven (7) days prior to the meeting date.

Dated: September 23, 2004.

Teresa LaHaie,

Administrative Officer, National Foundation on the Arts and the Humanities, Institute of Museum and Library Services.

[FR Doc. 04-21828 Filed 9-24-04; 2:11 pm]

BILLING CODE 7036-01-M

NATIONAL FOUNDATION ON THE ARTS AND THE HUMANITIES

SES Performance Review Board

AGENCY: The National Endowment for the Humanities.

ACTION: Notice.

SUMMARY: This notice announces the membership of the Performance Review Board of the National Endowment for the Humanities.

FOR FURTHER INFORMATION CONTACT:

Timothy G. Connelly, Director of Human Resources, National Endowment for the Humanities, 1100 Pennsylvania Avenue, NW., Washington, DC 20506; telephone (202) 606-8415.

SUPPLEMENTARY INFORMATION: 5 U.S.C. 3393 and 4314 (c) (1) through (5) require each agency to establish, in accordance with regulations prescribed by the Office of Personnel Management, both an executive resources board and a performance review board for SES. The National Endowment for the Humanities has a combined Board, which is referred to as the Executive Resources and Performance Review Board (ERPRB).

Effective October 1, 2004, the members of the National Endowment for the Humanities SES Performance Review Board selected to serve are Jeffrey Thomas, Assistant Chairman for Planning and Operations—Board Chairman, Howard Dickman, Assistant Chairman for Programs, Stephen Ross, Director Office of Challenge Grants and Candace Katz, Deputy Director, President's Committee on the Arts and Humanities. All members will serve "until replaced."

Bruce Cole,
Chairman.

[FR Doc. 04-21693 Filed 9-27-04; 8:45 am]

BILLING CODE 7536-01-P

NUCLEAR REGULATORY COMMISSION

[Docket Nos. 50-335 and 50-389]

Florida Power and Light Company; Notice of Consideration of Issuance of Amendments to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of amendments to Renewed Facility Operating License Nos. DPR-67 and NPF-16 issued to Florida Power and Light Company for operation of the St. Lucie Plant, Unit

Nos. 1 and 2, located in St. Lucie County, Florida.

The proposed amendments would allow the licensee to revise the St. Lucie Units 1 and 2 Technical Specifications to eliminate certain pressure sensor response time testing (RTT) requirements, as discussed in the Combustion Engineering Owners Group (CEOG) Topical Report NPSD-1167, Revision 2, "Elimination of Pressure Sensor Response Time Testing Requirements," which was approved by the NRC staff by letters dated July 24, 2000, and December 5, 2000. Specifically, these amendments revise the St. Lucie Units 1 and 2 Technical Specification Definitions 1.12, "Engineered Safety Features Response Time," and 1.26, "Reactor Protection System Response Time."

Before issuance of the proposed license amendments, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations.

The Commission has made a proposed determination that the amendment requests involve no significant hazards consideration. Under the Commission's regulations in Title 10 of the Code of Federal Regulations (10 CFR), Section 50.92, this means that operation of the facility in accordance with the proposed amendments would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. Operation of the facility in accordance with the proposed amendments would not involve a significant increase in the probability or consequences of an accident previously evaluated.

The proposed changes allow the elimination of pressure sensor response time testing. Response time testing is not an initiator of any accident previously evaluated. Consequently, the probability of an accident previously evaluated is not significantly increased. The allocated pressure sensor response times allowed in lieu of measurement have been determined to adequately represent the response time of the components such that the safety systems utilizing those components will continue to perform their accident mitigation function as assumed in the safety analysis. Therefore, the consequences of an accident previously evaluated are not significantly increased by this change. Therefore, this change does not