proposed settlements are available from: Ms. Paula V. Batchelor, U.S. EPA, Region 4 (WMD–PSB), 61 Forsyth Street SW, Atlanta, Georgia 30303, (404) 562–8887

Written comments may be submitted to Ms. Batchelor within 30 calendar days of the date of this publication.

Dated: December 21, 2000.

Franklin E. Hill,

Chief, CERCLA Program Services Branch, Waste Management Division.

[FR Doc. 00–33356 Filed 12–28–00; 8:45 am]

BILLING CODE 6560-50-P

ENVIRONMENTAL PROTECTION AGENCY

[FRL-6924-9]

Stage 2 Microbial and Disinfection Byproducts Federal Advisory Committee Agreement in Principle

AGENCY: Environmental Protection Agency.

ACTION: Notice of agreement in principle.

SUMMARY: The purpose of today's notice is to make available to the public recommendations to the Administrator of the Environmental Protection Agency contained in the Stage 2 Microbial and Disinfection Byproducts (M–DBP) Federal Advisory Committee Agreement in Principle (Agreement) that was signed in September 2000. The Stage 2 M-DBP rules are a set of interrelated drinking water regulations which address risks from microbial pathogens and disinfection byproducts (DBPs). The U.S. Environmental Protection Agency (USEPA) convened the Stage 2 M-DBP Federal Advisory Committee (Committee) to collect, share, and analyze information that has become available since promulgation of the Stage 1 M-DBP rules in December 1998. The purpose of the Committee was to evaluate whether and to what degree USEPA should establish revised or additional DBP and microbial standards to protect public health. The Committee consisted of organizational members representing USEPA, public interest groups, State and local public health and regulatory agencies, local elected officials, Indian tribes, drinking water suppliers, and chemical and equipment manufacturers. Recommendations from the Committee are contained in the Agreement in Principle which is provided below. This Agreement is the result of a tremendous collaborative effort and USEPA would like to express its appreciation to all members of the Committee, as well as to members of the

Technical Workgroup (TWG) which supported the Committee.

FOR FURTHER INFORMATION CONTACT: For general information contact the Safe Drinking Water Hotline, Telephone (800) 426–4791. The Safe Drinking Water Hotline is open Monday through Friday, excluding federal holidays, from 9:00 a.m. to 5:30 p.m. Eastern Time. For technical inquiries contact Dan Schmelling or Jennifer McLain, Office of Ground Water and Drinking Water (MC 4607), U.S. Environmental Protection Agency, 1200 Pennsylvania Avenue, NW., Washington, DC 20460; telephone (202) 260–1439 (Schmelling) or (202) 260–0431 (McLain).

SUPPLEMENTARY INFORMATION:

Introduction and Background

The Stage 2 M-DBP rules represent the final stage in a two phase M–DBP rulemaking strategy agreed upon by USEPA and stakeholders during a regulatory negotiation process in 1992-93, and later affirmed by Congress as part of the 1996 Amendments to the Safe Drinking Water Act (SDWA). They comprise the Long Term 2 Enhanced Surface Water Treatment Rule (LT2ESWTR) and the Stage 2 Disinfectants and Disinfection Byproducts Rule (DBPR). The LT2ESWTR focuses on risk from microbial pathogens, specifically Cryptosporidium, and the Stage 2 DBPR addresses risk from DBPs. These rules are being developed simultaneously in order to address complex risk trade-offs between the control of pathogens and limiting exposure to DBPs. Statutory deadlines require USEPA to promulgate the Stage 2 DBPR by May 2002. Consistent with statutory objectives for risk balancing, EPA will finalize the LT2ESWTR concurrent with the Stage 2 DBPR to ensure parallel protection from microbial and DBP risks.

Committee recommendations for the Stage 2 M-DBP rules would build upon the public health protection provided by the Stage 1 M-DBP rules, which include the Stage 1 DBPR, Interim Enhanced Surface Water Treatment Rule (IESWTR), and Long Term 1 Enhanced Surface Water Treatment Rule (LT1ESWTR). The Stage 1 DBPR and IESWTR were issued in December, 1998, and promulgation of the LT1ESWTR is anticipated for late 2000 or early 2001. The Stage 1 M-DBP rules are based on stakeholder agreements reached during the 1992-93 negotiated rulemaking, as well as the agreement of a subsequent Federal Advisory Committee which met from March to July 1997.

Prior to convening the Stage 2 M–DBP Advisory Committee, USEPA held three preparatory stakeholder meetings on pathogen and DBP health effects, occurrence, and treatment. The Committee then held fourteen formal negotiation meetings between March 1999 and September 2000 to discuss issues related to the Stage 2 DBPR and LT2ESWTR. The objective of the Committee at the outset was to reach a consensus regarding provisions for the two rules. Technical support for these discussions was provided by the TWG, which was established by the Committee at its first meeting. The Committee's activities resulted in the collection, development, evaluation, and presentation of substantial new information related to key elements for both rules. This information included new data on pathogenicity, occurrence, and treatment of microbial contaminants, specifically including Cryptosporidium, as well as new data on DBP health risks, exposure, and control.

A significant source of new data was the Information Collection Rule (ICR), which EPA promulgated in 1996 pursuant to SDWA requirements. The ICR required approximately 300 large public water systems to conduct 18 months of sampling for water quality and treatment parameters related to DBP formation and the occurrence of microbial pathogens. Data on DBP formation in small systems was obtained through a survey of approximately 120 treatment plants in systems serving fewer than 10,000 people. Seven states also provided small system DBP data. Subsequent to the ICR, EPA obtained additional data on pathogen occurrence through the ICR Supplemental Surveys (ICRSS). These surveys involved 127 water treatment plants, including 40 small systems, and comprised one year of bi-monthly sampling for Cryptosporidium, Giardia, and other water quality parameters (small systems did not measure protozoa).

USEPA and the TWG developed a series of eight databases to facilitate analysis of ICR data. The ICR databases were integrated with a Surface Water Analytical Tool model to predict the impact of potential new standards for DBPs and/or pathogens on shifts in treatment technologies among water systems and resulting DBP exposure profiles. Based on data supplied by equipment vendors, the TWG produced unit cost estimates for a number of potential regulatory compliance technologies. These technology unit costs were used in conjunction with SWAT projections of technology shifts

to make national cost estimates for regulatory options.

USEPA, in consultation with nationally recognized experts in the field of statistics, evaluated ICR and ICRSS data to generate estimates of the national occurrence distribution of Cryptosporidium. Occurrence distributions were coupled with data on the infectivity of different strains of Cryptosporidium and assumptions for the removal efficiency of treatment plants to make projections of the possible risk associated with Cryptosporidium in drinking water. In considering risks associated with DBPs, the Committee reviewed available toxicological and epidemiological data from a number of studies on reproductive and developmental health effects (e.g., early term miscarriages), as well as cancer.

Despite the evaluation of a large amount of data, the Committee recognized that uncertainty remains in a number of areas regarding the precise nature and magnitude of risk associated with DBPs and pathogens in drinking water. In light of this uncertainty, the Committee recommended a series of balanced steps to address the areas of greatest health concern, taking into careful consideration the costs and potential impacts on public water systems.

In regard to DBPs, the Committee recommended a two phase approach to provide further control of concentration peaks in the distribution system. In Phase 1, systems would continue to meet maximum contaminant levels (MCLs) established by the Stage 1 DBPR for total trihalomethanes (TTHM) and five haloacetic acids (HAA5) of 0.080 and 0.060 mg/L, respectively, with compliance based on a running annual average (RAA). In addition, Phase 1 would add new MCLs of 0.120 and 0.100 mg/L for TTHM and HAA5, respectively, with compliance based on a locational running annual average (LRAA). Under an LRAA standard, the annual average at each monitoring point must not exceed the MCL. This compares with the RAA established by the Stage 1 DBPR in which compliance is determined by averaging across all monitoring points. All Phase 1 monitoring would be conducted at Stage 1 DBPR sites. Phase 2 would consist of maintaining MCLs of 0.080 mg/L for TTHM and 0.060 mg/L for HAA5 but compliance with these levels would be based on the LRAA. Under Phase 2, monitoring would be conducted at new sites determined from an initial distribution system evaluation designed to select site-specific optimal sample points for capturing DBP peaks.

The two phase approach recommended by the Committee for the Stage 2 DBPR would provide an initial level of protection from DBP peaks under Phase 1. Systems would then make decisions regarding the potentially more significant treatment changes necessary to comply with Phase 2 during the same time period as they evaluate options to comply with the LT2ESWTR. This approach is consistent with the Committee's support for simultaneous compliance for the Stage 2 M-DBP rules and the statutory objectives for balancing microbial and DBP risks.

In regard to microbial pathogens, the Committee recognized that systems with poor quality source waters may need to provide additional protection against Cryptosporidium. The Committee recommended a 'Microbial Framework' approach which involves assignment of systems into different categories (or bins) based on the results of source water Cryptosporidium monitoring. Additional treatment requirements depend on the bin to which the system is assigned. Systems would chose technologies to comply with additional treatment requirements from a 'toolbox' of options. The Committee also made recommendations for unfiltered systems and uncovered finished water reservoirs.

The Agreement in Principle is the full statement of the points on which the Committee reached consensus. The Agreement is divided into Parts A & B. The recommendations in each part stand alone and are independent of one another. The entire Committee reached consensus on Part A, which contains provisions that apply directly to the Stage 2 DBPR and LT2ESWTR. The full Committee with the exception of the National Rural Water Association agreed to Part B, which has recommendations for future activity by USEPA in the areas of distribution systems and microbial water quality criteria. Following the Agreement in today's notice is a list of the twenty one organizational members of the Committee and their alternates.

The recommendations contained in the Stage 2 M–DBP Agreement in Principle reflect the Committee's emphasis on targeted, risk based rulemaking. They incorporate substantial initial monitoring to identify systems with the highest potential risk. Additional treatment steps are required only where systems exceed specified locational average DBP concentrations or source water *Cryptosporidium* occurrence levels. In addition, the recommendations address risks from *Cryptosporidium* in unfiltered systems, as well as longstanding concerns over

risks from uncovered finished water reservoirs. They also facilitate the use of nontraditional and potentially low cost treatment technologies like UV disinfection.

These recommendations represent an important and balanced step forward in controlling public health risks associated with drinking water. The ability of Committee representatives with different interests, areas of expertise, and perspectives to find common ground and reach agreement reflects an exceptional commitment to public health protection and to the regulatory negotiation process. In the future, results from new research will provide further insights into drinking water risks associated with reproductive and developmental toxicity of DBPs, the occurrence and pathogenicity of microorganisms, and other related topics. As new information evolves, USEPA will continue to work with stakeholders in evaluating the adequacy of existing drinking water standards and the need for revised or additional measures to protect public health.

USEPA has agreed to develop a proposed rulemaking for the Stage 2 DBPR and LT2ESWTR in 2001 that will reflect recommendations contained in the Agreement in Principle. As part of the proposed rulemaking, USEPA will solicit comments on the Agreement. Today's notice, however, is intended only to inform the public of the availability of the Agreement and USEPA does not request comment on this notice.

Dated: December 19, 2000.

J. Charles Fox,

Assistant Administrator, Office of Water.

1.0 Introduction

Pursuant to requirements under the Safe Drinking Water Act (SDWA), the Environmental Protection Agency (EPA) is developing interrelated regulations to control microbial pathogens and disinfectants/disinfection byproducts (D/DBPs) in drinking water. These rules are collectively known as the microbial/disinfection byproducts (M–DBP) rules.

The regulations are intended to address complex risk trade-offs between the two different types of contaminants. In keeping with a phased M–DBP strategy agreed to by stakeholders during the 1992–93 negotiated rulemaking on these matters and affirmed by Congress as part of the 1996 Amendments to the Safe Drinking Water Act, EPA issued the final Stage 1 Disinfectants and Disinfection Byproducts Rule (DBPR) and Interim Enhanced Surface Water Rule (IESWTR) in December 1998. These two rules built

upon stakeholder agreements reached in 1993 but also reflected the more recent 1997 Agreement in Principle signed by stakeholders who participated in an intensive Stage 1 M–DBP Federal Advisory Committee Act (FACA) negotiation process from March to July 1997.

As part of the 1996 amendments to the SDWA, Congress established deadlines for the M-DBP rules, beginning with a November 1998 deadline for promulgation of both the IESWTR and the Stage 1 D/DBP Rule. Related statutory deadlines for the Stage 2 M-DBP process require that EPA promulgate a Stage 2 Disinfectants and Disinfection Byproducts Rule (DBPR) by May 2002. The Agency plans to promulgate the Long Term 2 Enhanced Surface Water Treatment Rule (LT2ESWTR) by May 2002, as well. The central challenge of the Stage 2 M-DBP rule development process has been to assess information and research not fully considered in the Stage 1 process or only available since 1998 and evaluate whether and to what degree EPA should establish revised or additional DBP and microbial standards to protect public health.

As agreed to during Stage 1, EPA has convened a Stage 2 M-DBP Advisory Committee made up of organizational members (parties) named by EPA (see Attachment A). The purpose of the Advisory Committee is to develop recommendations for the Stage 2 DBPR and LT2ESWTR to be proposed in 2001. This Committee met from March 1999 through September 2000, with the initial objective to reach consensus. This document is the Committee's statement on the points of agreement reached. This document is separated into Part A and Part B. The recommendations in each part stand alone and are independent of one another.

2.0 Agreement in Principle

The Stage 2 M–DBP Federal Advisory Committee (Stage 2 FACA) considered both the strengths and limitations of new M–DBP information as well as the related technical and policy issues involved in developing a Stage 2 DBPR and a LT2ESWTR under the Safe Drinking Water Act and recommends that the Environmental Protection Agency base the applicable sections of its anticipated Stage 2 DBPR and LT2ESWTR proposals on the elements of agreement described below.

This agreement in principle Part A and B represents the consensus of the parties on the best conceptual principles that the Committee was able to generate

within the allocated time and resources available.

The , a party to the negotiations, agrees that:

2.1 The person signing Part A or Part B of this agreement is authorized to commit this party to the terms of Part A or Part B, as the case may be.

2.2 EPA agrees to develop a Proposed Rulemaking in 2001 in accordance with applicable statutes and procedural requirements that will reflect recommendations contained in this Agreement in Principle, and will obtain comments from Stage 2 FACA parties and the public.

2.3 Each party and individual signatory that submits comments on the Stage 2 DBPR and LT2ESWTR proposals agrees to support those components of the proposals that reflect the recommendations contained in this Agreement in Principle. Each party and individual signatory reserves the right to comment, as individuals or on behalf of the organization he or she represents, on any other aspect of the proposals.

2.4 If new information becomes available that significantly affects the basis for provisions in this Agreement in Principle, EPA agrees to publish this information in a NODA and will consider whether it is necessary to reconvene the FACA.

2.5 EPA will work jointly with stakeholders while developing guidance documents in order to ensure that technical issues are adequately addressed prior to the final rule. EPA agrees to publish revised guidance documents that reflect consideration of comments on earlier drafts.

2.6 Concurrent with publication of the proposed rules, EPA will publish a draft guidance document that includes ozone and chlorine dioxide CT tables for the inactivation of *Cryptosporidium* (UV tables are addressed in 5.0). EPA will request comment in the proposed LT2ESWTR on whether any of the CT tables or other criteria in the guidance document should be incorporated into the final LT2ESWTR.

2.7 EPA will consider all relevant comments submitted concerning the Stage 2 DBPR and LT2ESWTR Notice(s) of Proposed Rulemaking and in response to such comments will make such modifications to the proposed rule(s) and preamble(s) as EPA determines are appropriate when issuing a final rule.

2.8 Recognizing that under the Appointments Clause of the Constitution governmental authority may be exercised only by officers of the United States and recognizing that it is EPA's responsibility to issue final rules,

EPA intends to issue final rules that are based on the provisions of the Safe Drinking Water Act, pertinent facts, and comments received from the public.

2.9 Each party agrees not to take any action to inhibit the adoption of final rule(s) to the extent it and corresponding preamble(s) have the same substance and effect as the elements of the Agreement in Principle Part A or Part B or both parts as evidenced by the signature following each part.

2.10 EPA will hold a stakeholder meeting during the comment period to update stakeholders on new information germane to the Stage 2 DBPR and LT2ESWTR.

2.11 Implementation Schedule

2.11.a Compliance schedules for the LT2ESWTR will be tied to the availability of sufficient analytical capacity at approved laboratories for all large and medium affected systems to initiate *Cryptosporidium* and *E. coli* monitoring, and the availability of software for transferring, storing, and evaluating the results of all microbial analyses.

(1) If the availability of adequate laboratory capacity or data management software for microbial monitoring under LT2ESWTR for large or medium systems is delayed then monitoring, implementation, and compliance schedules for both the LT2ESWTR and Stage 2 DBPR described under 2.11.c will be delayed by an equivalent time period.

2.11.b The principle of simultaneous compliance reflected in the Stage 1 M-DBP rules will be continued in the Stage 2 M-DBP rules.

(1) The principle of simultaneous compliance means that systems will address the Stage 2 DBPR and LT2ESWTR requirements concurrently in order to protect public health and optimize technology choice decisions.

2.11.c Implementation Schedule

(1) Once the Stage 2 M-DBP rules have been promulgated, systems will conduct Cryptosporidium (Section 4.1) and IDSE (Section 3.1.a) monitoring and submit the results to their States/ Primacy Agency. Large and medium systems must submit a report with the results of the Initial Distribution System Evaluation (IDSE) (including any monitoring) and the results of the Cryptosporidium monitoring two years and two and a half years after rule promulgation, respectively. Small systems must submit a report recommending new DBP compliance monitoring locations and supporting data with the results of their IDSE,

including any monitoring, and *Cryptosporidium* monitoring 4 years and 5 years after rule promulgation, respectively.¹

- (2) Systems will comply with the Stage 2 DBPR MCL for TTHMs/HAA5 in two phases:
- (a) Phase 1: 3 years after rule promulgation (with an additional 2 year extension available for systems requiring capital improvements), all systems must comply with a 120/100 locational running annual average (LRAA) based on Stage 1 monitoring sites and also continue to comply with the Stage 1 80/60 running annual average.
- (b) Phase 2: Systems must comply with 80/60 LRAA based on new sampling sites identified under the IDSE. This will begin 6 years after rule promulgation (with an additional 2 year extension available for systems requiring capital improvements) for large and medium systems. For small systems required to do Cryptosporidium monitoring, compliance with the 80/60 LRAA will begin 8.5 years after rule promulgation (with an additional 2 year extension available for systems requiring capital improvements). For all other small systems, compliance with the 80/60 LRAA will begin 7.5 years after rule promulgation (with an additional 2 year extension available for systems requiring capital improvements).

Part A

3.0 Disinfection Byproducts

The requirements in the Stage 2 DBPR will apply to all community water systems and non-transient non-community water systems that add a disinfectant other than UV or deliver water that has been disinfected.

The Stage 2 DBPR is designed to reduce DBP occurrence peaks in the distribution system based on changes to compliance monitoring provisions. Compliance monitoring will be preceded by an initial distribution system monitoring (IDSE)/study to select site-specific optimal sample points for capturing peaks. The FACA recognizes that TTHM and HAA5 concentrations vary over time and space and therefore agrees that compliance monitoring locations should reflect this variability.

3.1 TTHM/HAA5

Compliance with each MCL will be determined based on a Locational Running Annual Average (a running annual average must be calculated at each sample location). Systems will comply with the Stage 2 DBPR MCL in two phases:

Phase 1: 3 years after rule promulgation (with an additional 2 year extension available for systems requiring capital improvements), all systems must comply with a 120/100 locational running annual average (LRAA) based on Stage 1 monitoring sites and also continue to comply with the Stage 1 80/60 running annual average.

Phase 2: 6 years after rule promulgation (with an additional 2 year extension available for systems requiring capital improvements) large and medium systems must comply with an 80/60 LRAA based on new sampling sites identified under the IDSE. For small systems required to do Cryptosporidium monitoring, compliance with the 80/60 LRAA will begin 8.5 years after rule promulgation (with an additional 2 year extension available for systems requiring capital improvements). For all other small systems, compliance with the 80/60 LRAA will begin 7.5 years after rule promulgation (with an additional 2 year extension available for systems requiring capital improvements).

3.1.a Initial Distribution System Evaluation (IDSE)

IDSEs are studies conducted by Community Water Systems and are intended to select new compliance monitoring sites that more accurately reflect sites representing high TTHM and HAA5 levels. The studies will be based either on system specific monitoring or other system specific data that provides equivalent or better information on site selection. Systems will recommend new or revised monitoring sites to their State/Primacy Agency based on their IDSE study. IDSE results will not be used for compliance purposes.

Systems conducting IDSE monitoring shall monitor for one year under a schedule determined by source water type (e.g., surface water vs. ground water) and system size as discussed in 1–3 below. As a part of the monitoring schedule, all systems conducting IDSE monitoring must monitor during the peak historical month for DBP levels or water temperature. All IDSE samples will be paired (i.e., TTHM and HAA5 sample at each site).

(1) Surface Water Systems ≥ 10,000:

Systems must monitor bimonthly on a regular schedule of approximately every 60 days ² for one year at 8 distribution system sites per plant (at sites that are in addition to the Stage 1 DBPR compliance monitoring sites).

The location of the 8 sites will be determined by residual disinfectant type as follows:

- (a) For plants with chloramine distribution systems: 2 near distribution system entry point, 2 at average residence time, and 4 at points representative of highest THM and HAA5 concentrations;
- (b) For plants with chlorine distribution systems: 1 near distribution system entry point, 2 at average residence time, and 5 at points representative of highest THM and HAA5 concentrations.
 - (2) Surface Water Systems < 10,000:
- (a) 500–9,999: Systems must monitor quarterly on a regular schedule of approximately every 90 days for one year at 2 distribution system sites per plant (at sites that are in addition to the Stage 1 DBPR compliance monitoring sites).
- (b) Under 500: System must monitor semi-annually on a regular schedule of approximately every 180 days for one year at 2 distribution system sites per plant (at sites that are in addition to the Stage 1 DBPR compliance monitoring sites).
- (i) This monitoring requirement for systems under 500 may be waived if the State/Primacy Agency determines that the monitoring site approved for Stage 1 DBPR compliance is sufficient to represent both the highest HAA5 and the highest TTHM concentrations. The State/Primacy Agency must submit criteria for this determination to EPA as part of their Primacy application.
 - (3) Ground Water Systems:

Multiple wells drawing water from a single aquifer may, with State/Primacy Agency approval, be considered one treatment plant.

- (a) ≥ 10,000: Systems must monitor quarterly on a regular schedule of approximately every 90 days for one year at 2 distribution system sites per plant (at sites that are in addition to the Stage 1 DBPR compliance monitoring sites)
- (b) < 10,000: Systems must monitor semi-annually on a regular schedule of approximately every 180 days for one year at 2 distribution system sites per plant (at sites in addition to the Stage 1 DBPR compliance monitoring sites)

¹ Systems which monitor for an indicator organism (e.g., E. coli) and do not monitor for *Cryptosporidium* must submit the results of the indicator monitoring three and one-half years after rule promulgation.

² The objective of this monitoring provision and similar monitoring provisions herein after is to prevent systems from avoiding monitoring during peak occurrence.

(i) This monitoring requirement for systems under 500 may be waived if the State/Primacy Agency determines that the monitoring site approved for Stage 1 DBPR compliance is sufficient to represent both the highest HAA5 and the highest TTHM concentrations. The State/Primacy Agency must submit criteria for this determination to EPA as part of their Primacy application.

(4) System Specific Študies—In lieu of the IDSE monitoring, systems may perform an IDSE study based on other system specific monitoring or system specific data which will provide comparable or superior selection of new monitoring sites that target high DBP levels. EPA agrees to work with stakeholders to develop guidance on criteria for system specific studies.

(5) Systems that certify to their State/ Primacy Agency that all samples taken in the last 2 years were below 40/30 are not required to conduct the IDSE.

3.1.b. Long Term Compliance Monitoring (Phase 2)

Principles of the reduced compliance monitoring strategy reflected in the Stage 1 DBPR shall be continued in the Stage 2 DBPR. These principles are designed for systems with very low DBP levels.

Systems will collect paired samples (TTHM and HAA5) at each compliance monitoring sample site with the possible exception of some systems serving < 500 people.

(1) Surface Water Systems \geq 10,000: Systems must monitor quarterly on a regular schedule of approximately every 90 days ³ at 4 distribution system sites per plant. At least 1 quarterly sample must be taken during the peak historical month for DBP levels.

The location of the 4 sites in the distribution system will be determined as follows:

- -One representative average from among current Stage 1 locations.
- One representative highest HAA5 identified under IDSE.
- -Two at highest TTHM identified during IDSE.
 - (2) Surface Water Systems < 10,000.
- (a) 500-9,999: Systems must monitor quarterly on a regular schedule of approximately every 90 days at the highest TTHM and the highest HAA5 points in the distribution system as identified under the IDSE. The State/ Primacy Agency may determine, based on the results of the IDSE, that the site representative of the highest TTHM is at

the same location as the site representative of the highest HAA5 and thus may determine that the system only has to monitor at a single site.

(b) Under 500: Systems must monitor annually at the site representing the highest TTHM and the highest HAA5 points in the distribution system as identified under the IDSE. If the State/ Primacy Agency determines, based on the results of the IDSE, that this site is not representative of both the highest TTHM and HAA5 concentrations, the system should collect unpaired samples at two sites in the distribution system (i.e., TTHM only at one site and HAA5 only at another site).

(i) If the State/Primacy Agency has waived the requirement to conduct the IDSE, systems under 500 will conduct annual sampling at the point of maximum residence time in the distribution system during the month of warmest water temperature.

(ii) Systems under 500 have the option of moving to quarterly compliance sampling consistent with the Stage 1 sampling strategy.

(3) Groundwater Systems:

(a) \geq 10,000: Systems must monitor quarterly on a regular schedule of approximately every 90 days at the highest TTHM and the highest HAA5 points in the distribution system as identified under the IDSE. The State/ Primacy Agency may determine, based on the results of the IDSE, that the site representative of the highest TTHM is at the same location as the site representative of the highest HAA5 and thus may determine that the system only has to monitor at a single site.

(b) 500-9,999: Systems must monitor annually at the highest TTHM and the highest HAA5 points in the distribution system as identified under the IDSE. The State/Primacy Agency may determine, based on the results of the IDSE, that the site representative of the highest TTHM is at the same location as the site representative of the highest HAA5 and thus may determine that the system only has to monitor at a single site.

(i) Ground water systems under 10,000 have the option of moving to quarterly compliance sampling consistent with Stage 1 sampling strategy.

(c) Under 500: Systems must monitor annually at the site representing the highest TTHM and the highest HAA5 points in the distribution system as identified under the IDSE. If the State/ Primacy Agency determines, based on the results of the IDSE, that this site is not representative of both the highest TTHM and HAA5 concentrations, the system should collect unpaired samples at two sites in the distribution system (i.e., TTHM only at one site and HAA5 only at another site).

(i) If the State/Primacy Agency waives the requirement for systems under 500 to conduct the IDSE, they will conduct annual sampling at the point of maximum residence time in the distribution system during the month of warmest water temperature.

(ii) Ground water systems under 500 have the option of moving to quarterly compliance sampling consistent with Stage 1 sampling strategy.

3.1.c Wholesale and Consecutive

Systems

The FACA has considered the issues of consecutive systems and recommends that EPA propose that all wholesale and consecutive systems must comply with provisions of the Stage 2 DBPR on the same schedule required of the wholesale or consecutive system serving the largest population in the combined distribution system.

Principles:

- Consumers in consecutive systems should be just as well protected as customers of all systems, and
- Monitoring provisions should be tailored to meet the first principle.

The FACA recognizes that there may be issues that have not been fully explored or completely analyzed and therefore recommends that EPA solicit comments.

3.1.d Peaks

Recognizing that significant excursions of DBP levels will sometimes occur, even when systems are in full compliance with the enforceable MCL, public water systems that have significant excursions during peak periods are to refer to EPA guidance on how to conduct peak excursion evaluations, and how to reduce such peaks. Such excursions will be reviewed as a part of the sanitary survey process. EPA guidance on DBP level excursions will be issued prior to promulgation of the final rule and will be developed in consultation with stakeholders.

3.2. Bromate MCL

The Stage 2 M-DBP Advisory Committee has considered the present potential that reducing the bromate MCL to 0.005 mg/L would both increase the concentration of other DBPs in the drinking water and interfere with the efficacy of microbial pathogen inactivation. Therefore, the Committee recommends for purposes of Stage 2 that the bromate MCL remain at 0.010 mg/ L. This recommendation is based upon current alternative technology utilization and upon current

³ The objective of this monitoring provision and similar monitoring provisions herein after is to prevent systems from avoiding monitoring during peak occurrence.

understanding of bromate formation as a result of bromide concentrations. EPA commits to review the bromate MCL as part of the 6 year review and determine whether the MCL should remain at 0.010 mg/L or be reduced to 0.005 mg/L or a lower concentration. As a part of that review, EPA will consider the increased utilization of alternative technologies and whether the risk/risk concerns reflected in today's recommendation remain valid. The FACA agrees that it is important to continue research on bromate detection, formation, treatment, and health effects.

4.0 LT2ESWTR

The requirements of the LT2ESWTR will apply to all public water systems that use surface water or ground water under the direct influence of surface water

The FACA recognizes that systems may need to provide additional protection against Cryptosporidium, and that such decisions should be made on a system specific basis. The LT2ESWTR incorporates system specific treatment requirements based on a 'Microbial Framework' approach. This approach generally involves assignment of systems into different categories (or bins) based on the results of source water Cryptosporidium monitoring. Additional treatment requirements depend on the bin to which the system is assigned. Systems will choose technologies to comply with additional treatment requirements from a 'toolbox' of options.

- 4.1 Monitoring and Treatment Requirements for Filtered Systems
- 4.1.a Monitoring for Bin Classification
 - (1) Systems ≥ 10.000 :

For purposes of bin classification, source water *Cryptosporidium* monitoring shall be conducted using EPA Method 1622/23 and no less than 10L samples. EPA will provide guidance for those cases where it is not possible to process a 10L sample.

(a) Cryptosporidium, E. coli, and turbidity source water sampling shall be carried out on a predetermined schedule for 24 months with two choices:

(i) Bin classification based on highest 12 month running annual average if monthly samples, OR (ii) Optional bin classification based on 2 year mean if facility conducts twice per month monitoring for 24 months (i.e. 48 samples). Systems may carry out additional sampling but it must be evenly distributed over the 2 year monitoring period.

(b) Systems with at least 2 years of historical *Cryptosporidium* data that is equivalent in sample number, frequency, and data quality (e.g. volume analyzed, percent recovery) to data that would be collected under the LT2ESWTR with EPA Method 1622/23 may use those data to determine bin classification in lieu of further monitoring. Systems which are able to use historical data in lieu of conducting new monitoring must submit such *Cryptosporidium* data to the State/Primacy Agency for consideration in selecting bin placement.

(c) Systems that provide 2.5 logs of treatment for *Cryptosporidium* (equivalent to Bin 4, including inactivation) in addition to conventional treatment are exempt from monitoring for purposes of selecting bin placement. Conventional treatment is defined as coagulation, flocculation, sedimentation and granular media filtration.

(d) EPA agrees to work with stakeholders to develop a guidance manual with appropriate QA/QC procedures for *Cryptosporidium* sampling

(2) Systems < 10,000:

(a) Based on the large system monitoring under 4.1.a, EPA will work with stakeholders to evaluate alternative indicators and system characterization scenarios for predicting Cryptosporidium occurrence in small systems. This evaluation will include new information on surrogates, including E. coli, and will assess whether E. coli concentrations of 10 and 50 per 100ml are appropriate values to trigger Cryptosporidium monitoring in lakes/reservoirs and flowing streams, respectively.

(b) In the absence of an alternative indicator specified by the State/Primacy Agency, based on EPA guidance, source water *E. coli* levels trigger *Cryptosporidium* monitoring as

described below:

(i) Systems must begin on

(i) Systems must begin one year of biweekly *E. coli* source water monitoring 2 years after large systems initiate *Cryptosporidium* monitoring.

- (ii) Systems must conduct *Cryptosporidium* monitoring if *E. coli* concentrations exceed the following levels:
- —annual mean > 10/100 ml for lakes and reservoirs.
- —annual mean > 50/100 ml for flowing streams.
- (c) Systems that provide 2.5 logs of treatment for *Cryptosporidium* (equivalent to Bin 4, including inactivation) in addition to conventional treatment are exempt from monitoring for purposes of selecting bin placement.
- (d) The FACA recommends that *E. coli* monitoring for small systems will begin two and one half years after rule promulgation and also that *Cryptosporidium* monitoring be comprised of 24 samples over 1 year. The FACA also recommends that EPA solicit comment on any additional approaches to expedite small system compliance.
- (e) EPA will work with stakeholders to explore the feasibility of developing alternative, lower frequency, *Cryptosporidium* monitoring criteria for providing a conservative mean estimate.
- 4.1.b Action Bins (for conventional treatment plants)
- (1) The bins have been structured considering the total *Cryptosporidium* oocyst count, uncorrected for recovery, as measured using EPA Method 1623 and 10 L samples.
- (2) Systems have 3 years following initial bin classification to meet the treatment requirements associated with the bin (see Bin Requirements Table below). The State/Primacy Agency may grant systems an additional 2 year extension to comply when capital investments are necessary.
- (3) Systems currently using ozone, chlorine dioxide, UV, or membranes in addition to conventional treatment may receive credit for those technologies towards bin requirements.
- (4) Bin requirements table is shown below:

BIN REQUIREMENTS TABLE

Bin No.	Average Cryptosporidium concentration	Additional treatment requirements for systems with conventional treatment that are in full compliance with IESWTR 4
	Cryptosporidium <0.075/L	

BIN REQUIREMENTS TABLE—Continued

Bin No.	Average Cryptosporidium concentration	Additional treatment requirements for systems with conventional treatment that are in full compliance with IESWTR ⁴
3	1.0/L ≤ <i>Cryptosporidium</i> < 3.0/L	2.0 log treatment (systems must achieve at least 1-log of the required 2-log treatment using ozone, chlorine dioxide, UV, membranes, bag/cartridge filters, or in-bank filtration).
4	Cryptosporidium ≥3.0/L	2.5 log treatment (systems must achieve at least 1-log of the required 2.5-log treatment using ozone, chlorine dioxide, UV, membranes, bag/cartridge filters, or in-bank filtration).

⁴FACA has not addressed direct filtration systems. EPA will address direct filtration systems in connection with bins 2–4 in the proposed LT2ESWTR and request comment.

(5) The additional treatment requirements in the bin requirement table are based, in part, on the assumption that conventional treatment plants in compliance with the IESWTR achieve an average of 3 logs removal of *Cryptosporidium*. The total *Cryptosporidium* removal requirements for the action bins with 1 log, 2 log, and 2.5 log additional treatment correspond to total *Cryptosporidium* removals of 4, 5, and 5.5 log respectively.

(6) FACA recommends that EPA request public comment on whether current guidance regarding *Giardia* treatment requirements for meeting the Surface Water Treatment Rule need to

be revised (to be consistent with multiple barrier concept in the current guidance and the FACA recommendations herein).

4.1.c Toolbox

- (1) Meeting the log treatment requirements identified for each "Action Bin" may necessitate one or more actions from an array of management strategies which include watershed control, reducing influent *Cryptosporidium* concentrations, improved system performance, and additional treatment barriers.
- (2) Based on available information, the FACA recommends that LT2ESWTR

employ a "toolbox" approach, and that the following tools when properly designed and implemented receive the following log credit (or range of credit). As recognized previously in this Agreement, EPA must employ the best information available in developing the final rule and will request comment on the proposed log credits assigned in the following table.

- (3) EPA will provide guidance for determining if toolbox options are properly designed and implemented.
- (4) Table with microbial toolbox components and associated potential log credit is shown below:

MICROBIAL TOOLBOX COMPONENTS [To be used in addition to existing treatment]

Tracticant		Potential log credit			
Treatment approach	0.5	1.0	2.0	>2.5	
Natershed Control:					
Watershed Control Program (1)	X				
Reduction in oocyst concentration (3)	As measured				
Reduction in viable oocyst concentration (3)	As measured				
Alternative Source:					
Intake relocation (3)	As measured				
Change to alternative source of supply (3)	As measured				
Management of intake to reduce capture of oocysts in source water (3)	As measured				
Managing timing of withdrawal (3)	As measured				
Managing level of withdrawal in water column (3)	As measured				
Pretreatment:					
Off-stream raw water storage w/detention of X days (1)	X				
Off-stream raw water storage w/detention of Y weeks (1)		X			
Pre-settling basin w/coagulant	X	→			
Lime softening (1)	\rightarrow	→			
In-bank filtration (1)		X	\rightarrow	\rightarrow	
mproved Treatment:					
Lower finished water turbidity (0.15 NTU 95%tile CFE)	X				
Slow sand filters (1)				X	
Roughing filters (1)	X	→	\rightarrow	\rightarrow	
Membranes (MF, UF, NF, RO) (1)				X	
Bag filters (1)		X	\rightarrow	→	
Cartridge filters (1)			X		
mproved Disinfection:					
Chlorine dioxide (2)	X	X			
Ozone (2)	X	X	X		
UV (2)				X	
Peer Review/Other Demonstration/Validation or System Performance:					
Peer review program (e.g., Partnership Phase IV)		X			

MICROBIAL TOOLBOX COMPONENTS—Continued

[To be used in addition to existing treatment]

Trootmont approach		Potential log credit			
Treatment approach	0.5	1.0	2.0	>2.5	
Performance studies demonstrating reliable specific log removals for technologies not listed above. This provision does not supercede other inactivation requirements.	n				

Key to table symbols: (X) indicates potential log credit based on proper design and implementation in accordance with EPA guidance. (→) indicates estimation of potential log credit based on site specific or technology specific demonstration of performance.

Table footnotes: (1) Criteria to be specified in guidance to determine allowed credit, (2) Inactivation dependent on dose and source water characteristics, (3) Additional monitoring for *Cryptosporidium* after this action would determine new bin classification and whether additional treatment is required.

4.1.d Reassessment and Future Monitoring

- (1) Systems that provide a total of 2.5 logs of treatment (equivalent to Bin 4 including inactivation) for *Cryptosporidium* in addition to conventional treatment are exempt from reassessment and future monitoring.
- (2) Four years after initial bin characterization, EPA will initiate a stakeholder process to review available methods and the bin characterization structures. EPA will conduct a stakeholder process to determine the appropriate analytical method, monitoring frequency, monitoring location, etc., for this second round of national assessment monitoring.
- (3) Six years after completion of the initial bin characterization, systems will conduct a second round of monitoring, equivalent or superior to the initial round from a statistical perspective, as part of a national reassessment. In the absence of an improved Cryptosporidium method (specified by the State/Primacy Agency, based on EPA guidance or rule and appropriate adjustment factors) site-specific reassessment monitoring will utilize method 1623 and site specific rebinning will occur under the current bin structure and time interval. If a new monitoring method is used, or the assumptions underlying the current bin structure change, the resulting data will be used for a site specific risk characterization in accordance with a revised bin structure (may require a revised rule) reflecting the changes in the underlying method.
- (4) As part of the three-year sanitary survey process, the Primacy Agency will assess any significant changes in the watershed and source water. The Primacy Agency will determine with the systems what follow-up action is appropriate. Actions that may be deemed appropriate include those outlined in the toolbox in this agreement.

4.2 Unfiltered Systems

- 4.2.a Unfiltered systems must:
- (1) Continue to meet filtration avoidance criteria, and
- (2) Provide 4 log virus inactivation, and
- (3) Provide 3 log *Giardia lamblia* inactivation, and
- (4) Provide 2 log *Cryptosporidium* inactivation.
- 4.2.b Overall inactivation requirements must be met using a minimum of 2 disinfectants.
- 4.2.c Ongoing monitoring and any eventual reassignment to risk bins for unfiltered systems will be consistent with requirements for other systems of their size, with the provision that unfiltered systems must demonstrate that their *Cryptosporidium* occurrence level continues to be less than or equal to 1 in 100 liters (or equivalent, using advanced methods) or provide 3 logs of *Cryptosporidium* inactivation.
- 4.3 Uncovered Finished Water Reservoirs 4.3.a Systems with uncovered finished water reservoirs must:
- (1) Cover the uncovered finish water reservoir, or
- (2) Treat reservoir discharge to the distribution system to achieve a 4 log virus inactivation, unless
- (3) State/Primacy Agency determines that existing risk mitigation is adequate.
- (a) Systems must develop and implement risk mitigation plans.
- (i) Risk mitigation plans must address physical access, surface water run-off, animal and bird waste, and on-going water quality assessment.
- (ii) Risk mitigation plans must account for cultural uses by tribes.

5.0 Ultraviolet Light

5.1 Based on available information, EPA believes that ultraviolet (UV) disinfection is available and feasible. However, information is needed in order to clarify how UV disinfection will be used as a tool for compliance with the proposed LT2ESWTR. Issues of particular importance include

- engineering issues like: Hydraulic control, reliability, redundancy, monitoring, placement of sensors, lamp cleaning and replacement, and lamp breakage, as well as confirmation of the information underlying EPA's assessment that UV is available and feasible.
- 5.2 Concurrent with publication of the proposed rules, EPA will publish the following:
- 5.2.a Tables specifying UV doses (product of irradiance (I) and exposure time (T)) needed to achieve up to 3 logs inactivation of *Giardia lamblia*, up to 3 logs inactivation of *Cryptosporidium*, and up to 4 logs inactivation of viruses.
- 5.2.b Minimum standards to determine if UV systems are acceptable for compliance with drinking water disinfection requirements. These standards will address the following:
- (1) A UV Validation Protocol to be established for drinking water applications of UV technology.⁵ Protocol to be premised on post-filter application of UV. Protocol will include the following:
- (a) Water quality criteria and site specific performance demonstration requirements for alternative placement of UV treatment in WTP.
- (b) Demonstration of adherence with the UV dose tables for inactivation per the identified protocols.
- (c) Testing of UV reactors to validate performance under worst case conditions (These independent testing protocols would necessarily encompass a range of worst case conditions appropriate to the range of WTPs that must comply with the LT2ESWTR).
- (d) Minimum UV sensor performance characteristics (e.g. accuracy, stability, sensitivity).
- (2) Description of on-site monitoring required to ensure ongoing compliance with required dose, including necessary testing and calibration of UV sensors.

⁵ The FACA recommends that EPA analyze the Deutscher Verein des Gas und Wasserfaches (DVGW) Technical Guidelines W 294 in developing the validation protocol.

5.2.c UV Guidance Manual, the purpose of which is primarily to facilitate design and planning of UV installations by familiarizing State/Primacy Agencies and utilities with important design and operational issues, including:

(1) Redundancy, reliability and hydraulic constraints in UV system design including design limitations with

respect to plant/pipe size

(2) Design considerations to account for water quality (e.g. UV absorbance, turbidity), lamp fouling and aging

(3) Appropriate operations and maintenance protocols to ensure performance of UV lamp (e.g., sleeve cleaning systems).

(4) Recommendations for water systems when soliciting UV disinfection systems to ensure conformance to criteria described under 5.2.b.

(5) Instructions on routine equipment and water quality monitoring practices used to assure reliable UV performance over time.

- 5.3 The availability of UV disinfection is a fundamental premise of this Agreement in Principle. The FACA recommends that EPA incorporate into the final LT2ESWTR provisions in 5.2 that will facilitate the approval of UV technology by Primacy Agencies. EPA agrees in the proposed LT2ESWTR to request comment on which criteria should be incorporated into the final LT2ESWTR.
- 5.4 EPA agrees to publish revised IT tables and revised guidance manuals as part of the final LT2ESWTR that reflect comments on earlier drafts.
- 5.5 EPA agrees to conduct a stakeholder meeting during the comment period for the proposed LT2ESWTR to update stakeholders on a range of issues including the status of UV and any outstanding guidance manual issues.

5.6 If EPA identifies substantial new information related to the availability or feasibility of UV, EPA agrees to publish this information in a NODA. If EPA determines that this information significantly impacts the basis for provisions in this agreement, EPA agrees to reconvene the FACA to address feasibility and availability of UV.

6.0 Health Risk Reduction and Cost Analysis (HRRCA)

EPA agrees to include in the Stage 2 DBPR and LT2ESWTR proposals an estimate of public health effects, and a health risk reduction and cost analysis (HRRCA). EPA agrees to use costing analysis that was developed to support the FACA process as part of its HRRCA analysis and where there is a significant difference in costing information EPA will use HRCCA to explain the difference. EPA also agrees to request comments from the Science Advisory Board prior to proposal.

STAGE 2—M–DBP AGREEMENT IN PRINCIPLE

PART A, Section 1.0–6.0 agreed to by:

Name, Organization

Date

All members of the Stage 2 M-DBP Advisory Committee signed Part A.

Part B

7.0 Distribution Systems

- 7.1 The FACA recognizes that finished water storage and distribution systems may have an impact on water quality and may pose risks to public health.
- 7.2 The FACA recognizes that cross connections and backflow in distribution systems represent a significant public health risk 7.3 The FACA recognizes that water quality problems can be related to infrastructure problems and that aging of distribution systems may increase risks of infrastructure problems.
- 7.4 The FACA recognizes that distribution systems are highly complex and that there is a significant need for additional information and analysis on the nature and magnitude of risk associated with them.
- 7.5 Therefore, the FACA recommends that beginning in January 2001, as part of the 6-year review of the Total Coliform Rule, EPA should evaluate available data and research on aspects of distribution systems that may create risks to public health and, working with stakeholders, initiate a process for addressing cross connection control and backflow prevention requirements and consider additional distribution system requirements related to significant health risks.

8.0 Microbial Water Quality Criteria

The FACA recommends the development of national water quality criteria funded by EPA under the Clean Water Act for microbial pathogens for stream segments designated by states/tribes for drinking water use. The FACA recognizes that both nonpoint sources and point sources may be a significant contributor to microbial contamination of drinking water and both must be responsible for reducing their individual contributions to microbial contamination to achieve water quality standards.

STAGE 2 M—DBP AGREEMENT IN PRINCIPLE

PART B, Section 1.0–8.0 agreed to by: Name, Organization

Date

All members of the Stage 2 M–DBP Advisory Committee except for the National Rural Water Association signed Part B.

Stage 2 M-DBP Advisory Committee Members and Alternates

International Ozone Association Michael Dimitriou, IDI Aqua Source Rip Rice, Rice International Consulting Enterprises (Alternate)

U.S. Environmental Protection Agency Cynthia Dougherty, Office of Ground Water and Drinking Water, Office of Water

All Indian Pueblo Council, Pueblo Office of Environmental Protection Dave Esparza, All Indian Pueblo Council

Everett Chavez, All Indian Pueblo Council (Alternate)

Physicians for Social Responsibility Cathey Falvo, New York Medical College

Caroline Poppell, Physicians for Social Responsibility (Alternate) Chlorine Chemistry Council

Peggy Geimer, MD, Arch Chemicals,

Keith Christman, Chlorine Chemistry Council (Alternate)

National Association of People with AIDS

Jeffrey K. Griffiths, Tufts University Schools of Medicine & Veterinary Medicine

Terje Anderson, National Association of People with AIDS (Alternate) Association of State Drinking Water Administrators

Richard Haberman, California Department of Health Services Vanessa Leiby, Association of State Drinking Water Administrators

Environmental Council of the States Barker G. Hamill, Bureau of Safe Drinking Water

Eva Nieminski, Utah Department of Environmental Quality (Alternate) National Association of State Utility

Consumer Advocates

(Alternate)

Christine Hoover, Office of Consumer Advocate, PA

Brian Gallagher, National Association of State Utility Consumer Advocates (Alternate)

Unfiltered Systems

Rosemary Menard, Water Resources Management Group, Portland Water Bureau

Steve Leonard, San Francisco PUC (Alternate)

National Association of Water Companies

Richard Moser, American Water Works Service Company

Peter Cook, National Association of Water Companies (Alternate)

Natural Resources Defense Council

Erik Olson, Natural Resources Defense Council

Adrianna Quintero, Natural Resources Defense Council (Alternate)

Conservation Law Foundation David Ozonoff, School of Public Health, Boston University

American Water Works Association David Paris, Manchester Water Works John Sullivan, American Water Works Association (Alternate)

Association of Metropolitan Water Agencies

Brian Ramaley, Newport News Waterworks

Diane Van De Hei, Association of Metropolitan Water Agencies (Alternate)

Water and Wastewater Equipment
Manufacturers Association

Charles Reading, Jr., ITT/SafeWater Solutions

Gary Van Stone, Calgon Carbon Corporation (Alternate)

National Rural Water Association Rodney Tart, Harnett County Public Utility, NC

Randy Van Dyke, National Rural Water Association (Alternate)

National League of Cities

Bruce Tobey, Mayor of Gloucester, Massachusetts

Carol Kocheisen, National League of Cities (Alternate)

National Environmental Health Association

National Association of County and City Health Officials

Chris Wiant, TriCounty Health Department

National Association of Regulatory Utility Commissioners

John Williams, Florida Public Service Commission

Clean Water Action

Marguerite Young, Clean Water Action

Lynn Thorp, Clean Water Action (Alternate)

[FR Doc. 00–33306 Filed 12–28–00; 8:45 am] BILLING CODE 6560–50–P

FEDERAL COMMUNICATIONS COMMISSON

[Report No. AUC-00-38-C (Auction No. 38); DA 00-2571]

Auction of Licenses for the 700 MHz Guard Bands Scheduled for February 13, 2001; Auction Notice and Filing Requirements for 8 Licenses in the 700 MHz Guard Bands Minimum Opening Bids and Other Procedural Issues

AGENCY: Federal Communications Commission.

ACTION: Notice.

SUMMARY: This document announces the procedures and minimum opening bids for the upcoming auction of eight Guard Band Manager licenses in the 700 MHz Guard Bands ("Auction No. 38").

DATES: Auction No. 38 is scheduled for February 13, 2001.

FOR FURTHER INFORMATION CONTACT:

Legal questions contact Howard
Davenport, Auctions Attorney, at (202)
418–0660. For general auction and
bidding questions, contact Linda
Sanderson, Auctions Project Manager, at
(717) 338–2888 or Craig Bomberger,
Auctions Analyst, at (202) 418–0660.
Media Contact, Mark Rubin at (202)
418–2924. For licensing questions,
contact Roger Noel, Chief, Licensing &
Technical Analysis Branch, at (202)
418–0620.

SUPPLEMENTARY INFORMATION: This is a summary of a public notice released November 14, 2000. The complete text of the public notice, including attachments, is available for inspection and copying during normal business hours in the FCC Reference Center (Room CY-A257), 445 12th Street, SW., Washington, DC 20554. It may also be purchased from the Commission's copy contractor, International Transcription Services, Inc. (ITS, Inc.) 1231 20th Street, NW., Washington, DC 20036, (202) 857-3800. It is also available on the Commission's web site at http:// www.fcc.gov.

List of Attachments available at the FCC.

Attachment A—Licenses to be Auctioned

Attachment B—FCC Auction Seminar Registration Form

Attachment C—Electronic Filing and Review of the FCC Form 175

Attachment D—Guidelines for Completion of FCC Form 175 and Exhibits Attachment F—FCC Bidding Preference/ Remote Software Order Form

Attachment G—Accessing the FCC Network to File FCC Form 175

Attachment H—Summary of Documents Addressing the Anti-Collusion Rules

Attachment I—Incumbent Television Licensees on Channels 59–68

I. General Information

A. Introduction

1. This public notice announces the procedures and minimum opening bids for the upcoming auction of eight Guard Band Manager licenses in the 700 MHz Guard Bands ("Auction No. 38"). On October 13, 2000, the Wireless Telecommunications Bureau ("Bureau") released a public notice, seeking comment on the establishment of reserve prices or minimum opening bids for Auction No. 38, in accordance with the Balanced Budget Act of 1997. In addition, the Bureau sought comment on a number of procedures to be used in Auction No. 38. The Bureau received no comments in response to the Auction No. 38 Comment Public Notice 65 FR 63584 (October 24, 2000).

i. Background of Proceeding

2. The 746-806 MHz band has historically been used exclusively by television stations (Channels 60-69). Incumbent analog television broadcasters are permitted by statute to continue operations in this band until their markets are converted to digital television ("DTV"). The Budget Act directed the Commission to reallocate this spectrum for public safety and commercial use by December 31, 1997, and to commence competitive bidding for the commercial licenses on the reallocated spectrum after January 1, 2001. In November 1999, Congress enacted a consolidated appropriations statute that revised the latter instruction. This legislation accelerated the schedule for auction of the commercial spectrum bands. Accordingly, the Bureau held an auction that began on September 6, 2000 and concluded on September 21, 2000 (Auction No. 33).

ii. Licenses to Be Auctioned

3. The licenses available in this auction consist of the following licenses that remained unsold in Auction No. 33.

Market No.	Market name	Block	Bandwidth
MEA012	Pittsburgh, PA	А	2 MHz
MEA014	Columbus, OH	В	4 MHz
MEA028	Little Rock, AR	В	4 MHz