

200-foot-long, 14-foot-wide open canal tailrace structure which returns the water into the Alamo River approximately 150 feet downstream of the convergence of the Central Drain

and Alamo River; and (4) appurtenant facilities. The proposed project would have an estimated annual generating capacity of 1,292 megawatt-hours.

A qualifying conduit hydropower facility is one that is determined or deemed to meet all of the criteria shown in the table below.

TABLE 1—CRITERIA FOR QUALIFYING CONDUIT HYDROPOWER FACILITY

Statutory provision	Description	Satisfies (Y/N)
FPA 30(a)(3)(A), as amended by HREA ...	The conduit the facility uses is a tunnel, canal, pipeline, aqueduct, flume, ditch, or similar manmade water conveyance that is operated for the distribution of water for agricultural, municipal, or industrial consumption and not primarily for the generation of electricity.	Y
FPA 30(a)(3)(C)(i), as amended by HREA	The facility is constructed, operated, or maintained for the generation of electric power and uses for such generation only the hydroelectric potential of a non-federally owned conduit.	Y
FPA 30(a)(3)(C)(ii), as amended by HREA	The facility has an installed capacity that does not exceed 5 megawatts .....	Y
FPA 30(a)(3)(C)(iii), as amended by HREA	On or before August 9, 2013, the facility is not licensed, or exempted from the licensing requirements of Part I of the FPA.	Y

*Preliminary Determination:* Based upon the above criteria, Commission staff preliminarily determines that the proposal satisfies the requirements for a qualifying conduit hydropower facility, which is not required to be licensed or exempted from licensing.

*Comments and Motions to Intervene:* Deadline for filing comments contesting whether the facility meets the qualifying criteria is 45 days from the issuance date of this notice.

Deadline for filing motions to intervene is 30 days from the issuance date of this notice.

Anyone may submit comments or a motion to intervene in accordance with the requirements of Rules of Practice and Procedure, 18 CFR 385.210 and 385.214. Any motions to intervene must be received on or before the specified deadline date for the particular proceeding.

*Filing and Service of Responsive Documents:* All filings must (1) bear in all capital letters the “COMMENTS CONTESTING QUALIFICATION FOR A CONDUIT HYDROPOWER FACILITY” or “MOTION TO INTERVENE,” as applicable; (2) state in the heading the name of the applicant and the project number of the application to which the filing responds; (3) state the name, address, and telephone number of the person filing; and (4) otherwise comply with the requirements of sections 385.2001 through 385.2005 of the Commission’s regulations.<sup>1</sup> All comments contesting Commission staff’s preliminary determination that the facility meets the qualifying criteria must set forth their evidentiary basis.

The Commission strongly encourages electronic filing. Please file motions to intervene and comments using the

Commission’s eFiling system at <http://www.ferc.gov/docs-filing/efiling.asp>. Commenters can submit brief comments up to 6,000 characters, without prior registration, using the eComment system at <http://www.ferc.gov/docs-filing/ecomment.asp>. You must include your name and contact information at the end of your comments. For assistance, please contact FERC Online Support at [FERCOnlineSupport@ferc.gov](mailto:FERCOnlineSupport@ferc.gov), (866) 208–3676 (toll free), or (202) 502–8659 (TTY). In lieu of electronic filing, please send a paper copy to: Secretary, Federal Energy Regulatory Commission, 888 First Street NE., Washington, DC 20426. A copy of all other filings in reference to this application must be accompanied by proof of service on all persons listed in the service list prepared by the Commission in this proceeding, in accordance with 18 CFR 4.34(b) and 385.2010.

*Locations of Notice of Intent:* Copies of the notice of intent can be obtained directly from the applicant or such copies can be viewed and reproduced at the Commission in its Public Reference Room, Room 2A, 888 First Street NE., Washington, DC 20426. The filing may also be viewed on the web at <http://www.ferc.gov/docs-filing/elibrary.asp> using the “eLibrary” link. Enter the docket number (e.g., CD15–12–000) in the docket number field to access the document. For assistance, call toll-free 1–866–208–3676 or email [FERCOnlineSupport@ferc.gov](mailto:FERCOnlineSupport@ferc.gov). For TTY, call (202) 502–8659.

Dated: December 10, 2014.

**Kimberly D. Bose,**  
Secretary.

[FR Doc. 2014–29539 Filed 12–16–14; 8:45 am]

**BILLING CODE 6717–01–P**

## DEPARTMENT OF ENERGY

### Federal Energy Regulatory Commission

[Docket No. CD15–7–000]

#### Imperial Irrigation District; Notice of Preliminary Determination of a Qualifying Conduit Hydropower Facility and Soliciting Comments and Motions To Intervene

On November 26, 2014, the Imperial Irrigation District filed a notice of intent to construct a qualifying conduit hydropower facility, pursuant to section 30 of the Federal Power Act (FPA), as amended by section 4 of the Hydropower Regulatory Efficiency Act of 2013 (HREA). The proposed Westside Main Canal Heading In-Conduit Hydroelectric Project would have an installed capacity of 1,045 kilowatts (kW) and would be located on the existing Westside Main Canal. This conduit transports water for irrigation, municipal, and industrial purposes. The project would be located near the city of Calexico in Imperial County, California.

*Applicant Contact:* Carl Stills, 1651 West Main Street, El Centro, CA 92243, Phone No. (760) 339–9701.

*FERC Contact:* Robert Bell, Phone No. (202) 502–6062, email: [robert.bell@ferc.gov](mailto:robert.bell@ferc.gov).

*Qualifying Conduit Hydropower Facility Description:* The proposed project would consist of: (1) one proposed 81-foot-long, 52-foot-wide covered concrete canal intake structure with three 10-foot-wide gates; (2) a proposed 15- by 60-foot powerhouse containing three turbine generator units with a total installed capacity of 1,045 kW; (3) the proposed 47-foot-long, 52-foot-wide concrete box tailrace structure which returns the water into the

<sup>1</sup> 18 CFR 385.2001–2005 (2014).

Westside Main Canal; and (4) appurtenant facilities. The proposed project would have an estimated annual

generating capacity of 5,938 megawatt-hours.  
A qualifying conduit hydropower facility is one that is determined or

deemed to meet all of the criteria shown in the table below.

TABLE 1—CRITERIA FOR QUALIFYING CONDUIT HYDROPOWER FACILITY

Statutory provision	Description	Satisfies (Y/N)
FPA 30(a)(3)(A), as amended by HREA	The conduit the facility uses is a tunnel, canal, pipeline, aqueduct, flume, ditch, or similar manmade water conveyance that is operated for the distribution of water for agricultural, municipal, or industrial consumption and not primarily for the generation of electricity.	Y
FPA 30(a)(3)(C)(i), as amended by HREA	The facility is constructed, operated, or maintained for the generation of electric power and uses for such generation only the hydroelectric potential of a non-federally owned conduit.	Y
FPA 30(a)(3)(C)(ii), as amended by HREA	The facility has an installed capacity that does not exceed 5 megawatts	Y
FPA 30(a)(3)(C)(iii), as amended by HREA	On or before August 9, 2013, the facility is not licensed, or exempted from the licensing requirements of Part I of the FPA.	Y

*Preliminary Determination:* Based upon the above criteria, Commission staff preliminarily determines that the proposal satisfies the requirements for a qualifying conduit hydropower facility, which is not required to be licensed or exempted from licensing.

*Comments and Motions to Intervene:* Deadline for filing comments contesting whether the facility meets the qualifying criteria is 45 days from the issuance date of this notice.

Deadline for filing motions to intervene is 30 days from the issuance date of this notice.

Anyone may submit comments or a motion to intervene in accordance with the requirements of Rules of Practice and Procedure, 18 CFR 385.210 and 385.214. Any motions to intervene must be received on or before the specified deadline date for the particular proceeding.

*Filing and Service of Responsive Documents:* All filings must (1) bear in all capital letters the “COMMENTS CONTESTING QUALIFICATION FOR A CONDUIT HYDROPOWER FACILITY” or “MOTION TO INTERVENE,” as applicable; (2) state in the heading the name of the applicant and the project number of the application to which the filing responds; (3) state the name, address, and telephone number of the person filing; and (4) otherwise comply with the requirements of sections 385.2001 through 385.2005 of the Commission’s regulations.<sup>1</sup> All comments contesting Commission staff’s preliminary determination that the facility meets the qualifying criteria must set forth their evidentiary basis.

The Commission strongly encourages electronic filing. Please file motions to intervene and comments using the Commission’s eFiling system at <http://www.ferc.gov/docs-filing/efiling.asp>.

[www.ferc.gov/docs-filing/efiling.asp](http://www.ferc.gov/docs-filing/efiling.asp). Commenters can submit brief comments up to 6,000 characters, without prior registration, using the eComment system at <http://www.ferc.gov/docs-filing/ecomment.asp>. You must include your name and contact information at the end of your comments. For assistance, please contact FERC Online Support at [FERCOnlineSupport@ferc.gov](mailto:FERCOnlineSupport@ferc.gov), (866) 208-3676 (toll free), or (202) 502-8659 (TTY). In lieu of electronic filing, please send a paper copy to: Secretary, Federal Energy Regulatory Commission, 888 First Street NE., Washington, DC 20426. A copy of all other filings in reference to this application must be accompanied by proof of service on all persons listed in the service list prepared by the Commission in this proceeding, in accordance with 18 CFR 4.34(b) and 385.2010.

*Locations of Notice of Intent:* Copies of the notice of intent can be obtained directly from the applicant or such copies can be viewed and reproduced at the Commission in its Public Reference Room, Room 2A, 888 First Street NE., Washington, DC 20426. The filing may also be viewed on the web at <http://www.ferc.gov/docs-filing/elibrary.asp> using the “eLibrary” link. Enter the docket number (e.g., CD15-7-000) in the docket number field to access the document. For assistance, call toll-free 1-866-208-3676 or email [FERCOnlineSupport@ferc.gov](mailto:FERCOnlineSupport@ferc.gov). For TTY, call (202) 502-8659.

Dated: December 10, 2014.

**Kimberly D. Bose,**  
*Secretary.*

[FR Doc. 2014-29535 Filed 12-16-14; 8:45 am]

BILLING CODE 6717-01-P

**DEPARTMENT OF ENERGY**

**Federal Energy Regulatory Commission**

[Docket No. CD15-16-000]

**Imperial Irrigation District; Notice of Preliminary Determination of a Qualifying Conduit Hydropower Facility and Soliciting Comments and Motions To Intervene**

On November 26, 2014, the Imperial Irrigation District filed a notice of intent to construct a qualifying conduit hydropower facility, pursuant to section 30 of the Federal Power Act (FPA), as amended by section 4 of the Hydropower Regulatory Efficiency Act of 2013 (HREA). The proposed Fillaree Check on Westside Main Canal In-Conduit Hydroelectric Project would have an installed capacity of 675 kilowatts (kW) and would be located on the existing Westside Main Canal. This conduit transports water for irrigation, municipal, and industrial purposes. The project would be located near the city of Edgar in Imperial County, California.

*Applicant Contact:* Carl Stills, 1651 West Main Street, El Centro, CA 92243, Phone No. (760) 339-9701.

*FERC Contact:* Robert Bell, Phone No. (202) 502-6062, email: [robert.bell@ferc.gov](mailto:robert.bell@ferc.gov).

*Qualifying Conduit Hydropower Facility Description:* The proposed project would consist of: (1) A proposed 20.2-foot-long, 35.8-foot-wide open concrete canal intake structure with two 10-foot wide gates; (2) a proposed 15- by 41-foot powerhouse containing two turbine generator units with a total installed capacity of 675 kW; (3) the proposed 184-foot-long, 35.8-foot-wide underground closed concrete box tailrace structure which returns the water into the Westside Main Canal; and

<sup>1</sup> 18 CFR 385.2001-2005 (2014).