

present evidence and cross-examine witnesses.

A request for a hearing or a petition for leave to intervene must be filed with the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention: Rulemakings and Adjudications Staff, or may be delivered to the Commission's Public Document Room, located at One White Flint North, 11555 Rockville Pike (first floor), Rockville, Maryland, by the above date. A copy of the petition should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and to Mr. William D. Johnson, Vice President and Corporate Secretary, Carolina Power & Light Company, Post Office Box 1551, Raleigh, North Carolina 27602, attorney for the licensee.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the presiding Atomic Safety and Licensing Board that the petition and/or request should be granted based upon a balancing of the factors specified in 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).

If a request for a hearing is received, the Commission's staff may issue the amendment after it completes its technical review and prior to the completion of any required hearing if it publishes a further notice for public comment of its proposed finding of no significant hazards consideration in accordance with 10 CFR 50.91 and 50.92.

For further details with respect to this action, see the application for amendment dated December 14, 2000, which is available for public inspection at the Commission's Public Document Room, located at One White Flint North, 11555 Rockville Pike (first floor), Rockville, Maryland, and accessible electronically through the ADAMS Public Electronic Reading Room link at the NRC Web site (<http://www.nrc.gov>).

Dated at Rockville, Maryland, this 31st day of January 2001.

For the Nuclear Regulatory Commission.

**Richard J. Laufer,**

*Project Manager, Section 2, Project Directorate II, Division of Licensing Project Management, Office of Nuclear Reactor Regulation.*

[FR Doc. 01-3024 Filed 2-5-01; 8:45 am]

BILLING CODE 7590-01-P

## NUCLEAR REGULATORY COMMISSION

[Docket No. 50-213-OLA and ASLBP No. 01-787-02-OLA]

### Connecticut Yankee Atomic Power Company Haddam Neck Plant; Establishment of Atomic Safety and Licensing Board

Pursuant to delegation by the Commission dated December 29, 1972, published in the **Federal Register**, 37 Fed. Reg. 28,710 (1972), and Sections 2.105, 2.700, 2.702, 2.714, 2.714a, 2.717, 2.721, and 2.772(j) of the Commission's Regulations, all as amended, an Atomic Safety and Licensing Board is being established to preside over the following proceeding:

Connecticut Yankee Atomic Power Company Haddam Neck Plant

This Board is being established pursuant to a notice of consideration of issuance of operating license amendments, proposed no significant hazards consideration determination, and opportunity for a hearing published in the **Federal Register** (65 Fed. Reg. 77,913, 77,915 (Dec. 13, 2000)). The proceeding involves petitions for intervention filed on January 10 and January 12, 2001, respectively, by Citizens Awareness Network and the Connecticut Department of Public Utility Controls challenging a license amendment request by Connecticut Yankee Atomic Power Company to add a license condition to the operating license for the Haddam Neck Plant. The amendment would approve the License Termination Plan (LTP), dated July 7, 2000, and allow the licensee to make changes to the approved LTP without prior Nuclear Regulatory Commission approval, provided criteria specified in the license condition are met.

The Board is comprised of the following administrative judges:

Ann Marshall Young, Chair, Atomic Safety and Licensing Board Panel, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555-0001

Dr. Peter S. Lam, Atomic Safety and Licensing Board Panel, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555-0001

Thomas D. Murphy, Atomic Safety and Licensing Board Panel, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555-0001

All correspondence, documents, and other materials shall be filed with the administrative judges in accordance with 10 CFR 2.701.

Issued at Rockville, Maryland, this 31st day of January 2001.

**G. Paul Bollwerk, III,**

*Chief Administrative Judge, Atomic Safety and Licensing Board Panel.*

[FR Doc. 01-3023 Filed 2-5-01; 8:45 am]

BILLING CODE 7590-01-P

## NUCLEAR REGULATORY COMMISSION

### Public Workshop to Discuss Nuclear Power Reactor Steam Generator Tube Issues

**AGENCY:** Nuclear Regulatory Commission.

**ACTION:** Notice of Workshop.

**SUMMARY:** The Nuclear Regulatory Commission (NRC) will host a public workshop to provide an opportunity for discussion of recent events with respect to nuclear power plant steam generators and their implications. The workshop is open to the public.

**DATES:** The workshop will be held on Tuesday, February 27, 2001, from 7:30 a.m. to 5:15 p.m. and Wednesday, February 28, 2001 from 8:00 a.m. to 11:45 a.m.

**ADDRESSES:** Holiday Inn, Bethesda, 8120 Wisconsin Avenue, Bethesda, Maryland 20814. The hotel's telephone number is (301) 652-2000.

#### FOR FURTHER INFORMATION CONTACT:

Robert L. Rothman, Mail Stop O-9D3, U.S. Nuclear Regulatory Commission, Washington, DC 20555, telephone: (301) 415-3306, email [rlr@nrc.gov](mailto:rlr@nrc.gov).

**SUPPLEMENTARY INFORMATION:** All pressurized water reactor licensees are required by NRC regulations to provide reasonable assurance of steam generator tube integrity. These regulations pertain to design, operation and surveillance activities of steam generators and are reflected in the licensing basis of each facility. The surveillance requirements are important to maintaining integrity, since different types of tube degradation are expected to occur over the life of the steam generator. Tubes that are identified as containing defects of a specified depth are removed from service.

In recent years, the NRC staff has examined the regulatory programs which comprise the framework for ensuring the integrity of steam generator tubes. In 1997 the Nuclear Energy Institute proposed NEI 97-06, "Steam Generator Program Guidelines," as a formal industry initiative to provide a consistent industry approach for managing steam generator programs and for maintaining steam generator tube integrity. In 1998, the Commission