

Wolf Creek Nuclear Operating Corporation, Docket No. 50-482, Wolf Creek Generating Station, Coffey County, Kansas

Date of amendment request: August 25, 2006, as supplemented by letter dated October 25, 2006.

Brief description of amendment: The amendment revised Technical Specification (TS) 3.7.2, "Main Steam Isolation Valves (MSIVs)," and TS 3.7.3, "Main Feedwater Isolation Valves (MFIVs)," to add the associated actuator trains to (1) the limiting condition for operation (LCO), (2) the conditions, required actions, and completion times for the LCO, and (3) the surveillance requirements. The Table of Contents for the TSs is changed to account for the resulting renumbering of TS pages.

Date of issuance: November 7, 2006.

Effective date: As of its date of issuance and shall be implemented within 30 days of the date of issuance.

Amendment No.: 171.

Facility Operating License No. NPF-42. The amendment revised the Technical Specifications.

Date of initial notice in Federal Register: September 1, 2006 (71 FR 52173).

The supplemental letter dated October 25, 2006, provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the NRC staff's original proposed no significant hazards consideration determination published in the **Federal Register**.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated November 7, 2006.

No significant hazards consideration comments received: No.

Dated at Rockville, Maryland, this 9th day of November, 2006.

For The Nuclear Regulatory Commission.
Catherine Haney,

Director, Division of Operating Reactor Licensing, Office of Nuclear Reactor Regulation.

[FR Doc. E6-19434 Filed 11-20-06; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[NUREG-1852]

Demonstrating the Feasibility and Reliability of Operator Manual Actions in Response to Fire, Draft Report for Comment

AGENCY: Nuclear Regulatory Commission.

ACTION: Extension of comment period for NUREG-1852, "Demonstrating the Feasibility and Reliability of Operator Manual Actions in Response to Fire, Draft Report for Comment."

SUMMARY: On October 12, 2006 (71 FR 60200), the Nuclear Regulatory Commission (NRC) issued for public comment NUREG 1852, "Demonstrating the Feasibility and Reliability of Operator Manual Actions in Response to Fire, Draft Report for Comment." Due to an error in the previous notice of comment period extension, a request has been made to extend the public comment period to allow the public 60 days to review the document. Currently, the **Federal Register** specifies that the public comment period ends on December 12, 2006.

DATES: The comment period has been extended and now expires on January 30, 2007. Comments received after this date will be considered if it is practical to do so, but the Commission is able to ensure consideration only for comments received before this date.

ADDRESSES: Members of the public are invited and encouraged to submit written comments to Michael Lesar, Chief, Rules and Directives Branch, Office of Administration, Mail Stop T6-D59, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001. Hand-deliver comments attention to Michael Lesar, 11545 Rockville Pike, Rockville, MD, between 7:30 a.m. and 4:15 p.m. on Federal workdays. Comments may also be sent electronically to NRCREP@nrc.gov.

This document, NUREG-1852, is available at the Agencywide Documents Access and Management System (ADAMS) Public Electronic Reading Room on the Internet at the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> under Accession No. ML062350292; on the NRC Web site at <http://www.nrc.gov/reading-rm/doc-collections/nuregs/docs4comment.html>; and at the NRC Public Document Room, 11555 Rockville Pike, Rockville, MD. The PDR's mailing address is USNRC PDR, Washington, DC 20555; telephone (301) 415-4737 or (800) 397-4205; fax (301) 415-3548; e-mail PDR@NRC.GOV.

FOR FURTHER INFORMATION CONTACT: Erasmia Lois, Human Factors and Reliability Branch, Office of Nuclear Regulatory Research, telephone: (301) 415-6560; e-mail: exl1@nrc.gov.

Dated at Rockville, Maryland, this 15th day of November, 2006.

For the Nuclear Regulatory Commission.

Jose Ibarra,

Chief, Human Factors and Reliability Branch, Probabilistic Risk and Applications, Division of Risk Assessment and Special Projects, Office of Nuclear Regulatory Research.

[FR Doc. E6-19626 Filed 11-20-06; 8:45 am]

BILLING CODE 7590-01-P

OFFICE OF PERSONNEL MANAGEMENT

General Schedule Locality Pay Areas

AGENCY: Office of Personnel Management.

ACTION: Notice.

SUMMARY: On behalf of the President's Pay Agent, the Office of Personnel Management (OPM) is providing notice about two changes in locality pay area boundaries in 2007 under the locality pay program for General Schedule and certain other employees. Grayson County, TX, will be added to the Dallas locality pay area, and Berks County, PA, will be added to the Philadelphia locality pay area. These changes will occur automatically under existing regulations. OPM also plans to issue a notice later about changes in the regulations needed to update the official descriptions of the Boston-Worcester-Manchester, MA-NH-ME-RI locality pay area and the Denver-Aurora-Boulder, CO locality pay area. As required by OPM regulations, the additions to locality pay areas are effective as of the first pay period beginning on or after January 1, 2007. Both the additions and the planned description changes are the result of changes made by the Office of Management and Budget in Metropolitan Statistical Areas and Combined Statistical Areas.

DATES: The additions to locality pay areas are applicable on the first day of the first pay period beginning on or after January 1, 2007.

FOR FURTHER INFORMATION CONTACT: Allan Hearne, (202) 606-2838; FAX: (202) 606-4264; e-mail: pay-performance-policy@opm.gov.

Section 5304 of title 5, United States Code, authorizes locality pay for General Schedule (GS) employees with duty stations in the contiguous United States and the District of Columbia.

Section 5304(f) of title 5, United States Code, authorizes the President's Pay Agent (the Secretary of Labor, the Director of the Office of Management and Budget (OMB), and the Director of the Office of Personnel Management (OPM) to determine locality pay areas. The boundaries of locality pay areas must be based on appropriate factors,