

If the amendment is issued before the expiration of the 30-day hearing period, the Commission will make a final determination on the issue of no significant hazards consideration. If a hearing is requested, the final determination will serve to decide when the hearing is held.

If the final determination is that the amendment request involves no significant hazards consideration, the Commission may issue the amendment and make it immediately effective, notwithstanding the request for a hearing. Any hearing held would take place after issuance of the amendment.

If the final determination is that the amendment request involves a significant hazards consideration, any hearing held would take place before the issuance of any amendment.

A request for a hearing or a petition for leave to intervene must be filed with the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention: Rulemakings and Adjudications Staff, or may be delivered to the Commission's Public Document Room, located at One White Flint North, 11555 Rockville Pike (first floor), Rockville, Maryland, by the above date. A copy of the petition should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and to David W. Jenkins, Esq., Indiana Michigan Power Company, Nuclear Generation Group, One Cook Place, Bridgman, MI 49106, attorney for the licensee.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the presiding Atomic Safety and Licensing Board that the petition and/or request should be granted based upon a balancing of the factors specified in 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).

For further details with respect to this action, see the application for amendment dated July 17, 2001, which is available for public inspection at the Commission's Public Document Room, located at One White Flint North, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible electronically from the Agencywide Documents Access and Management Systems (ADAMS) Public Electronic Reading Room on the Internet at the NRC web site, <http://www.nrc.gov/NRC/ADAMS/index.html>. If you do not have access to ADAMS or if there are problems in accessing the documents located in ADAMS, contact the NRC Public Document Room

Reference staff at 1-800-397-4209, 301-415-4737 or by email to pdr@nrc.gov.

Dated at Rockville, Maryland, this 19th day of July 2001.

For the Nuclear Regulatory Commission.

Carl F. Lyon,

Project Manager, Section 1, Project Directorate III, Division of Licensing Project Management, Office of Nuclear Reactor Regulation.

[FR Doc. 01-18522 Filed 7-24-01; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket Nos. STN 50-454, STN 50-455, STN 50-456 and STN 50-457]

Exelon Generation Company, LLC Byron Station, Units 1 and 2 Braidwood Station, Units 1 and 2; Environmental Assessment and Finding of No Significant Impact

The U.S. Nuclear Regulatory Commission (NRC) is considering issuance of an exemption from the requirements of Title 10 of the *Code of Federal Regulations* (10 CFR) part 50, Section 50.60(a) for Facility Operating License Nos. NPF-37, NPF-66, NPF-72 and NPF-77, issued to Exelon Generation Company, LLC, (the licensee), for operation of the Byron Station, Units 1 and 2, and Braidwood Station, Units 1 and 2 located in Ogle County in Illinois and Will County in Illinois, respectively. Therefore, as required by 10 CFR 51.21, the NRC is issuing this environmental assessment and finding of no significant impact.

Environmental Assessment

Identification of the Proposed Action

The proposed action would exempt Byron and Braidwood from application of specific requirements of 10 CFR part 50, Section 50.60(a) as it applies to Appendix G, and substitute with the use of ASME Code Cases N-588 and N-640. 10 CFR part 50, Appendix G, requires that pressure-temperature (P-T) limits be established for reactor pressure vessels (RPVs) during normal operating and hydrostatic or leak rate testing conditions. Specifically, 10 CFR part 50, Appendix G, states, "The appropriate requirements on both the pressure-temperature limits and the minimum permissible temperature must be met for all conditions." Appendix G of 10 CFR Part 50 specifies that the requirements for these limits are the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code (Code), Section XI, Appendix G Limits.

The proposed action is in accordance with the licensee's application for exemption dated July 5, 2000, as supplemented by letter dated December 8, 2000.

The Need for the Proposed Action

The proposed action (*i.e.*, granting the exemption) is needed because utilization of Code Case N-588 and Code Case N-640 will widen the current narrow P-T operating window, especially in the region of low temperature operations. The two primary safety benefits that would be realized are a reduction in the challenges to the low-temperature over pressure protection (LTOP) system, resulting in an inadvertent opening of a power-operated relief valve (PORV) and a reduction in the risk of damaging the reactor coolant pump seals due to pump operation, under conditions where it is difficult to maintain adequate seal differential pressure to ensure proper pump operation.

Code Case N-588 permits the postulation of a circumferentially-oriented flaw (in lieu of an axially-oriented flaw) for the evaluation of the circumferential welds in RPV P-T limit curves. Code Case N-640 permits the use of an alternate reference fracture toughness (K_{IC} fracture toughness curve instead of K_{Ia} fracture toughness curve) for reactor vessel materials in determining the P-T limits. Since the pressure stresses on a circumferentially-oriented flaw are lower than the pressure stresses on an axially-oriented flaw by a factor of 2, using Code Case N-588 for establishing the P-T limits would be less conservative than the methodology currently endorsed by 10 CFR Part 50, Appendix G and, therefore, an exemption to apply the Code Case would be required by 10 CFR 50.60. Likewise, since the K_{IC} fracture toughness curve shown in ASME Section XI, Appendix A, Figure G-2200-1 (the K_{IC} fracture toughness curve) provides greater allowable fracture toughness than the corresponding K_{Ia} fracture toughness curve of ASME Section XI, Appendix G, Figure G-2210-1 (the K_{Ia} fracture toughness curve), using Code Case N-640 for establishing the P-T limits would be less conservative than the methodology currently endorsed by 10 CFR Part 50, Appendix G and, therefore, an exemption to apply the Code Case would also be required by 10 CFR 50.60. It should be noted that, although Code Case N-640 was incorporated into the ASME Code recently, an exemption is still needed because the proposed P-T limits (excluding Code Cases N-588 and

N-640) are based on the 1989 edition of the ASME Code.

Environmental Impacts of the Proposed Action

The NRC has completed its evaluation of the proposed action and concludes granting the exemption would provide an adequate margin of safety against brittle failure of the Byron and Braidwood reactor vessels. The proposed action (*i.e.*, granting the exemption) will not significantly increase the probability or consequences of accidents, no changes are being made in the types of any effluents that may be released off site, and there is no significant increase in occupational or public radiation exposure. Therefore, there are no significant radiological environmental impacts associated with the proposed action.

With regard to potential non-radiological impacts, the proposed action does not have a potential to affect any historic sites. It does not affect non-radiological plant effluents and has no other environmental impact. Therefore, there are no significant non-radiological environmental impacts associated with the proposed action.

Accordingly, the NRC concludes that there are no significant environmental impacts associated with the proposed action.

Environmental Impacts of the Alternatives to the Proposed Action

As an alternative to the proposed action, the staff considered denial of the proposed action (*i.e.*, the "no-action" alternative). Denial of the application would result in no change in current environmental impacts. The environmental impacts of the proposed action and the alternative action are similar.

Alternative Use of Resources

This action does not involve the use of any different resource than those previously considered in the Final Environmental Statement for the Byron and Braidwood stations dated April 1982 and June 1984 respectively.

Agencies and Persons Consulted

On June 22, 2001, the staff consulted with the Illinois State official, Mr. Frank Niziolek of the Illinois Department of Nuclear Safety, regarding the environmental impact of the proposed action. The State official had no comments.

Finding of No Significant Impact

On the basis of the environmental assessment, the NRC concludes that the proposed action will not have a

significant effect on the quality of the human environment. Accordingly, the NRC has determined not to prepare an environmental impact statement for the proposed action.

For further details with respect to the proposed action, see the licensee's letter dated July 5, 2000, as supplemented by letter dated December 8, 2000. Documents may be examined, and/or copied for a fee, at the NRC's Public Document Room, located at One White Flint North, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible electronically from the Agencywide Documents Access and Management Systems (ADAMS) Public Electronic Reading Room on the Internet at the NRC web site, <http://www.nrc.gov/NRC/ADAMS/index.html>. If you do not have access to ADAMS or if there are problems in accessing the documents located in ADAMS, contact the NRC Public Document Room (PDR) Reference staff at 1-800-397-4209, 301-415-4737 or by e-mail to pdr@nrc.gov.

Dated at Rockville, Maryland, this 19th day of July 2001.

For the Nuclear Regulatory Commission.

Maresh Chawla,

Project Manager, Section 2, Project Directorate III, Division of Licensing Project Management, Office of Nuclear Reactor Regulation.

[FR Doc. 01-18520 Filed 7-24-01; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

Biweekly Notice; Applications and Amendments to Facility Operating Licenses Involving No Significant Hazards Considerations

I. Background

Pursuant to Public Law 97-415, the U.S. Nuclear Regulatory Commission (the Commission or NRC staff) is publishing this regular biweekly notice. Public Law 97-415 revised section 189 of the Atomic Energy Act of 1954, as amended (the Act), to require the Commission to publish notice of any amendments issued, or proposed to be issued, under a new provision of section 189 of the Act. This provision grants the Commission the authority to issue and make immediately effective any amendment to an operating license upon a determination by the Commission that such amendment involves no significant hazards consideration, notwithstanding the pendency before the Commission of a request for a hearing from any person.

This biweekly notice includes all notices of amendments issued, or proposed to be issued from July 2, 2001 through July 13, 2001. The last biweekly notice was published on July 11, 2001 (66 FR 36335).

Notice of Consideration of Issuance of Amendments to Facility Operating Licenses, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing

The Commission has made a proposed determination that the following amendment requests involve no significant hazards consideration. Under the Commission's regulations in 10 CFR 50.92, this means that operation of the facility in accordance with the proposed amendment would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. The basis for this proposed determination for each amendment request is shown below.

The Commission is seeking public comments on this proposed determination. Any comments received within 30 days after the date of publication of this notice will be considered in making any final determination.

Normally, the Commission will not issue the amendment until the expiration of the 30-day notice period. However, should circumstances change during the notice period such that failure to act in a timely way would result, for example, in derating or shutdown of the facility, the Commission may issue the license amendment before the expiration of the 30-day notice period, provided that its final determination is that the amendment involves no significant hazards consideration. The final determination will consider all public and State comments received before action is taken. Should the Commission take this action, it will publish in the **Federal Register** a notice of issuance and provide for opportunity for a hearing after issuance. The Commission expects that the need to take this action will occur very infrequently.

Written comments may be submitted by mail to the Chief, Rules and Directives Branch, Division of Administrative Services, Office of Administration, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and should cite the publication date and page number of this **Federal Register** notice. Written comments may