

**NUCLEAR REGULATORY
COMMISSION****[Docket Nos. 50-269, 50-270, and 50-287]****Duke Energy Corporation; Oconee
Nuclear Station, Units 1, 2, and 3,
Exemption****1.0 Background**

Duke Energy Corporation (the licensee) is the holder of Facility Operating License Nos. DPR-38, DPR-47, and DPR-55, which authorize operation of the Oconee Nuclear Station, Units 1, 2, and 3. The licenses provide, among other things, that the facility is subject to all rules, regulations, and orders of the U.S. Nuclear Regulatory Commission (NRC/the Commission) now or hereafter in effect.

The facility consists of three pressurized water reactors located in Seneca County in South Carolina.

2.0 Request/Action

Title 10 of the Code of Federal Regulations (10 CFR) § 55.59(a)(1) requires that each licensed operator successfully complete a requalification program developed by the licensee that has been approved by the Commission. This program is to be conducted for a continuous period not to exceed 24 months in duration and upon its conclusion must be promptly followed by a successive requalification program. In addition, pursuant to 10 CFR 55.59(a)(2), each licensed operator must also pass a comprehensive requalification written examination and an annual operating test.

By letter dated March 6, 2001, the licensee requested an exemption under 10 CFR 55.11 from the requirements of 10 CFR 55.59(a)(1) and (a)(2). The exemption requested will extend the current Oconee Nuclear Station requalification program from June 4, 2001, to July 13, 2001. The requested exemption would constitute a one-time extension of the requalification program duration.

3.0 Discussion

Pursuant to 10 CFR 55.11, the Commission may, upon application by an interested person, or upon its own initiative, grant such exemptions from the requirements of the regulations in this part as it determines are authorized by law and will not endanger life or property and are otherwise in the public interest.

The Commission has determined that, pursuant to 10 CFR 55.11, granting an exemption to the licensee from the requirements in 10 CFR 55.59(a)(1) and

(a)(2) is authorized by law, will not endanger life or property, and is in the public interest. To require the licensee's operators and staff to support the comprehensive examination and operating tests schedule during the 24-month requalification cycle could have a detrimental effect on the public interest because it would remove qualified operators from refueling operations and place them into the training program, which could interfere with the current Oconee Unit 2 refueling outage schedule. Further, this one-time exemption will provide additional operator support during plant shutdown conditions, which would provide a safety enhancement during plant shutdown operations and post-maintenance testing. The affected licensed operators will continue to demonstrate and possess the required levels of knowledge, skills, and abilities needed to safely operate the plant throughout the transitional period via continuation of the current satisfactory licensed operator requalification program.

4.0 Conclusion

Accordingly, the Commission hereby grants the licensee an exemption on a one-time only basis from the requirements of 10 CFR 55.59(a)(1) and (a)(2) to allow the current Oconee Nuclear Station requalification program to be extended beyond the 24 months, but not to exceed 26 months and to expire on July 13, 2001. Upon completion of the examinations on July 13, 2001, the follow-on cycle will end on March 8, 2003. Future annual requalification cycles will run from March to March.

Pursuant to 10 CFR 51.32, the Commission has determined that the granting of this exemption will not have a significant effect on the quality of the human environment (66 FR 29347).

This exemption is effective upon issuance and expires on March 8, 2003.

Dated at Rockville, Maryland, this 30th day of May 2001.

For the Nuclear Regulatory Commission.

Bruce A. Boger,

*Director, Division of Inspection Program
Management, Office of Nuclear Reactor
Regulation.*

[FR Doc. 01-14094 Filed 6-4-01; 8:45 am]

BILLING CODE 7590-01-P

**NUCLEAR REGULATORY
COMMISSION****[Docket No. 50-389]****Florida Power and Light Company, et
al. St. Lucie Plant, Unit No. 2;
Environmental Assessment and
Finding of No Significant Impact**

The U.S. Nuclear Regulatory Commission (NRC) is considering issuance of an exemption from 10 CFR 50.55a(f)(ii) and 50.55a(f)(5)(i) for Facility Operating License No. NPF-16, issued to Florida Power and Light Company, *et al.* (the licensee), for operation of the St. Lucie Unit 2, located in St. Lucie County, Florida.

Environmental Assessment*Identification of the Proposed Action*

The proposed action would revise the second and third 120-month Inservice Test (IST) intervals for St. Lucie Unit 2. Currently, St. Lucie Unit 2 is in its second IST interval, with an end date of August 7, 2003. The proposed action would shorten the second IST interval for St. Lucie Unit 2 by retroactively changing the end date to February 10, 1998, to coincide with the end date of the second IST interval for St. Lucie Unit 1. Thus, the third IST interval for both units would begin on February 11, 1998, and end on February 10, 2008.

The proposed action is in accordance with the licensee's application for exemption dated November 27, 2000.

The Need for the Proposed Action

The IST intervals for St. Lucie Units 1 and 2 are currently offset by approximately 5 years, primarily due to the initial licensing dates of the units. This requires maintaining distinct but similar programs, with the administrative burden of updating them approximately every 5 years. The proposed action provides a one-time schedule exemption, which would allow the licensee to implement a combined IST program consistent between units, requiring compliance with the same edition of the American Society of Mechanical Engineers Code and addenda, and allow both units to be tested using the same test requirements.

Environmental Impacts of the Proposed Action

The NRC has completed its evaluation of the proposed action and concludes that there are no significant environmental impacts associated with the proposed action.

The proposed action will not significantly increase the probability or consequences of accidents, no changes

are being made in the types of any effluents that may be released off site, and there is no significant increase in occupational or public radiation exposure. Therefore, there are no significant radiological environmental impacts associated with the proposed action.

With regard to potential nonradiological impacts, the proposed action does not involve any historic sites. It does not affect nonradiological plant effluents and has no other environmental impact. Therefore, there are no significant nonradiological environmental impacts associated with the proposed action.

Accordingly, the NRC concludes that there are no significant environmental impacts associated with the proposed action.

Alternatives to the Proposed Action

As an alternative to the proposed action, the staff considered denial of the proposed action (i.e., the "no-action" alternative). Denial of the application would result in no change in current environmental impacts. The environmental impacts of the proposed action and the alternative action are similar.

Alternative Use of Resources

This action does not involve the use of any different resources than those previously considered in the Final Environmental Statement for St. Lucie Unit 2 (NUREG-0842).

Agencies and Persons Consulted

In accordance with its stated policy, on May 17, 2001, the staff consulted with the Florida State official, William Passetti, of the Bureau of Radiation Control, regarding the environmental impact of the proposed action. The State official had no comments.

Finding of No Significant Impact

On the basis of the environmental assessment, the NRC concludes that the proposed action will not have a significant effect on the quality of the human environment. Accordingly, the NRC has determined not to prepare an environmental impact statement for the proposed action.

For further details with respect to the proposed action, see the licensee's letter dated November 27, 2000. Documents may be examined, and/or copied for a fee, at the NRC's Public Document Room, located at One White Flint North, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible electronically from the ADAMS Public Library component on the NRC Web site, <http://www.nrc.gov> (the Public Electronic Reading Room).

/www.nrc.gov (the Public Electronic Reading Room).

Dated at Rockville, Maryland, this 30th day of May 2001.

For the Nuclear Regulatory Commission.

Brendan T. Moroney,

Project Manager, Section 2, Project Directorate II Division of Licensing Project Management Office of Nuclear Reactor Regulation

[FR Doc. 01-14093 Filed 6-4-01; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

Sunshine Act Meeting

AGENCY HOLDING THE MEETING: Nuclear Regulatory Commission.

DATES: Weeks of June 4, 11, 18, 25, July 2, 9, 2001.

PLACE: Commissioners' Conference Room, 11555 Rockville Pike, Rockville, Maryland.

STATUS: Public and Closed.

MATTERS TO BE CONSIDERED:

Week of June 4, 2001

Tuesday, June 5, 2001

9:25 a.m.—Affirmation Session (Public Meeting) (if needed)

2:00 p.m.—Discussion of Management Issues (Closed-Ex. 2)

Wednesday, June 6, 2001

10:30 a.m.—All Employees Meeting (Public Meeting)

1:30 p.m.—All Employees Meeting (Public Meeting)

Week of June 11, 2001—Tentative

Thursday, June 14, 2001

9:55 a.m.—Affirmation Session (Public Meeting) (if needed)

10:00 a.m.—Meeting with Nuclear Waste Technical Review Board (Public Meeting)

1:30 p.m.—Briefing on License Renewal Program (Public Meeting) (Contact: David Solorio, 301-415-1973)

Week of June 18, 2001—Tentative

There are no meetings scheduled for the Week of June 18, 2001.

Week of June 25, 2001—Tentative

Wednesday, June 27, 2001

9:25 a.m.—Affirmation Session (Public Meeting) (if needed)

Week of July 2, 2001—Tentative

There are no meetings scheduled for the Week of July 2, 2001.

Week of July 9, 2001—Tentative

Monday, July 9, 2001

1:25 p.m.—Affirmative Session (Public Meeting) (if needed)

*The schedule for Commission meetings is subject to change on short notice. To verify the status of meetings call (recording)—(301) 415-1292. Contact person for more information: David Louis Gamberoni, (301) 415-1651.

The NRC Commission Meeting Schedule can be found on the Internet at: <http://www.nrc.gov/SECY/smj/schedule.htm>

This notice is distributed by mail to several hundred subscribers; if you no longer wish to receive it, or would like to be added to the distribution, please contact the Office of the Secretary, Washington, D.C. 20555 (301-415-1969). In addition, distribution of this meeting notice over the Internet system is available. If you are interested in receiving this Commission meeting schedule electronically, please send an electronic message to dkw@nrc.gov.

Dated: May 31, 2001.

David Louis Gamberoni,

Technical Coordinator, Office of the Secretary.

[FR Doc. 01-14257 Filed 6-1-01; 2:03 pm]

BILLING CODE 7590-01-M

SECURITIES AND EXCHANGE COMMISSION

[Release No. 35-27409]

Filings Under the Public Utility Holding Company Act of 1935, as Amended ("Act")

May 29, 2001.

Notice is hereby given that the following filing(s) has/have been made with the Commission pursuant to provisions of the Act and rules promulgated under the Act. All interested persons are referred to the application(s) and/or declaration(s) for complete statements of the proposed transaction(s) summarized below. The application(s) and/or declaration(s) and any amendment(s) is/are available for public inspection through the Commission's Branch of Public Reference.

Interested persons wishing to comment or request a hearing on the application(s) and/or declaration(s) should submit their views in writing by June 22, 2001, to the Secretary, Securities and Exchange Commission, Washington, DC 20549-0609, and serve a copy on the relevant applicant(s) and/or declaration(s) at the address(es) specified below. Proof of service (by