

III. Backfitting and Issue Finality

This preliminary draft guidance would set forth a set of security design considerations that a designer should consider while developing the facility design. These considerations, if adequately implemented through detailed design, along with the adequate implementation of administrative controls and security programs, are one way to protect a nuclear power reactor against the design basis threat for radiological sabotage. These considerations do not limit designers or applicants from applying other methods or approaches in designing engineered systems to perform intended security functions.

The purpose of this preliminary draft guidance is to assist the NRC staff and future applicants. The security design considerations are not regulatory requirements. Parts 50 and 52 of title 10 of the *Code of Federal Regulations* (10 CFR), require that an application for an operating license, design certification, combined license, standard design approval, or manufacturing license, describe how the proposed facility would comply with the physical and cyber security requirements in §§ 73.55 and 54, respectively. The security design considerations provide guidance intended to support the resolution of security issues through the facility design.

This preliminary draft guidance, if finalized, for example, in a regulatory guide, would not constitute backfitting as defined in 10 CFR 50.109 (the Backfit Rule) and would not otherwise be inconsistent with the issue finality provisions in 10 CFR part 52, “Licenses, Certifications and Approvals for Nuclear Power Plants.” This guidance, if finalized, would represent the first NRC guidance on this subject. Issuance of new guidance, by itself, does not represent backfitting unless the NRC intends to impose the guidance on existing licensees and currently-approved design certification rules issued under 10 CFR part 52. The NRC does not have such an intention.

Existing licensees and applicants of final design certification rules would not be required to comply with this guidance, unless the licensee or design certification rule applicant seeks a voluntary change to its licensing basis with respect to resolving security matters through facility design.

Applicants and potential applicants are not, with certain exceptions, protected by either the Backfit Rule or any issue finality provisions under 10 CFR part 52. Neither the Backfit Rule nor the issue finality provisions under

10 CFR part 52—with certain exceptions discussed in the next paragraph—were intended to apply to every NRC action which substantially changes the expectations of current and future applicants. Therefore, this guidance, if finalized and imposed on applicants, would not represent backfitting (except as discussed below).

The exceptions to the general principle are applicable whenever a combined license applicant references a 10 CFR part 52 license (*i.e.*, an early site permit or a manufacturing license) and/or 10 CFR part 52 regulatory approval (*i.e.*, a design certification rule or standard design approval). The NRC does not, at this time, intend to impose the positions represented in this preliminary draft guidance in a manner that is inconsistent with any issue finality provisions in the 10 CFR part 52 licenses and regulatory approvals. If, in the future, the NRC seeks to impose a position in this guidance in a manner which does not provide issue finality as described in the applicable issue finality provision, then the NRC must address the criteria for avoiding issue finality as described in the applicable issue finality provision.

Dated at Rockville, Maryland, this 3rd day of March, 2017.

For the Nuclear Regulatory Commission.

Michael E. Mayfield,

Deputy Director (Acting), Office of New Reactors.

[FR Doc. 2017-04873 Filed 3-10-17; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket No. 50-341; NRC-2017-0072]

DTE Electric Company; Fermi, Unit 2

AGENCY: Nuclear Regulatory Commission.

ACTION: License amendment application; opportunity to comment, request a hearing, and petition for leave to intervene.

SUMMARY: The U.S. Nuclear Regulatory Commission (NRC) is considering issuance of an amendment to Renewed Facility Operating License No. NPF-43, issued to DTE Electric Company (DTE), for operation of the Fermi, Unit 2. The proposed amendment revises technical specifications (TS) for emergency core cooling system (ECCS) instrumentation (TS 3.3.5.1) and reactor core isolation cooling (RCIC) system instrumentation (TS 3.3.5.2). The proposed changes add footnotes indicating that the injection functions of “Drywell Pressure—High”

for high-pressure coolant injection (HPCI) and “Manual Initiation” for HPCI and RCIC are not required to be operable under low reactor pressure conditions.

DATES: Submit comments by April 12, 2017. Requests for a hearing or petition for leave to intervene must be filed by May 12, 2017.

ADDRESSES: Please refer to Docket ID NRC-2017-0072 when contacting the NRC about the availability of information regarding this document. You may obtain publicly-available information related to this document using any of the following methods:

- **Federal Rulemaking Web site:** Go to <http://www.regulations.gov> and search for Docket ID NRC-2017-0072. Address questions about NRC dockets to Carol Gallagher; telephone: 301-415-3463; email: Carol.Gallagher@nrc.gov. For technical questions, contact the project manager listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- **Mail comments to:** Cindy Bladey, Office of Administration, Mail Stop: OWFN-12-H08, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001.

For additional direction on obtaining information and submitting comments, see “Obtaining Information and Submitting Comments” in the **SUPPLEMENTARY INFORMATION** section of this document.

FOR FURTHER INFORMATION CONTACT: Sujata Goetz, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001; telephone: 301-415-8004, email: Sujata.Goetz@NRC.gov.

SUPPLEMENTARY INFORMATION:

I. Obtaining Information and Submitting Comments

A. Obtaining Information

Please refer to Docket ID NRC-2017-0072 when contacting the NRC about the availability of information for this action. You may obtain publicly-available information related to this action by any of the following methods:

- **Federal Rulemaking Web site:** Go to <http://www.regulations.gov> and search for Docket ID NRC-2017-0072.

- **NRC’s Agencywide Documents Access and Management System (ADAMS):** You may obtain publicly-available documents online in the ADAMS Public Documents collection at <http://www.nrc.gov/reading-rm/adams.html>. To begin the search, select “ADAMS Public Documents” and then select “Begin Web-based ADAMS Search.” For problems with ADAMS,

please contact the NRC's Public Document Room (PDR) reference staff at 1-800-397-4209, 301-415-4737, or by email to pdr.resource@nrc.gov. The "License Amendment Request to Revise Technical Specifications for Emergency Core Cooling System Instrumentation and Reactor Core Isolation Cooling System Instrumentation" is available in ADAMS under Accession No. ML17055A365.

- *NRC's PDR:* You may examine and purchase copies of public documents at the NRC's PDR, Room O1-F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

B. Submitting Comments

Please include Docket ID NRC-2017-0072 in the subject line of your comment submission, in order to ensure that the NRC is able to make your comment submission available to the public in this docket.

The NRC cautions you not to include identifying or contact information that you do not want to be publicly disclosed in your comment submission. The NRC posts all comment submissions at <http://www.regulations.gov> as well as entering the comment submissions into ADAMS. The NRC does not routinely edit comment submissions to remove identifying or contact information.

If you are requesting or aggregating comments from other persons for submission to the NRC, then you should inform those persons not to include identifying or contact information that they do not want to be publicly disclosed in their comment submission. Your request should state that the NRC does not routinely edit comment submissions to remove such information before making the comment submissions available to the public or entering the comment submissions into ADAMS.

II. Introduction

The NRC is considering issuance of an amendment to Renewed Facility Operating License No. NFP-43, issued to DTE, for operation of the Fermi, Unit 2, located in Monroe County, Michigan. The proposed amendment requests modification of the TSs for emergency core cooling system (ECCS) instrumentation (TS 3.3.5.1) and reactor core isolation cooling (RCIC) system instrumentation (TS 3.3.5.2). The proposed changes add footnotes indicating that the injection functions of "Drywell Pressure—High" for HPCI and "Manual Initiation" for HPCI and RCIC are not required to be operable under low reactor pressure conditions.

Before any issuance of the proposed license amendment, the NRC will need to make the findings required by the Atomic Energy Act of 1954, as amended (the Act), and NRC's regulations.

The NRC has made a proposed determination that the license amendment request involves no significant hazards consideration. Under the NRC's regulations in § 50.92 of title 10 of the *Code of Federal Regulations* (10 CFR), this means that operation of the facility in accordance with the proposed amendment would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. Does the proposed change involve a significant increase in the probability or consequences of an accident previously evaluated?

Response: No.

The proposed changes involve the addition of clarifying footnotes to the HPCI [High Pressure Cooling Injection] and RCIC [Reactor Core Isolation Cooling] actuation instrumentation TS [Technical Specification] to reflect the as-built plant design and operability requirements of HPCI and RCIC instrumentation as described in the Fermi 2 UFSAR [Updated Final Safety Analysis Report].

HPCI is an initiator of the increase in reactor coolant inventory accident in UFSAR (Reference 7.1) Section 15.5.1. However, the accident assumes inadvertent manual startup of HPCI. The change being requested in this amendment is administrative in nature and does not make any changes to the HPCI system or procedures that would increase the probability for inadvertent manual startup of HPCI. RCIC is not an initiator of any accident previously evaluated. As a result, the probability of any accident previously evaluated is not increased. In addition, the manual initiation of HPCI and RCIC are not credited to mitigate the consequences of design basis accidents or transients within the current Fermi 2 design and licensing basis and automatic actuation of the HPCI system on the high drywell pressure signal is not required for the HPCI to perform its system safety functions in mitigating the consequences of a LOCA initiating at low reactor pressure.

Therefore, the proposed changes do not involve a significant increase in the probability or consequences of an accident previously evaluated.

2. Does the proposed change create the possibility of a new or different kind of accident from any accident previously evaluated?

Response: No.

The proposed changes do not alter the protection system design, create new failure modes, or change any modes of operation. The proposed changes do not involve a physical alteration of the plant, and no new or different kind of equipment will be installed. Consequently, there are no new initiators that could result in a new or different kind of accident.

Therefore, the proposed changes do not create the possibility of a new or different kind of accident from any accident previously evaluated.

3. Does the proposed change involve a significant reduction in a margin of safety?

Response: No.

The proposed changes have no adverse effect on plant operation. The plant response to the design basis accidents does not change. The proposed changes do not adversely affect existing plant safety margins or the reliability of the equipment assumed to operate in the safety analyses. There is no change being made to safety analysis assumptions, safety limits or limiting safety system settings that would adversely affect plant safety as a result of the proposed changes.

Therefore, the proposed changes do not involve a significant reduction in a margin of safety.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the license amendment request involves a no significant hazards consideration.

The NRC is seeking public comments on this proposed determination that the license amendment request involves no significant hazards consideration. Any comments received within 30 days after the date of publication of this notice will be considered in making any final determination.

Normally, the Commission will not issue the amendment until the expiration of 60 days after the date of publication of this notice. The Commission may issue the license amendment before expiration of the 60-day notice period if the Commission concludes the amendment involves no significant hazards consideration. In addition, the Commission may issue the amendment prior to the expiration of the 30-day comment period if circumstances change during the 30-day comment period such that failure to act in a timely way would result, for example, in derating or shutdown of the facility. If the Commission takes action prior to the expiration of either the comment period or the notice period, it will publish in the **Federal Register** a notice of issuance. If the Commission makes a final no significant hazards consideration determination, any hearing will take place after issuance. The Commission expects that the need

to take this action will occur very infrequently.

Opportunity To Request a Hearing and Petition for Leave To Intervene

Within 60 days after the date of publication of this notice, any persons (petitioner) whose interest may be affected by this action may file a request for a hearing and petition for leave to intervene (petition) with respect to the action. Petitions shall be filed in accordance with the Commission's "Agency Rules of Practice and Procedure" in 10 CFR part 2. Interested persons should consult a current copy of 10 CFR 2.309. The NRC's regulations are accessible electronically from the NRC Library on the NRC's Web site at <http://www.nrc.gov/reading-rm/doc-collections/cfr/>. Alternatively, a copy of the regulations is available at the NRC's Public Document Room, located at One White Flint North, Room O1-F21, 11555 Rockville Pike (first floor), Rockville, Maryland 20852. If a petition is filed, the Commission or a presiding officer will rule on the petition and, if appropriate, a notice of a hearing will be issued.

As required by 10 CFR 2.309(d) the petition should specifically explain the reasons why intervention should be permitted with particular reference to the following general requirements for standing: (1) The name, address, and telephone number of the petitioner; (2) the nature of the petitioner's right under the Act to be made a party to the proceeding; (3) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (4) the possible effect of any decision or order which may be entered in the proceeding on the petitioner's interest.

In accordance with 10 CFR 2.309(f), the petition must also set forth the specific contentions which the petitioner seeks to have litigated in the proceeding. Each contention must consist of a specific statement of the issue of law or fact to be raised or controverted. In addition, the petitioner must provide a brief explanation of the bases for the contention and a concise statement of the alleged facts or expert opinion which support the contention and on which the petitioner intends to rely in proving the contention at the hearing. The petitioner must also provide references to the specific sources and documents on which the petitioner intends to rely to support its position on the issue. The petition must include sufficient information to show that a genuine dispute exists with the applicant or licensee on a material issue of law or fact. Contentions must be limited to matters within the scope of

the proceeding. The contention must be one which, if proven, would entitle the petitioner to relief. A petitioner who fails to satisfy the requirements at 10 CFR 2.309(f) with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene. Parties have the opportunity to participate fully in the conduct of the hearing with respect to resolution of that party's admitted contentions, including the opportunity to present evidence, consistent with the NRC's regulations, policies, and procedures.

Petitions must be filed no later than 60 days from the date of publication of this notice. Petitions and motions for leave to file new or amended contentions that are filed after the deadline will not be entertained absent a determination by the presiding officer that the filing demonstrates good cause by satisfying the three factors in 10 CFR 2.309(c)(1)(i) through (iii). The petition must be filed in accordance with the filing instructions in the "Electronic Submissions (E-Filing)" section of this document.

If a hearing is requested, and the Commission has not made a final determination on the issue of no significant hazards consideration, the Commission will make a final determination on the issue of no significant hazards consideration. The final determination will serve to establish when the hearing is held. If the final determination is that the amendment request involves no significant hazards consideration, the Commission may issue the amendment and make it immediately effective, notwithstanding the request for a hearing. Any hearing would take place after issuance of the amendment. If the final determination is that the amendment request involves a significant hazards consideration, then any hearing held would take place before the issuance of the amendment unless the Commission finds an imminent danger to the health or safety of the public, in which case it will issue an appropriate order or rule under 10 CFR part 2.

A State, local governmental body, Federally-recognized Indian Tribe, or agency thereof, may submit a petition to the Commission to participate as a party under 10 CFR 2.309(h)(1). The petition should state the nature and extent of the petitioner's interest in the proceeding. The petition should be submitted to the Commission by May 12, 2017. The petition must be filed in accordance with the filing instructions in the

"Electronic Submissions (E-Filing)" section of this document, and should meet the requirements for petitions set forth in this section. Alternatively, a State, local governmental body, Federally-recognized Indian Tribe, or agency thereof may participate as a non-party under 10 CFR 2.315(c).

If a hearing is granted, any person who is not a party to the proceeding and is not affiliated with or represented by a party may, at the discretion of the presiding officer, be permitted to make a limited appearance pursuant to the provisions of 10 CFR 2.315(a). A person making a limited appearance may make an oral or written statement of his or her position on the issues but may not otherwise participate in the proceeding. A limited appearance may be made at any session of the hearing or at any prehearing conference, subject to the limits and conditions as may be imposed by the presiding officer. Details regarding the opportunity to make a limited appearance will be provided by the presiding officer if such sessions are scheduled.

Electronic Submissions (E-Filing)

All documents filed in NRC adjudicatory proceedings, including a request for hearing and petition for leave to intervene (petition), any motion or other document filed in the proceeding prior to the submission of a request for hearing or petition to intervene, and documents filed by interested governmental entities that request to participate under 10 CFR 2.315(c), must be filed in accordance with the NRC's E-Filing rule (72 FR 49139; August 28, 2007, as amended at 77 FR 46562, August 3, 2012). The E-Filing process requires participants to submit and serve all adjudicatory documents over the internet, or in some cases to mail copies on electronic storage media. Detailed guidance on making electronic submissions may be found in the Guidance for Electronic Submissions to the NRC and on the NRC Web site at <http://www.nrc.gov/site-help/e-submittals.html>. Participants may not submit paper copies of their filings unless they seek an exemption in accordance with the procedures described below.

To comply with the procedural requirements of E-Filing, at least 10 days prior to the filing deadline, the participant should contact the Office of the Secretary by email at hearing.docket@nrc.gov, or by telephone at 301-415-1677, to (1) request a digital identification (ID) certificate, which allows the participant (or its counsel or representative) to digitally sign submissions and access the E-Filing

system for any proceeding in which it is participating; and (2) advise the Secretary that the participant will be submitting a petition or other adjudicatory document (even in instances in which the participant, or its counsel or representative, already holds an NRC-issued digital ID certificate). Based upon this information, the Secretary will establish an electronic docket for the hearing in this proceeding if the Secretary has not already established an electronic docket.

Information about applying for a digital ID certificate is available on the NRC's public Web site at <http://www.nrc.gov/site-help/e-submittals/getting-started.html>. Once a participant has obtained a digital ID certificate and a docket has been created, the participant can then submit adjudicatory documents. Submissions must be in Portable Document Format (PDF). Additional guidance on PDF submissions is available on the NRC's public Web site at <http://www.nrc.gov/site-help/electronic-sub-ref-mat.html>. A filing is considered complete at the time the document is submitted through the NRC's E-Filing system. To be timely, an electronic filing must be submitted to the E-Filing system no later than 11:59 p.m. Eastern Time on the due date. Upon receipt of a transmission, the E-Filing system time-stamps the document and sends the submitter an email notice confirming receipt of the document. The E-Filing system also distributes an email notice that provides access to the document to the NRC's Office of the General Counsel and any others who have advised the Office of the Secretary that they wish to participate in the proceeding, so that the filer need not serve the document on those participants separately. Therefore, applicants and other participants (or their counsel or representative) must apply for and receive a digital ID certificate before adjudicatory documents are filed so that they can obtain access to the documents via the E-Filing system.

A person filing electronically using the NRC's adjudicatory E-Filing system may seek assistance by contacting the NRC's Electronic Filing Help Desk through the "Contact Us" link located on the NRC's public Web site at <http://www.nrc.gov/site-help/e-submittals.html>, by email to MSHD.Resource@nrc.gov, or by a toll-free call at 1-866-672-7640. The NRC Electronic Filing Help Desk is available between 9 a.m. and 6 p.m., Eastern Time, Monday through Friday, excluding government holidays.

Participants who believe that they have a good cause for not submitting

documents electronically must file an exemption request, in accordance with 10 CFR 2.302(g), with their initial paper filing stating why there is good cause for not filing electronically and requesting authorization to continue to submit documents in paper format. Such filings must be submitted by: (1) First class mail addressed to the Office of the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention: Rulemaking and Adjudications Staff; or (2) courier, express mail, or expedited delivery service to the Office of the Secretary, 11555 Rockville Pike, Rockville, Maryland, 20852, Attention: Rulemaking and Adjudications Staff. Participants filing adjudicatory documents in this manner are responsible for serving the document on all other participants. Filing is considered complete by first-class mail as of the time of deposit in the mail, or by courier, express mail, or expedited delivery service upon depositing the document with the provider of the service. A presiding officer, having granted an exemption request from using E-Filing, may require a participant or party to use E-Filing if the presiding officer subsequently determines that the reason for granting the exemption from use of E-Filing no longer exists.

Documents submitted in adjudicatory proceedings will appear in the NRC's electronic hearing docket which is available to the public at <https://adams.nrc.gov/ehd>, unless excluded pursuant to an order of the Commission or the presiding officer. If you do not have an NRC-issued digital ID certificate as described above, click cancel when the link requests certificates and you will be automatically directed to the NRC's electronic hearing dockets where you will be able to access any publicly available documents in a particular hearing docket. Participants are requested not to include personal privacy information, such as social security numbers, home addresses, or personal phone numbers in their filings, unless an NRC regulation or other law requires submission of such information. For example, in some instances, individuals provide home addresses in order to demonstrate proximity to a facility or site. With respect to copyrighted works, except for limited excerpts that serve the purpose of the adjudicatory filings and would constitute a Fair Use application, participants are requested not to include copyrighted materials in their submission.

For further details with respect to this action, see the application for license amendment dated February 23, 2017.

Attorney for licensee: Jon P. Christinidis, Expert Attorney—Regulatory, DTE Energy, 688 WCB, One Energy Plaza, Detroit, MI 48226.

Acting NRC Branch Chief: Kimberly J. Green.

Dated at Rockville, Maryland, this 7th day of March 2017.

For the Nuclear Regulatory Commission.

Sujata Goetz,

Project Manager, Division of Operating Reactor Licensing, Office of New Reactor Regulation.

[FR Doc. 2017-04874 Filed 3-10-17; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[NRC-2015-0229]

Design of Structures, Components, Equipment, and Systems

AGENCY: Nuclear Regulatory Commission.

ACTION: Standard review plan-final section revision; issuance.

SUMMARY: The U.S. Nuclear Regulatory Commission (NRC) is issuing a final revision to sections in Chapter 3, "Design of Structures, Components, Equipment, and Systems Reactor Coolant System and Connected Systems" of NUREG-0800, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants: LWR Edition." The changes to these Standard Review Plan (SRP) sections reflect responses to public comments and additional guidance based on current NRC staff review methods and practices based on lessons learned from the NRC's reviews of design certification and combined license applications completed since the last revision of this chapter.

DATES: The effective date of this Standard Review Plan (SRP) update is April 12, 2017.

ADDRESSES: Please refer to Docket ID NRC-2015-0229 when contacting the NRC about the availability of information regarding this document. You may obtain publicly-available information related to this document using any of the following methods:

- *Federal Rulemaking Web site:* Go to <http://www.regulations.gov> and search for Docket ID NRC-2015-0229. Address questions about NRC dockets to Carol Gallagher; telephone: 301-415-3463; email: Carol.Gallagher@nrc.gov. For technical questions, contact the individuals listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.