

email of new filings and issuances related to this or other pending projects. For assistance, call 1-866-208-3676 or email FERCOnlineSupport@ferc.gov, for TTY, call (202) 502-8659. Agencies may obtain copies of the application directly from the applicant.

m. Individuals desiring to be included on the Commission's mailing list should so indicate by writing to the Secretary of the Commission.

n. *Comments, Protests, or Motions to Intervene*: Anyone may submit comments, a protest, or a motion to intervene in accordance with the requirements of Rules of Practice and Procedure, 18 CFR 385.210, .211, .214, respectively. In determining the appropriate action to take, the Commission will consider all protests or other comments filed, but only those who file a motion to intervene in accordance with the Commission's Rules may become a party to the proceeding. Any comments, protests, or motions to intervene must be received on or before the specified comment date for the particular application.

o. *Filing and Service of Documents*: Any filing must (1) bear in all capital letters the title "COMMENTS", "PROTEST", or "MOTION TO INTERVENE" as applicable; (2) set forth in the heading the name of the applicant and the project number of the application to which the filing responds; (3) furnish the name, address, and telephone number of the person commenting, protesting or intervening; and (4) otherwise comply with the requirements of 18 CFR 385.2001 through 385.2005. All comments, motions to intervene, or protests must set forth their evidentiary basis. Any filing made by an intervenor must be accompanied by proof of service on all persons listed in the service list prepared by the Commission in this proceeding, in accordance with 18 CFR 385.2010.

Dated: March 8, 2022.

Kimberly D. Bose,
Secretary.

[FR Doc. 2022-05317 Filed 3-11-22; 8:45 am]

BILLING CODE 6717-01-P

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

Combined Notice of Filings

Take notice that the Commission has received the following Natural Gas Pipeline Rate and Refund Report filings:

Filings Instituting Proceedings

Docket Numbers: RP22-679-000.

Applicants: Discovery Gas

Transmission LLC.

Description: § 4(d) Rate Filing: Discovery Gas Transmission LLC Housekeeping Tariff Filing to be effective 4/8/2022.

Filed Date: 3/8/22.

Accession Number: 20220308-5007.

Comment Date: 5 p.m. ET 3/21/22.

Any person desiring to protest in any the above proceedings must file in accordance with Rule 211 of the Commission's Regulations (18 CFR 385.211) on or before 5:00 p.m. Eastern time on the specified comment date.

The filings are accessible in the Commission's eLibrary system (<https://elibrary.ferc.gov/idmws/search/fercgensearch.asp>) by querying the docket number.

eFiling is encouraged. More detailed information relating to filing requirements, interventions, protests, service, and qualifying facilities filings can be found at: <http://www.ferc.gov/docs-filing/efiling/filing-req.pdf>. For other information, call (866) 208-3676 (toll free). For TTY, call (202) 502-8659.

Dated: March 8, 2022.

Debbie-Anne A. Reese,
Deputy Secretary.

[FR Doc. 2022-05328 Filed 3-11-22; 8:45 am]

BILLING CODE 6717-01-P

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

[Project No. 2514-209]

Appalachian Power Company; Notice of Application Tendered for Filing With the Commission and Establishing Procedural Schedule for Licensing and Deadline for Submission of Final Amendments

Take notice that the following hydroelectric application has been filed with the Commission and is available for public inspection.

a. *Type of Application*: New Major License.

b. *Project No.*: 2514-209.

c. *Date Filed*: February 28, 2022.

d. *Applicant*: Appalachian Power Company (Appalachian).

e. *Name of Project*: Byllesby-Buck Hydroelectric Project (Byllesby-Buck Project).

f. *Location*: The two-development Byllesby-Buck Project is located on the New River in Carroll County, Virginia. The project occupies 7.23 acres of federal land managed by the U.S. Forest Service.

g. *Filed Pursuant to*: Federal Power Act, 16 U.S.C. 791(a)-825(r).

h. *Applicant Contact*: Elizabeth Parcell, Process Supervisor, American Electric Power Service Corporation, 40 Franklin Road SW, Roanoke, VA 24011; Phone at (540) 985-2441 or email at ebparcell@aep.com.

i. *FERC Contact*: Jody Callihan at (202) 502-8278, or jody.callihan@ferc.gov.

j. This application is not ready for environmental analysis at this time.

k. The Byllesby-Buck Project consists of two developments (Byllesby and Buck); the Byllesby Development is located 3 river miles upstream of the Buck Development. The current license authorizes a combined generating capacity of 30.1 megawatts (MW); however, the actual installed capacity is 26.1 MW, which Appalachian proposes to increase to 29.8 MW, as described below.

Between 2016 and 2020, the project had an average annual generation of 92,820 megawatt-hours (MWh).

The Byllesby Development consists of: (1) A 64-foot-high, 528-foot-long concrete dam, sluice gate, and main spillway section topped with four sections of 9-foot-high flashboards, five sections of 9-foot-high inflatable Obermeyer crest gates, and six bays of 10-foot-high Tainter gates; (2) an auxiliary spillway including six sections of 9-foot-high flashboards; (3) a 239-acre impoundment with a gross storage capacity of 2,000 acre-feet; (4) a powerhouse containing four turbine-generator units with a total installed capacity of 18.0 MW; (5) a control house and switchyard; and (6) appurtenant facilities.

The Buck Development consists of: (1) A 42-foot-high, 353-foot-long concrete dam and sluice gate; (2) a 1,005-foot-long, 19-foot-high spillway section topped with twenty sections of 9-foot-high flashboards, four sections of 9-foot-high inflatable crest gates, and six bays of 10-foot-high Tainter gates; (3) a 66-acre impoundment with a gross storage capacity of 661 acre-feet; (4) a powerhouse containing three turbine-generator units with a total installed capacity of 8.1 MW; (5) two 2-mile-long overhead 13.2-kilovolt transmission lines extending from the Buck powerhouse to the Byllesby control house; and (6) appurtenant facilities.

The Byllesby-Buck Project is currently operated in a run-of-river (ROR) mode, with the Byllesby impoundment maintained between elevations of 2,078.2 feet and 2,079.2 feet National Geodetic Vertical Datum of 1929 (NGVD 29) and the Buck impoundment maintained between elevations of