

Rules and Regulations

Federal Register
Vol. 80, No. 43
Thursday, March 5, 2015

This section of the FEDERAL REGISTER contains regulatory documents having general applicability and legal effect, most of which are keyed to and codified in the Code of Federal Regulations, which is published under 50 titles pursuant to 44 U.S.C. 1510.

The Code of Federal Regulations is sold by the Superintendent of Documents. Prices of new books are listed in the first FEDERAL REGISTER issue of each week.

DEPARTMENT OF ENERGY

10 CFR Part 431

[Docket No. EERE-2011-BT-STD-0029]

RIN 1904-AC47

Energy Conservation Program for Certain Industrial Equipment: Energy Conservation Standards and Test Procedures for Commercial Heating, Air-Conditioning, and Water-Heating Equipment; Correction

AGENCY: Office of Energy Efficiency and Renewable Energy, Department of Energy.

ACTION: Final rule; technical correction.

SUMMARY: On May 16, 2012, the U.S. Department of Energy (DOE) published a final rule in the Federal Register that amended the energy conservation standards and test procedures for certain commercial heating, air-conditioning, and water-heating equipment. Due to a drafting error, there was a typographical error (i.e., an incorrect symbol) for one equipment class of computer room air conditioners in a table to the applicable test procedure provision. This final rule rectifies this error.

DATES: Effective: March 5, 2015. The incorporation by reference of certain publications listed in the rule was approved by the Director of the Federal Register as of July 16, 2012.

FOR FURTHER INFORMATION CONTACT: Ms. Ashley Armstrong, U.S. Department of Energy, Office of Energy Efficiency and Renewable Energy, Building Technologies Office, Mailstop EE-5B, 1000 Independence Avenue SW., Washington, DC 20585-0121. Telephone: (202) 586-6590. Email: Ashley.Armstrong@ee.doe.gov.

Mr. Eric Stas, U.S. Department of Energy, Office of the General Counsel, GC-33, 1000 Independence Avenue SW., Washington, DC 20585-0121. Telephone: (202) 586-9507. Email: Eric.Stas@hq.doe.gov.

SUPPLEMENTARY INFORMATION:

I. Background

On May 16, 2012, DOE's Office of Energy Efficiency and Renewable Energy published an energy conservation standards and test procedure final rule in the Federal Register titled, "Energy Conservation Standards and Test Procedures for Commercial Heating, Air-Conditioning, and Water-Heating Equipment" (hereafter referred to as the "May 2012 final rule"). 77 FR 28928. Since the publication of that final rule, it has come to DOE's attention that, due to a technical oversight, the May 2012 final rule incorrectly included a typographical error regarding the symbol for one equipment class of the subject computer room air conditioners, which made it appear that there was more than one entry for that equipment class in the table showing the compliance date for use of the applicable test procedure. This final rule corrects this error, thereby eliminating the duplicative listing.

II. Need for Correction

As published, the May 2012 final rule mischaracterizes one computer room air conditioner equipment class in the table showing the compliance date for use of the applicable test procedure. In the May 2012 final rule, Table 2 on page 28990 contains a typographical error in the third column ("Cooling capacity") for the equipment type, Computer Room Air Conditioners. The entry for the second line, "<65,000 Btu/h and <760,000 Btu/h," should be corrected to read ">=65,000 Btu/h and <760,000 Btu/h." At no place in the May 2012 final rule did DOE discuss any intention to have two separate entries for computer room air conditioners <65,000 Btu/h in the test procedure, and DOE notes that this was a typographical error in the final rule as published in the Federal Register. Thus, the table has been corrected to eliminate this error. Accordingly, DOE finds that there is

good cause under 5 U.S.C. 553(b)(B) to not issue a separate notice to solicit public comment on the changes contained in this document. Issuing a separate document to solicit public comment would be impractical, unnecessary, and contrary to the public interest.

III. Procedural Requirements

DOE has concluded that the determinations made pursuant to the various procedural requirements applicable to the May 16, 2012 energy conservation standards and test procedure final rule for certain commercial heating, air-conditioning, and water-heating equipment remain unchanged for this final rule technical correction. These determinations are set forth in the May 16, 2012 final rule. 77 FR 28928, 28983-86.

List of Subjects in 10 CFR Part 431

Administrative practice and procedure, Confidential business information, Incorporation by reference, Energy conservation, Reporting and recordkeeping requirements.

Issued in Washington, DC on February 26, 2015.

Kathleen B. Hogan,
Deputy Assistant Secretary for Energy Efficiency, Energy Efficiency and Renewable Energy.

For the reasons set forth in the preamble, DOE amends part 431 of Chapter II, Subchapter D, of Title 10 of the Code of Federal Regulations as set forth below:

PART 431—ENERGY EFFICIENCY PROGRAM FOR CERTAIN COMMERCIAL AND INDUSTRIAL EQUIPMENT

■ 1. The authority citation for part 431 continues to read as follows:

Authority: 42 U.S.C. 6291-6317.

■ 2. Revise Table 2 in § 431.96(b)(2) to read as follows:

§ 431.96 Uniform test method for the measurement of energy efficiency of commercial air conditioners and heat pumps.

* * * * *
(b) * * *
(2) * * *

TABLE 2 TO § 431.96—TEST PROCEDURES FOR COMMERCIAL AIR CONDITIONERS AND HEAT PUMPS

Equipment type	Category	Cooling capacity	Energy efficiency descriptor	Compliance with test procedure required on or after	Use tests, conditions, and procedures ¹ in
Small Commercial Packaged Air-Conditioning and Heating Equipment.	Air-Cooled, 3-Phase, AC and HP.	<65,000 Btu/h	SEER and HSPF	May 13, 2013	AHRI 210/240–2008 (omit section 6.5).
	Air-Cooled AC and HP	≥65,000 Btu/h and <135,000 Btu/h	EER and COP	May 13, 2013	AHRI 340/360–2007 (omit section 6.3).
	Water-Cooled and Evaporatively-Cooled AC.	<65,000 Btu/h	EER	May 13, 2013	AHRI 210/240–2008 (omit section 6.5).
	Water-Source HP	≥65,000 Btu/h and <135,000 Btu/h	EER	May 13, 2013	AHRI 340/360–2007 (omit section 6.3).
Large Commercial Packaged Air-Conditioning and Heating Equipment.	Air-Cooled AC and HP	<135,000 Btu/h	EER and COP	May 13, 2013	ISO Standard 13256–1 (1998).
	Air-Cooled AC and HP	≥135,000 Btu/h and <240,000 Btu/h	EER and COP	May 13, 2013	AHRI 340/360–2007 (omit section 6.3).
Very Large Commercial Packaged Air-Conditioning and Heating Equipment.	Water-Cooled and Evaporatively-Cooled AC.	≥135,000 Btu/h and <240,000 Btu/h	EER	May 13, 2013	AHRI 340/360–2007 (omit section 6.3).
	Air-Cooled AC and HP	≥240,000 Btu/h and <760,000 Btu/h	EER and COP	May 13, 2013	AHRI 340/360–2007 (omit section 6.3).
	Water-Cooled and Evaporatively-Cooled AC.	≥240,000 Btu/h and <760,000 Btu/h	EER	May 13, 2013	AHRI 340/360–2007 (omit section 6.3).
	AC and HP	<760,000 Btu/h	EER and COP	May 13, 2013	AHRI 310/380–2004 (omit section 5.6).
Packaged Terminal Air Conditioners and Heat Pumps.	AC	<65,000 Btu/h	SCOP	October 29, 2012	ASHRAE 127–2007 (omit section 5.11).
Computer Room Air Conditioners	AC	≥65,000 Btu/h and <760,000 Btu/h	SCOP	May 13, 2013	ASHRAE 127–2007 (omit section 5.11).
Variable Refrigerant Flow Multi-split Systems.	AC	<760,000 Btu/h	EER and COP	May 13, 2013	AHRI 1230–2010 (omit sections 5.1.2 and 6.6).
	HP	<760,000 Btu/h	EER and COP	May 13, 2013	AHRI 1230–2010 (omit sections 5.1.2 and 6.6).
	HP	<17,000 Btu/h	EER and COP	October 29, 2012	AHRI 1230–2010 (omit sections 5.1.2 and 6.6).
	HP	≥17,000 Btu/h and <760,000 Btu/h	EER and COP	May 13, 2013	AHRI 1230–2010 (omit sections 5.1.2 and 6.6).
Single Package Vertical Air Conditioners and Single Package Vertical Heat Pumps.	AC and HP	<760,000 Btu/h	EER and COP	July 16, 2012	AHRI 390–2003 (omit section 6.4).

¹ Incorporated by reference, see § 431.95.

* * * * *

[FR Doc. 2015-05061 Filed 3-4-15; 08:45 am]

BILLING CODE 6450-01-P

DEPARTMENT OF TRANSPORTATION**Federal Aviation Administration****14 CFR Part 25****[Docket No. FAA-2014-0383; Special Conditions No. 25-578-SC]****Special Conditions: Bombardier Aerospace, Models BD-500-1A10 and BD-500-1A11 Series Airplanes; Alternate Fuel Tank Structural Lightning Protection Requirements****AGENCY:** Federal Aviation Administration (FAA), DOT.**ACTION:** Final special conditions.

SUMMARY: These special conditions are issued for the Bombardier Aerospace Models BD-500-1A10 and BD-500-1A11 series airplanes. These airplanes will have a novel or unusual design feature when compared to the state of technology envisioned in the airworthiness standards for transport category airplanes. This design feature is a nitrogen generation system (NGS) for all fuel tanks that actively reduces flammability exposure within the fuel tanks significantly below that required by the fuel tank flammability regulations. Among other benefits, the NGS significantly reduces the potential for fuel vapor ignition caused by lightning strikes. The applicable airworthiness regulations do not contain adequate or appropriate safety standards for this design feature. These special conditions contain the additional safety standards that the Administrator considers necessary to establish a level of safety equivalent to that established by the existing airworthiness standards.

DATES: This action is effective on Bombardier Aerospace on April 6, 2015.

FOR FURTHER INFORMATION CONTACT:

Margaret Langsted, FAA, Propulsion and Mechanical Systems Branch, ANM-112, Transport Airplane Directorate, Aircraft Certification Service, 1601 Lind Avenue SW., Renton, Washington, 98057-3356; telephone 425-227-2677; facsimile 425-227-1149.

SUPPLEMENTARY INFORMATION:**Background**

On December 10, 2009, Bombardier Aerospace applied for a type certificate for their new Models BD-500-1A10 and BD-500-1A11 series airplanes (hereafter collectively referred to as "C-Series"). The C-Series airplanes are swept-wing

monoplanes with a composite wing fuel tank structure and an aluminum alloy fuselage that is sized for 5-abreast seating. Passenger capacity is designated as 110 for the Model BD-500-1A10 and 125 for the Model BD-500-1A11. Maximum takeoff weight is 131,000 pounds for the Model BD-500-1A10 and 144,000 pounds for the Model BD-500-1A11.

Type Certification Basis

Under the provisions of Title 14, Code of Federal Regulations (14 CFR) 21.17, Bombardier Aerospace must show that the C-Series airplanes meet the applicable provisions of part 25 as amended by Amendments 25-1 through 25-129.

If the Administrator finds that the applicable airworthiness regulations (*i.e.*, 14 CFR part 25) do not contain adequate or appropriate safety standards for the C-Series airplanes because of a novel or unusual design feature, special conditions are prescribed under the provisions of § 21.16.

Special conditions are initially applicable to the model for which they are issued. Should the type certificate for that model be amended later to include any other model that incorporates the same or similar novel or unusual design feature, the special conditions would also apply to the other model under § 21.101.

In addition to the applicable airworthiness regulations and special conditions, the C-Series airplanes must comply with the fuel vent and exhaust emission requirements of 14 CFR part 34 and the noise certification requirements of 14 CFR part 36, and the FAA must issue a finding of regulatory adequacy under § 611 of Public Law 92-574, the "Noise Control Act of 1972."

The FAA issues special conditions, as defined in 14 CFR 11.19, in accordance with § 11.38, and they become part of the type certification basis under § 21.17.

Novel or Unusual Design Features

The C-Series airplanes will incorporate the following novel or unusual design feature: A fuel tank nitrogen generation system (NGS) that is intended to control fuel tank flammability for all fuel tanks. This NGS is designed to provide a level of performance to all fuel tanks of the C-Series airplanes that applies the more stringent standard for warm day flammability performance applicable to normally emptied tanks within the fuselage contour from § 25.981(b) and appendix M to part 25. An NGS actively reduces flammability exposure within the fuel tanks significantly below that required by the fuel tank flammability

regulations. Among other benefits, the NGS significantly reduces the potential for fuel vapor ignition caused by lightning strikes. This high level of NGS performance for all fuel tanks is a novel or unusual design feature compared to the state of technology envisioned in the airworthiness standards for transport category airplanes.

Discussion

The certification basis of the C-Series airplanes includes § 25.981, as amended by Amendment 25-125, as required by 14 CFR 26.37. This amendment includes the ignition prevention requirements in § 25.981(a), as amended by Amendment 25-102, and it includes revised flammability limits for all fuel tanks and new specific limitations on flammability for all fuel tanks as defined in § 25.981(b), as amended by Amendment 25-125.

Ignition Source Prevention

Section 25.981(a)(3) requires applicants to show that an ignition source in the fuel tank system could not result from any single failure, from any single failure in combination with any latent failure condition not shown to be extremely remote, or from any combination of failures not shown to be extremely improbable. This requirement was originally adopted in Amendment 25-102, and it requires the assumption that the fuel tanks are always flammable when showing that the probability of an ignition source being present is extremely remote. (Amendment 25-102 included § 25.981(c) that required minimizing fuel tank flammability, and this was defined in the preamble as being equivalent to unheated aluminum fuel tanks located in the wing.) This requirement defines three types of scenarios that must be addressed in order to show compliance with § 25.981(a)(3). The first scenario is that any single failure, regardless of the probability of occurrence of the failure, must not cause an ignition source. The second scenario is that any single failure, regardless of the probability of occurrence, in combination with any latent failure condition not shown to be at least extremely remote, must not cause an ignition source. The third scenario is that any combination of failures not shown to be extremely improbable must not cause an ignition source. Demonstration of compliance with this requirement would typically require a structured, quantitative safety analysis. Design areas that have latent failure conditions typically would be driven by these requirements to have multiple fault tolerance, or "triple redundancy." This means that ignition