

RPV beltline region will not result in changes in operation or configuration of the facility. The change does not impose any new or different requirements or eliminate any existing requirements. The change is consistent with the current safety analysis assumptions and current plant operating practice. No new accident scenarios, transient precursors, failure mechanisms, or limiting single failures are introduced as a result of the proposed change. Equipment important to safety will continue to operate as designed. The change does not result in any event previously deemed incredible being more credible. The change does not result in any adverse conditions or result in any increase in the challenges to safety systems.

Therefore, this change does not create the possibility of a new or different kind of accident from an accident previously evaluated.

3. Does the proposed exemption involve a significant reduction in a margin of safety?

Response: No.

The proposed exemption does not alter safety limits, limiting safety system settings, or limiting conditions for operation. The setpoints at which protective actions are initiated are not altered by the change. There are no new or significant changes to initial conditions contributing to accident severity or consequences. The exemption will not otherwise affect plant protective boundaries, will not cause a release of fission products to the public, nor will it degrade the performance of any other structures, systems or components important to safety.

Therefore, the proposed exemption does not involve a significant reduction in a margin of safety.

Based on the above evaluation of the standards set forth in 10 CFR 50.92(c), the NRC concludes that the proposed exemption involves no significant hazards consideration. Accordingly, the requirements of 10 CFR 51.22(c)(9)(i) are met.

Requirements in 10 CFR 51.22(c)(9)(ii–iii)

The proposed exemption does not make any changes to the facility, equipment at the facility, or to fuel or core design. The proposed alternate methodology serves the same purpose as the requirements set forth in 10 CFR 50.61 and 10 CFR part 50, appendix G. Therefore, the NRC concludes that the exemption involves no significant change in the types or a significant increase in the amounts of any effluents that may be released offsite, and that

there is no significant increase in individual or cumulative public or occupational radiation exposure.

Therefore, the requirements of 10 CFR 51.22(c)(9)(ii–iii) are met.

#### Conclusion

Based on the above, the NRC concludes that the proposed exemption meets the eligibility criteria for the categorical exclusion set forth in 10 CFR 51.22(c)(9). Therefore, in accordance with 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the NRC's issuance of this exemption.

#### IV. Conclusions

Accordingly, the Commission has determined that, pursuant to 10 CFR 50.12(a), the exemption is authorized by law, will not present an undue risk to the public health and safety, and is consistent with the common defense and security. Also, special circumstances are present. Therefore, the Commission hereby grants the licensee an exemption from 10 CFR part 50, appendix G.II.D(i) and 10 CFR 50.61(a)(5) requirements, in order to use the alternate methodology specified in AREVA TR BAW-2308, Revisions 1–A and 2–A, in lieu of the existing requirement to use  $C_v$  and drop weight-based methodologies to evaluate the initial (unirradiated)  $RT_{NDT}$  of the Linde 80 weld materials in the RPV beltline region at ANO, Unit 1.

This exemption is effective upon issuance.

Dated at Rockville, Maryland, this 16th day of March 2015.

For The Nuclear Regulatory Commission.

**Michele G. Evans,**

*Director, Division of Operating Reactor Licensing, Office of Nuclear Reactor Regulation.*

[FR Doc. 2015–06700 Filed 3–23–15; 8:45 am]

**BILLING CODE 7590–01–P**

#### NUCLEAR REGULATORY COMMISSION

[Docket No. 50–305; NRC–2015–0068]

#### Dominion Energy Kewaunee, Inc.; Kewaunee Power Station

**AGENCY:** Nuclear Regulatory Commission.

**ACTION:** Exemption; issuance.

**SUMMARY:** The U.S. Nuclear Regulatory Commission (NRC) is issuing an exemption from certain power reactor liability insurance requirements in response to a request from Dominion Energy Kewaunee, Inc. (DEK or the

licensee) dated March 20, 2014. This exemption would permit the licensee to reduce its primary offsite liability insurance and withdraw from participation in the secondary retrospective rating pool for deferred premium charges.

**DATES:** March 24, 2015.

**ADDRESSES:** Please refer to Docket ID NRC–2015–0068 when contacting the NRC about the availability of information regarding this document. You may obtain publicly-available information related to this document using any of the following methods:

- Federal Rulemaking Web site: Go to <http://www.regulations.gov> and search for Docket ID NRC–2015–0068. Address questions about NRC dockets to Carol Gallagher; telephone: 301–415–3463; email: [Carol.Gallagher@nrc.gov](mailto:Carol.Gallagher@nrc.gov). For technical questions, contact the individual listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- NRC's Agencywide Documents Access and Management System (ADAMS): You may obtain publicly-available documents online in the ADAMS Public Documents collection at <http://www.nrc.gov/reading-rm/adams.html>. To begin the search, select “ADAMS Public Documents” and then select “Begin Web-based ADAMS Search.” For problems with ADAMS, please contact the NRC's Public Document Room (PDR) reference staff at 1–800–397–4209, 301–415–4737, or by email to [pdr.resource@nrc.gov](mailto:pdr.resource@nrc.gov). The ADAMS accession number for each document referenced (if it available in ADAMS) is provided the first time that a document is referenced.

- NRC's PDR: You may examine and purchase copies of public documents at the NRC's PDR, Room O1–F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

**FOR FURTHER INFORMATION CONTACT:** William Huffman, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, DC 20555–0001; telephone: 301–415–2046; email: [William.Huffman@nrc.gov](mailto:William.Huffman@nrc.gov).

#### SUPPLEMENTARY INFORMATION:

##### I. Background

The Kewaunee Power Station (KPS) facility is a decommissioning power reactor located on approximately 900 acres in Carlton (Kewaunee County), Wisconsin, 27 miles southeast of Green Bay, Wisconsin. The licensee, DEK, is the holder of the KPS Renewed Facility Operating License No. DPR–43. The license provides, among other things, that the facility is subject to all rules,

regulations, and orders of the NRC now or hereafter in effect.

By letter dated February 25, 2013 (ADAMS Accession No. ML13058A065), DEK submitted a certification to the NRC indicating it would permanently cease power operations at KPS on May 7, 2013. On May 7, 2013, DEK permanently shut down the KPS reactor. On May 14, 2013, DEK certified that it had permanently defueled the KPS reactor vessel (ADAMS Accession No. ML13135A209). As a permanently shutdown and defueled facility, and in accordance with § 50.82(a)(2) of Title 10 of the *Code of Federal Regulations* (10 CFR), KPS is no longer authorized to operate the reactor or emplace nuclear fuel into the reactor vessel. The licensee is still authorized to possess and store irradiated nuclear fuel. Irradiated fuel is currently being stored onsite in a spent fuel pool (SFP) and in independent spent fuel storage installation dry casks.

## II. Request/Action

Pursuant to 10 CFR 140.8, “Specific exemptions,” DEK has requested an exemption from 10 CFR 140.11(a)(4), by letter dated March 20, 2014 (ADAMS Accession No. ML14090A112). The exemption from 10 CFR 140.11(a)(4) would permit the licensee to reduce the required level of primary offsite liability insurance from \$375 million to \$100 million, and would allow DEK to withdraw from participation in the secondary financial protection (also known as the secondary retrospective rating pool for deferred premium charges).

The regulation in 10 CFR 140.11(a)(4) requires each licensee to have and maintain financial protection. For a single unit reactor site, which has a rated capacity of 100,000 kilowatts electric or more, 10 CFR 140.11(a)(4) requires the licensee to maintain \$375 million in primary financial protection. In addition, the licensee is required to participate in a secondary retrospective rating pool (secondary financial protection) that commits each licensee to additional indemnification for damages that may exceed primary insurance coverage. Participation in the secondary retrospective rating pool could potentially subject DEK to deferred premium charges up to a maximum total deferred premium of \$121,255,000 with respect to any nuclear incident at any operating nuclear power plant, and up to a maximum annual deferred premium of \$18,963,000 per incident.

The licensee states that the risk of an offsite radiological release is significantly lower at a nuclear power reactor that has permanently shut down

and defueled, when compared to an operating power reactor. Similarly, the associated risk of offsite liability damages that require insurance indemnification is commensurately lower. Therefore, DEK is requesting an exemption from 10 CFR 140.11(a)(4), to permit a reduction in primary offsite liability insurance and to withdraw from participation in the secondary financial protection pool.

## III. Discussion

Pursuant to 10 CFR 140.8, the Commission may, upon application by any interested person or upon its own initiative, grant exemptions from the requirements of 10 CFR part 140, when the exemptions are authorized by law and are otherwise in the public interest.

The financial protection limits of 10 CFR 140.11(a)(4) were established to require a licensee to maintain sufficient insurance to satisfy liability claims by members of the public for personal injury, property damage, or the legal cost associated with lawsuits, as the result of a nuclear accident. The insurance levels established by this regulation were derived from the risks and potential consequences of an accident at an operating reactor with a rated capacity of 100,000 kilowatts electric (or greater). During normal power reactor operations, the forced flow of water through the reactor coolant system (RCS) removes heat generated by the reactor. The RCS, operating at high temperatures and pressures, transfers this heat through the steam generator tubes converting non-radioactive feedwater to steam, which then flows to the main turbine generator to produce electricity. Many of the accident scenarios postulated for operating power reactors involve failures or malfunctions of systems that could affect the fuel in the reactor core, which in the most severe postulated accidents, would involve the release of large quantities of fission products. With the permanent cessation of reactor operations at KPS and the permanent removal of the fuel from the reactor core, such accidents are no longer possible. The reactor, RCS, and supporting systems no longer operate and have no function related to the storage of the irradiated fuel. Therefore, postulated accidents involving failure or malfunction of the reactor, RCS, or supporting systems are no longer applicable.

During reactor decommissioning, the principal radiological risks are associated with the storage of spent fuel onsite. In its March 20, 2014, exemption request, DEK discusses both design-basis and beyond design-basis events

involving irradiated fuel stored in the SFP. The licensee states that there are no possible design-basis events at KPS that could result in an offsite radiological release exceeding the limits established by the U.S. Environmental Protection Agency’s early-phase Protective Action Guidelines of 1 rem (roentgen equivalent man) at the exclusion area boundary. The only accident that might lead to a significant radiological release at a decommissioning reactor is a zirconium fire. The zirconium fire scenario is a postulated, but highly unlikely, beyond design-basis accident scenario that involves loss of water inventory from the SFP, resulting in a significant heat-up of the spent fuel, and culminating in substantial zirconium cladding oxidation and fuel damage. The probability of a zirconium fire scenario is related to the decay heat of the irradiated fuel stored in the SFP. Therefore, the risks from a zirconium fire scenario continue to decrease as a function of the time that KPS has been permanently shut down.

The licensee provided a detailed analysis of the events that could result in an offsite radiological release at KPS in its January 16, 2014, submittal to the NRC (ADAMS Accession No. ML14029A076). One of these beyond design-basis accidents involves a complete loss of SFP water inventory, where cooling of the spent fuel would be primarily accomplished by natural circulation of air through the uncovered spent fuel assemblies. The licensee’s analysis of this accident shows that by October 30, 2014, air-cooling of the spent fuel assemblies will be sufficient to keep the fuel within a safe temperature range indefinitely without fuel damage or offsite radiological release. This is important because the Commission has previously authorized a lesser amount of liability insurance coverage, based on an analysis of the zirconium fire risk. In SECY-93-127, “Financial Protection Required of Licensees of Large Nuclear Power Plants During Decommissioning,” dated May 10, 1993 (ADAMS Accession No. ML12257A628), the staff outlined a policy for reducing required liability insurance coverage for decommissioning reactors. The discussions in SECY-93-127 centered primarily on the public health and safety risks associated with storing fuel in spent fuel pools. In its Staff Requirements Memorandum dated July 13, 1993, the Commission approved a policy that would permit reductions in commercial liability insurance coverage, when a licensee was able to demonstrate

that the spent fuel could be air-cooled if the SFP was drained of water. Upon demonstration of this technical criterion, the Commission policy allowed decommissioning licensees to withdraw from participation in the secondary insurance protection layer, and permitted reductions in the required amount of commercial liability insurance coverage to \$100 million. The staff has used this technical criterion to grant similar exemptions to other decommissioning reactor licensees (*e.g.*, Maine Yankee Atomic Power Station, published in the **Federal Register** on January 19, 1999 (64 FR 2920); and Zion Nuclear Power Station, published in the **Federal Register** on December 28, 1999 (64 FR 72700)). Additional discussions of other decommissioning reactor licensees that have received exemptions to reduce their primary insurance level to \$100 million is provided in SECY-96-256, "Changes to Financial Protection Requirements for Permanently Shutdown Nuclear Power Reactors, 10 CFR 50.54(w)(1) and 10 CFR 140.11," dated December 17, 1996 (ADAMS Accession No. ML15062A483). These prior exemptions were based on the licensee demonstrating that the SFP could be air-cooled, consistent with the technical criterion discussed above.

In SECY-00-0145, "Integrated Rulemaking Plan for Nuclear Power Plant Decommissioning," dated June 28, 2000, and SECY-01-0100, "Policy Issues Related to Safeguards, Insurance, and Emergency Preparedness Regulations at Decommissioning Nuclear Power Plants Storing Fuel in the Spent Fuel Pool," dated June 4, 2001 (ADAMS Accession Nos. ML003721626 and ML011450420, respectively), the staff discussed additional information concerning SFP zirconium fire risks at decommissioning reactors and associated implications for offsite insurance. Analyzing when the spent fuel stored in the SFP is capable of air-cooling is one measure that demonstrates when the probability of a zirconium fire would be exceedingly low. However, the staff has more recently used an additional analysis that would bound an incomplete drain down of the SFP water, or some other catastrophic event (such as a complete drainage of the SFP with rearrangement of spent fuel rack geometry and/or the addition of rubble to the SFP). The analysis postulates that decay heat transfer from the spent fuel via conduction, convection, or radiation would be impeded. This analysis is often referred to as an adiabatic heat-up.

The licensee's analyses referenced in its exemption request demonstrates that under conditions where the SFP water

inventory has drained and only air-cooling of the stored irradiated fuel is available, there is reasonable assurance that after October 2014, the KPS spent fuel will remain at temperatures far below those associated with a significant radiological release. In addition, the licensee's adiabatic heat-up analyses demonstrate that as of October 21, 2014, there would be at least 10 hours after the loss of all means of cooling (both air and/or water), before the spent fuel cladding would reach a temperature where the potential for a significant offsite radiological release could occur. The licensee states that for this loss of all cooling scenario, 10 hours is sufficient time for personnel to respond with additional resources, equipment, and capability to restore cooling to the SFP, even after a non-credible, catastrophic event. As provided in DEK's letter dated January 10, 2014 (ADAMS Accession No. ML14016A078), the licensee furnished information concerning its makeup strategies, in the event of a loss of SFP coolant inventory. The multiple strategies for providing makeup to the SFP include: Using existing plant systems for inventory makeup; supplying water through hoses to a spool piece connection to the existing SFP piping; or using a diesel-driven portable pump to take suction from Lake Michigan and provide makeup or spray to the SFP. These strategies will be maintained by a license condition. The licensee states that the equipment needed to perform these actions are located onsite, and that the external makeup strategy (using a diesel driven portable pump) is capable of being deployed within 2 hours. The licensee also stated that, considering the very low-probability of beyond design-basis accidents affecting the SFP, these diverse strategies provide defense-in-depth and time to mitigate and prevent a zirconium fire, using makeup or spray into the SFP before the onset of zirconium cladding rapid oxidation.

In the safety evaluation of the licensee's request for exemptions from certain emergency planning requirements dated October 27, 2014 (ADAMS Accession No. ML14261A223), the NRC staff assessed the DEK accident analyses associated with the radiological risks from a zirconium fire at the permanently shutdown and defueled KPS site. The NRC staff has confirmed that under conditions where cooling air flow can develop, suitably conservative calculations indicate that by the end of October 2014, the fuel would remain at temperatures where the cladding would be undamaged for an

unlimited period. For the very unlikely beyond design-basis accident scenario, where the SFP coolant inventory is lost in such a manner that all methods of heat removal from the spent fuel are no longer available, there will be a minimum of 10 hours from the initiation of the accident until the cladding reaches a temperature where offsite radiological release might occur. The staff finds that 10 hours is sufficient time to support deployment of mitigation equipment, consistent with plant conditions, to prevent the zirconium cladding from reaching a point of rapid oxidation.

The NRC staff has determined that the licensee's proposed reduction in primary offsite liability coverage to a level of \$100 million, and the licensee's proposed withdrawal from participation in the secondary insurance pool for offsite financial protection, are consistent with the policy established in SECY-93-127 and subsequent insurance considerations, resulting from additional zirconium fire risks, as discussed in SECY-00-0145 and SECY-01-0100. In addition, the NRC staff noted that there is a well-established precedent of granting a similar exemption to other permanently shutdown and defueled power reactors, upon demonstration that the criterion of the zirconium fire risks from the irradiated fuel stored in the SFP is of negligible concern.

#### *A. Authorized by Law*

In accordance with 10 CFR 140.8, the Commission may grant exemptions from the regulations in 10 CFR part 140, as the Commission determines are authorized by law. The NRC staff has determined that granting of the licensee's proposed exemption will not result in a violation of the Atomic Energy Act of 1954, Section 170, or other laws, as amended, which require licensees to maintain adequate financial protection. Therefore, the exemption is authorized by law.

#### *B. Is Otherwise in the Public Interest*

The financial protection limits of 10 CFR 140.11 were established to require licensees to maintain sufficient offsite liability insurance to ensure adequate funding for offsite liability claims, following an accident at an operating reactor. However, the regulation does not consider the reduced potential for and consequence of nuclear incidents at permanently shutdown and decommissioning reactors.

SECY-93-127, SECY-00-0145, and SECY-01-0100 provide a basis for allowing licensees of decommissioning plants to reduce their primary offsite

liability insurance and to withdraw from participation in the retrospective rating pool for deferred premium charges. As discussed in these documents, once the zirconium fire concern is determined to be negligible, possible accident scenario risks at permanently shutdown and defueled reactors are greatly reduced, when compared to operating reactors, and the associated potential for offsite financial liabilities from an accident are commensurately less. The licensee has analyzed and the staff has confirmed that the possible accidents that could result in an offsite radiological risk are minimal, thereby justifying the proposed reductions in offsite liability insurance and withdrawal from participation in the secondary retrospective rating pool for deferred premium charges.

Additionally, participation in the secondary retrospective rating pool could be problematic for DEK because the licensee would incur financial liability, if an extraordinary nuclear incident occurred at another nuclear power plant. Because KPS is permanently shut down, it does not produce revenue from electricity generation sales to cover such a liability. Therefore, such liability, if incurred, could significantly affect the financial resources available to the facility to conduct and complete radiological decontamination and decommissioning activities. Furthermore, the shared financial risk exposure to DEK is greatly disproportionate to the radiological risk posed by KPS, when compared to operating reactors.

The reduced overall risk to the public at decommissioning power plants does not warrant DEK to carry full operating reactor insurance coverage, after the requisite spent fuel cooling period has elapsed, following final reactor shutdown. The licensee's proposed financial protection limits will maintain a level of liability insurance coverage commensurate with the risk to the public. These changes are consistent with previous NRC policy and exemptions approved for other decommissioning reactors. Thus, the underlying purpose of the regulations will not be adversely affected by the reductions in insurance coverage.

Accordingly, the NRC staff concludes that granting the exemption from 10 CFR 140.11(a)(4) is in the public interest.

#### *C. Environmental Considerations*

The NRC approval of the exemption to insurance or indemnity requirements belongs to a category of actions that the Commission, by rule or regulation, has

declared to be a categorical exclusion, after first finding that the category of actions does not individually or cumulatively have a significant effect on the human environment. Specifically, the exemption is categorically excluded from further analysis in accordance with 10 CFR 51.22(c)(25).

Under 10 CFR 51.22(c)(25), granting of an exemption from the requirements of any regulation of Chapter I to 10 CFR is a categorical exclusion provided that (i) there is no significant hazards consideration; (ii) there is no significant change in the types or significant increase in the amounts of any effluents that may be released offsite; (iii) there is no significant increase in individual or cumulative public or occupational radiation exposure; (iv) there is no significant construction impact; (v) there is no significant increase in the potential for or consequences from radiological accidents; and (vi) the requirements from which an exemption is sought involve: surety, insurance, or indemnity requirements.

The Director, Division of Operating Reactor Licensing, Office of Nuclear Reactor Regulation, has determined that approval of the exemption request involves no significant hazards consideration because reducing a licensee's offsite liability requirements at KPS does not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. The exempted financial protection regulation is unrelated to the operation of KPS. Accordingly, there is no significant change in the types or significant increase in the amounts of any effluents that may be released offsite, and no significant increase in individual or cumulative public or occupational radiation exposure. The exempted regulation is not associated with construction, so there is no significant construction impact. The exempted regulation does not concern the source term (*i.e.*, potential amount of radiation in an accident), nor mitigation. Therefore, there is no significant increase in the potential for, or consequences of, a radiological accident. In addition, there would be no significant impacts to biota, water resources, historic properties, cultural resources, or socioeconomic conditions in the region. The requirement for offsite liability insurance may be viewed as involving surety, insurance, or indemnity matters.

Therefore, pursuant to 10 CFR 51.22(b) and 51.22(c)(25), no environmental impact statement or environmental assessment need be prepared in connection with the approval of this exemption request.

#### **IV. Conclusions**

Accordingly, the Commission has determined that, pursuant to 10 CFR 140.8, the exemption is authorized by law, and is otherwise in the public interest. Therefore, the Commission hereby grants DEK exemption from the requirement of 10 CFR 140.11(a)(4) to permit the licensee to reduce primary offsite liability insurance to \$100 million, accompanied by withdrawal from participation in the secondary insurance pool for offsite liability insurance.

The exemption is effective upon issuance.

Dated at Rockville, Maryland, this 13th day of March, 2015.

For the Nuclear Regulatory Commission.

**Michele G. Evans,**

*Director, Division of Operating Reactor Licensing, Office of Nuclear Reactor Regulation.*

[FR Doc. 2015-06730 Filed 3-23-15; 8:45 am]

**BILLING CODE 7590-01-P**

#### **OFFICE OF NATIONAL DRUG CONTROL POLICY**

##### **Paperwork Reduction Act; Proposed Collection; Comment Request**

**AGENCY:** Office of National Drug Control Policy.

**ACTION:** Notice of Submission to OMB and 30-Day Public Comment Period. Reinstatement with Change of Previously Approved Collection: Drug-Free Communities Support Program National Evaluation.

**SUMMARY:** In accordance with the Paperwork Reduction Act of 1995 (Pub. L. 104-13, 44 U.S.C. Chapter 35), the Office of National Drug Control Policy (ONDCP) announces it will submit to the Office of Management and Budget (OMB) Office of Information and Regulatory Affairs (OIRA) an information collection request for processing under 5 CFR 1320.10. The purpose of this notice is to allow for an additional 30 days of public comment.

**DATES:** Public comments will be accepted until April 23, 2015.

**ADDRESSES:** Interested persons are invited to submit comments regarding this proposal. Comments should refer to the collection title by name or OMB Control Number, and should be sent to: