

placed on the Commission's environmental mailing list, will receive copies of the environmental documents, and will be notified of meetings associated with the Commission's environmental review process. Environmental commentors will not be required to serve copies of filed documents on all other parties. However, the non-party commentors will not receive copies of all documents filed by other parties or issued by the Commission (except for the mailing of environmental documents issued by the Commission) and will not have the right to seek court review of the Commission's final order.

The Commission strongly encourages electronic filings of comments, protests and interventions in lieu of paper using the "eFiling" link at <http://www.ferc.gov>. Persons unable to file electronically should submit an original and 14 copies of the protest or intervention to the Federal Energy Regulatory Commission, 888 First Street, NE., Washington, DC 20426.

Comment Date: June 22, 2009.

Kimberly D. Bose,
Secretary.

[FR Doc. E9-13239 Filed 6-5-09; 8:45 am]
BILLING CODE 6717-01-P

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

[Project No. 13434-000]

Klamath Irrigation District; Notice of Preliminary Permit Application Accepted for Filing and Soliciting Comments, Motions To Intervene, and Competing Applications

June 1, 2009.

On April 23, 2009, Klamath Irrigation District filed an application for a preliminary permit, pursuant to section 4(f) of the Federal Power Act, proposing to study the feasibility of the C Drop Hydroelectric Project (project), to be located at the existing diversion structure of the former Enterprise Hydroelectric Plant in Klamath County, Oregon. The diversion structure of the Enterprise Plant, which burned and was taken out of service approximately 25 years ago, is located approximately 8 miles below the origin of the A canal on Upper Klamath Lake, a tributary of the Klamath River. The proposed project would utilize some of the facilities of the former Enterprise Plant, and construct new facilities where needed. The sole purpose of a preliminary permit, if issued, is to grant the permit

holder priority to file a license application during the permit term. A preliminary permit does not authorize the permit holder to perform any land disturbing activities or otherwise enter upon lands or waters owned by others without the owners' express permission.

The proposed project would consist of: (1) An existing 14-foot-wide intake structure/bridge on the C canal with upgrades to the rack and gate; (2) an existing forebay with modifications consisting of new gates, concrete floors, walls, support, and access platform to direct water flow to one of three places: (a) Through a 20-foot-wide turbine isolation roller gate into the powerhouse turbine and back into the C canal; (b) through a 10-foot-wide bypass roller gate; or (c) over any or all of the three 9-foot-wide automatic trip gates to the bypass; (3) an existing powerhouse with modifications including a new 20-foot-long, 30-foot-wide, 20-foot-high pre-manufactured metal building covering the powerhouse; (4) a vertical Kaplan turbine with a maximum hydraulic capacity of 550 cubic-foot-per-second; (5) a 900-kilowatt synchronous generator; (6) a 12.47-kilovolt, 150-foot-long transmission line; and (7) appurtenant facilities. The proposed C Drop project would have an average annual generation of 2,900 megawatt-hours.

Applicant Contact: Ted Sorenson, P.E., Sorenson Engineering, 5203 South 11th East, Idaho Falls, ID 83404; *phone:* (208) 522-8069.

FERC Contact: Gaylord Hoisington, (202) 502-6032.

Deadline for filing comments, motions to intervene, competing applications (without notices of intent), or notices of intent to file competing applications: 60 days from the issuance of this notice. Comments, motions to intervene, notices of intent, and competing applications may be filed electronically via the Internet. See 18 CFR 385.2001(a)(1)(iii) and the instructions on the Commission's Web site under the "e-Filing" link. If unable to be filed electronically, documents may be paper-filed. To paper-file, an original and eight copies should be mailed to: Kimberly D. Bose, Secretary, Federal Energy Regulatory Commission, 888 First Street, NE., Washington, DC 20426. For more information on how to submit these types of filings please go to the Commission's Web site located at <http://www.ferc.gov/filing-comments.asp>. More information about this project, including a copy of the application, can be viewed or printed on the "eLibrary" link of Commission's Web site at <http://www.ferc.gov/docs-filing/>

elibrary.asp. Enter the docket number (P-13434) in the docket number field to access the document. For assistance, call toll-free 1-866-208-3372.

Kimberly D. Bose,
Secretary.

[FR Doc. E9-13238 Filed 6-5-09; 8:45 am]
BILLING CODE 6717-01-P

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

[Project No. 13365-000]

City of Angoon; Notice of Preliminary Permit Application Accepted for Filing and Soliciting Comments, Motions To Intervene, and Competing Applications

June 1, 2009.

On February 5, 2009 and supplemented on May 14, 2009, the City of Angoon filed an application for a preliminary permit, pursuant to section 4(f) of the Federal Power Act, proposing to study the feasibility of the Scenery Lake Hydroelectric Project located on Scenery Lake and Scenery Creek, near the town of Petersburg, Alaska. The project would be located within the Tongass National Forest, with a portion of the transmission line crossing the state of Alaska and city of Petersburg's lands. The sole purpose of a preliminary permit, if issued, is to grant the permit holder priority to file a license application during the permit term. A preliminary permit does not authorize the permit holder to perform any land disturbing activities or otherwise enter upon lands or waters owned by others without the owners' express permission.

The proposed project would consist of: (1) A 120-foot-high concrete arch dam with spillway impounding Scenery Lake having a surface area of 520 to 820 acres and a storage capacity of 58,000 to 80,000 acre-feet; (2) a lake tap or siphon with fish screen; (3) a 13,000-foot-long by 8-foot-diameter power conduit; (4) a powerhouse containing two to four new generating units having an installed capacity of 40 megawatts; (5) a proposed 29-mile-long, 69- and 138-kilovolt transmission line; and (6) appurtenant facilities. The proposed Scenery Lake Project would have an average annual generation of 80 gigawatt-hours.

Applicant Contact: Albert Howard, Mayor, City of Angoon, P.O. Box 189, Angoon, AK 99820; *phone:* (907) 788-3653.

FERC Contact: Gina Krump, (202) 502-6704, gina.krump@ferc.gov.

Deadline for filing comments, motions to intervene, competing applications