

DEPARTMENT OF ENERGY**Federal Energy Regulatory Commission****[Project No. 14861–002]****FFP Project 101, LLC; Notice Soliciting Scoping Comments**

Take notice that the following hydroelectric application has been filed with the Commission and is available for public inspection.

a. *Type of Application:* Original Major License.

b. *Project No.:* 14861–002.

c. *Date Filed:* June 23, 2020.

d. *Submitted By:* Rye Development on behalf of FFP Project 101, LLC (FFP).

e. *Name of Project:* Goldendale Pumped Storage Project.

f. *Location:* Off-stream on the north side of the Columbia River at River Mile 215.6 in Klickitat County, Washington, with transmission facilities extending into Sherman County, Oregon. The project would be located approximately 8 miles southeast of the City of Goldendale, Washington. The project would occupy 18.1 acres of lands owned by the U.S. Army Corps of Engineers and administered by the Bonneville Power Administration.

g. *Filed Pursuant to:* Federal Power Act 16 U.S.C. 791 (a)–825(r).

h. *Applicant Contact:* Erik Steimle, Rye Development, 220 Northwest 8th Avenue Portland, Oregon 97209; (503) 998–0230; email—erik@ryedevelopment.com.

i. *FERC Contact:* Michael Tust at (202) 502–6522; or email at michael.tust@ferc.gov.

j. *Deadline for filing scoping comments:* December 28, 2020.

The Commission strongly encourages electronic filing. Please file scoping comments using the Commission's eFiling system at <https://ferconline.ferc.gov/FEROnline.aspx>. Commenters can submit brief comments up to 6,000 characters, without prior registration, using the eComment system at <https://ferconline.ferc.gov/QuickComment.aspx>. You must include your name and contact information at the end of your comments. For assistance, please contact FERC Online Support at FEROnlineSupport@ferc.gov, (866) 208–3676 (toll free), or (202) 502–8659 (TTY). In lieu of electronic filing, you may submit a paper copy. Submissions sent via the U.S. Postal Service must be addressed to: Kimberly D. Bose, Secretary, Federal Energy Regulatory Commission, 888 First Street NE, Room 1A, Washington, DC 20426. Submissions sent via any other carrier must be addressed to:

Kimberly D. Bose, Secretary, Federal Energy Regulatory Commission, 12225 Wilkins Avenue, Rockville, Maryland 20852. All filings must clearly identify the project name and docket number on the first page: Goldendale Pumped Storage Project (P–14861–002).

The Commission's Rules of Practice and Procedure require all interveners filing documents with the Commission to serve a copy of that document on each person on the official service list for the project. Further, if an intervenor files comments or documents with the Commission relating to the merits of an issue that may affect the responsibilities of a particular resource agency, they must also serve a copy of the document on that resource agency.

k. The application is not ready for environmental analysis at this time.

l. The project would include the following new facilities: (1) A 61-acre upper reservoir formed by a 175-foot-high, 8,000-foot-long rockfill embankment dam at an elevation of 2,950 feet mean sea level (MSL) with a vertical concrete intake-outlet structure; (2) a 63-acre lower reservoir formed by a 205-foot-high, 6,100-foot-long embankment at an elevation of 590 feet MSL with a horizontal concrete intake-outlet structure and vertical steel slide gates; (3) an underground conveyance tunnel system connecting the two reservoirs consisting of a 2,200-foot-long, 29-foot-diameter concrete-lined vertical shaft, a 3,300-foot-long, 29-foot-diameter concrete-lined high pressure tunnel, a 200-foot-long, 22-foot-diameter high pressure manifold tunnel, three 600-foot-long, 15-foot-diameter steel/concrete penstocks, three 200-foot-long, 20-foot-diameter steel-lined draft tube tunnels with bonneted slide gates, a 200-foot-long, 26-foot-diameter concrete-lined low-pressure tunnel, and a 3,200-foot-long, 30-foot-diameter concrete-lined tailrace tunnel; (4) an underground powerhouse located between the upper and lower reservoir in a 0.83-acre powerhouse cavern containing three, 400-megawatt (MW) Francis-type pump-turbine units for a total installed capacity of 1,200 MW; (5) a 0.48-acre underground transformer cavern adjacent to the powerhouse containing intermediate step-up transformers that will step up the voltage from 18 kilovolts (kV) to 115 kV; (6) two 30-foot-diameter tunnels for accessing the powerhouse and transformer caverns; (7) a 0.84-mile-long, 115-kV underground transmission line extending from the transformer gallery through the combined access/transmission tunnel to where it emerges aboveground near the west side of the lower reservoir and extending an

additional 0.27 miles to an outdoor 7.3-acre substation/switchyard where the voltage would be stepped up to 500 kV; (8) a 3.13-mile-long, 500-kV transmission line routed from the substation/switchyard south across the Columbia River and connecting to Bonneville Power Administration's existing John Day Substation; (9) a buried 30-inch-diameter water fill line leading from a shut-off and throttling valve within a non-project water supply vault owned by Klickitat Public Utility District (KPUD) to an outlet structure within the lower reservoir to convey water to fill the reservoirs; and (10) appurtenant facilities. The project would also include an existing 0.7-mile road for accessing the lower reservoir site and an existing 8.6-mile-long road for accessing the upper reservoir site both of which may be modified to provide access for construction vehicles.

The water supply used to initially fill the lower reservoir as well as to provide make-up water would be purchased from KPUD and would be obtained from KPUD's existing intake pond on the Columbia River. The project water fill line would connect to a new KPUD-owned flanged water supply service connection in a water supply vault located near the lower reservoir. Within the vault, and just downstream of the service connection, there would be a project shut-off and throttling valve to allow control of the initial fill and make-up water flow rate into the lower reservoir. The initial fill would require 7,640 acre-feet of water and would be completed in about six months at an average flow rate of approximately 21 cubic feet per second (maximum flow rate available is 35 cubic feet per second). It is estimated that the project would need 360 acre-feet of water each year to replenish water lost through evaporation.

m. In addition to publishing the full text of this document in the **Federal Register**, the Commission provides all interested persons an opportunity to view and/or print the contents via the internet through the Commission's Home Page (<http://www.ferc.gov>) using the "eLibrary" link. Enter the docket number excluding the last three digits in the docket number field to access the document. At this time, the Commission has suspended access to the Commission's Public Reference Room, due to the proclamation declaring a National Emergency concerning the Novel Coronavirus Disease (COVID–19), issued by the President on March 13, 2020. For assistance, contact FERC at FEROnlineSupport@ferc.gov or call toll-free, (866) 208–3676 or TTY, (202) 502–8659.

n. You may also register online at <https://ferconline.ferc.gov/ferconline.aspx> to be notified via email of new filings and issuances related to this or other pending projects. For assistance, contact FERC Online Support.

o. Scoping Process

Commission staff will prepare either an environmental assessment (EA) or an Environmental Impact Statement (EIS) that describes and evaluates the probable effects, if any, of the licensee's proposed action and alternatives. The EA or EIS will consider environmental impacts and reasonable alternatives to the proposed action. The Commission's scoping process will help determine the required level of analysis and satisfy the NEPA scoping requirements, irrespective of whether the Commission prepares an EA or an EIS. Due to restrictions on mass gatherings related to COVID-19, we do not intend to conduct a public scoping meeting and site visit in this case. Instead, we are soliciting written comments and suggestions on the preliminary list of issues and alternatives to be addressed in the NEPA document, as described in scoping document 1 (SD1), issued October 29, 2020.

Copies of the SD1 outlining the subject areas to be addressed in the NEPA document were distributed to the parties on the Commission's mailing list and the applicant's distribution list. Copies of SD1 may be viewed on the web at <http://www.ferc.gov> using the "eLibrary" link. Enter the docket number excluding the last three digits in the docket number field to access the document. For assistance, call 1-866-208-3676 or for TTY, (202) 502-8659.

Dated: October 29, 2020.

Nathaniel J. Davis, Sr.,

Deputy Secretary.

[FR Doc. 2020-24460 Filed 11-3-20; 8:45 am]

BILLING CODE 6717-01-P

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

[Docket No. CD21-2-2000]

Heart Mountain Irrigation District; Notice of Preliminary Determination of a Qualifying Conduit Hydropower Facility and Soliciting Comments and Motions To Intervene

On October 23, 2020, Heart Mountain Irrigation District filed a notice of intent

to construct a qualifying conduit hydropower facility, pursuant to section 30 of the Federal Power Act (FPA). The proposed Ralston Lateral Hydrokinetic Project would have an installed capacity of 10 kilowatts (kW), and would be located in an existing irrigation lateral in Powell, Park County, Wyoming.

Applicant Contact: Tyler Weckler, District Manager, 1206 Rd 18, Powell, Wyoming 82435, Phone No. (307) 754-4685, Email: hmid00@tritnet.net.

FERC Contact: Christopher Chaney, Phone No. (202) 502-6778, Email: christopher.chaney@ferc.gov.

Qualifying Conduit Hydropower Facility Description: The proposed project would consist of: (1) One 10-kW hydrokinetic module; and (2) appurtenant facilities. The proposed project would have an estimated annual generation of approximately 44 megawatt-hours.

A qualifying conduit hydropower facility is one that is determined or deemed to meet all the criteria shown in the table below.

TABLE 1—CRITERIA FOR QUALIFYING CONDUIT HYDROPOWER FACILITY

Statutory provision	Description	Satisfies (Y/N)
FPA 30(a)(3)(A)	The conduit the facility uses is a tunnel, canal, pipeline, aqueduct, flume, ditch, or similar man-made water conveyance that is operated for the distribution of water for agricultural, municipal, or industrial consumption and not primarily for the generation of electricity..	Y
FPA 30(a)(3)(C)(i)	The facility is constructed, operated, or maintained for the generation of electric power and uses for such generation only the hydroelectric potential of a non-federally owned conduit.	Y
FPA 30(a)(3)(C)(ii)	The facility has an installed capacity that does not exceed 40 megawatts	Y
FPA 30(a)(3)(C)(iii)	On or before August 9, 2013, the facility is not licensed, or exempted from the licensing requirements of Part I of the FPA.	Y

Preliminary Determination: The proposed Ralston Lateral Hydrokinetic Project will not alter the primary purpose of the conduit, which is used to distribute water for agricultural irrigation. Therefore, based upon the above criteria, Commission staff preliminarily determines that the proposal satisfies the requirements for a qualifying conduit hydropower facility, which is not required to be licensed or exempted from licensing.

Comments and Motions To Intervene: Deadline for filing comments contesting whether the facility meets the qualifying criteria is 30 days from the issuance date of this notice. Deadline for filing motions to intervene is 30 days from the issuance date of this notice. Anyone may submit comments or a motion to intervene in accordance with the requirements of Rules of Practice and

Procedure, 18 CFR 385.210 and 385.214. Any motions to intervene must be received on or before the specified deadline date for the particular proceeding.

Filing and Service of Responsive Documents: All filings must (1) bear in all capital letters the "COMMENTS CONTESTING QUALIFICATION FOR A CONDUIT HYDROPOWER FACILITY" or "MOTION TO INTERVENE," as applicable; (2) state in the heading the name of the applicant and the project number of the application to which the filing responds; (3) state the name, address, and telephone number of the person filing; and (4) otherwise comply with the requirements of sections 385.2001 through 385.2005 of the Commission's regulations.¹ All

¹ 18 CFR 385.2001-2005 (2020).

comments contesting Commission staff's preliminary determination that the facility meets the qualifying criteria must set forth their evidentiary basis.

The Commission strongly encourages electronic filing. Please file motions to intervene and comments using the Commission's eFiling system at <http://www.ferc.gov/docs-filing/efiling.asp>. Commenters can submit brief comments up to 6,000 characters, without prior registration, using the eComment system at <http://www.ferc.gov/docs-filing/ecomment.asp>. You must include your name and contact information at the end of your comments. For assistance, please contact FERC Online Support at FERCOnlineSupport@ferc.gov, (866) 208-3676 (toll free), or (202) 502-8659 (TTY). In lieu of electronic filing, you may send a paper copy. Submissions sent via the U.S. Postal Service must be